

HOT WORK INSPECTION CHECKLIST

FIELD INSPECTION DOCUMENT

Project / Site	Date / Time	Inspector
Location / Area	Hot Work Permit No.	Company / Contractor

1

PERMIT AND AUTHORIZATION

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
1	A valid hot work permit is available for the task and location.	☐	☐	☐	CRITICAL	
2	The permit is displayed or immediately available at the work location.	☐	☐	☐	STANDARD	
3	Required permit approvals and signatures are complete.	☐	☐	☐	CRITICAL	
4	The task-specific risk assessment or JSA has been reviewed.	☐	☐	☐	CRITICAL	
5	A task-specific toolbox talk has been completed and recorded.	☐	☐	☐	STANDARD	
6	Simultaneous operations and nearby activities have been assessed.	☐	☐	☐	STANDARD	

2

PERSONNEL AND COMPETENCY

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
7	Personnel performing the work are trained, competent and authorized.	☐	☐	☐	CRITICAL	
8	A competent supervisor is assigned and available.	☐	☐	☐	STANDARD	
9	Workers understand the emergency alarm, escape route and assembly point.	☐	☐	☐	STANDARD	

3

ATMOSPHERIC TESTING

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
10	The need for atmospheric testing has been formally assessed.	☐	☐	☐	CRITICAL	
11	The gas detector is suitable, within calibration and function-tested.	☐	☐	☐	CRITICAL	
12	Oxygen concentration is within the site-approved safe range.	☐	☐	☐	CRITICAL	

3 ATMOSPHERIC TESTING

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
13	Flammable gas or vapour concentration is below the permitted limit.	☐	☐	☐	CRITICAL	
14	Toxic gases relevant to the area have been tested where required.	☐	☐	☐	CRITICAL	
15	Continuous or periodic atmospheric monitoring is arranged where conditions may change.	☐	☐	☐	CRITICAL	

4 FIRE PREVENTION AND FIRE WATCH

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
16	Combustible and flammable materials have been removed or effectively protected.	☐	☐	☐	CRITICAL	
17	Suitable fire extinguishing equipment is immediately available.	☐	☐	☐	CRITICAL	
18	A trained fire watch has been assigned where required.	☐	☐	☐	CRITICAL	
19	The fire watch understands alarm methods, extinguisher use and stop-work authority.	☐	☐	☐	CRITICAL	
20	Openings, penetrations, drains and gaps are protected from sparks and slag.	☐	☐	☐	CRITICAL	
21	Spark and slag containment is effective for the work configuration.	☐	☐	☐	CRITICAL	
22	Fire detection or suppression systems affected by the task are properly managed.	☐	☐	☐	CRITICAL	
23	Post-work fire monitoring duration has been defined.	☐	☐	☐	CRITICAL	

5 EQUIPMENT AND GAS CYLINDERS

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
24	Hot work equipment has passed the required pre-use inspection.	☐	☐	☐	CRITICAL	
25	Electrical cables, plugs, electrode holders and connections are undamaged.	☐	☐	☐	CRITICAL	
26	The welding return connection is secure and positioned appropriately.	☐	☐	☐	CRITICAL	
27	Gas cylinders are upright, secured and protected from damage.	☐	☐	☐	CRITICAL	

5

EQUIPMENT AND GAS CYLINDERS

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
28	Oxygen and fuel-gas equipment is free from oil, grease and contamination.	☐	☐	☐	CRITICAL	
29	Hoses, regulators, valves and connections are compatible and leak-free.	☐	☐	☐	CRITICAL	
30	Required flashback arrestors and non-return valves are correctly installed.	☐	☐	☐	CRITICAL	
31	Grinding wheels and cutting discs are suitable, undamaged and within their rated speed.	☐	☐	☐	CRITICAL	
32	Machine guards and handles are installed and correctly positioned.	☐	☐	☐	CRITICAL	

6

PERSONAL PROTECTIVE EQUIPMENT

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
33	Eye and face protection is suitable for the hot work process.	☐	☐	☐	CRITICAL	
34	Flame-resistant clothing provides adequate body coverage.	☐	☐	☐	CRITICAL	
35	Gloves are suitable for heat, sparks and the task being performed.	☐	☐	☐	STANDARD	
36	Safety footwear is suitable and protects against hot material.	☐	☐	☐	STANDARD	
37	Hearing protection is provided where noise exposure requires it.	☐	☐	☐	STANDARD	
38	Respiratory protection is provided where fumes or contaminants cannot be adequately controlled otherwise.	☐	☐	☐	CRITICAL	
39	Fall protection is provided where work-at-height exposure exists.	☐	☐	☐	CRITICAL	

7

WORK AREA AND ENVIRONMENTAL CONDITIONS

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
40	The work area is barricaded and warning signs are displayed.	☐	☐	☐	STANDARD	
41	Ventilation is adequate for fumes, gases and heat generated by the task.	☐	☐	☐	CRITICAL	
42	Lighting is sufficient for safe work and inspection.	☐	☐	☐	STANDARD	

7

WORK AREA AND ENVIRONMENTAL CONDITIONS

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
43	Access and emergency escape routes are clear.	☐	☐	☐	CRITICAL	
44	Housekeeping is acceptable and trip hazards are controlled.	☐	☐	☐	STANDARD	
45	Weather conditions are suitable for the work.	☐	☐	☐	STANDARD	
46	Screens or barriers protect nearby personnel from arc radiation and flying particles.	☐	☐	☐	STANDARD	

8

MONITORING DURING WORK

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
47	Permit conditions and control measures remain effective throughout the work.	☐	☐	☐	CRITICAL	
48	The fire watch remains in position and continuously observes the risk area.	☐	☐	☐	CRITICAL	
49	Workers continue to use required PPE correctly.	☐	☐	☐	STANDARD	
50	No gas leak, unexpected odour, alarm or process release is present.	☐	☐	☐	CRITICAL	
51	Hot slag, sparks and workpieces remain contained and controlled.	☐	☐	☐	CRITICAL	

9

COMPLETION AND POST-WORK INSPECTION

#	Inspection Item	YES	NO	N/A	Priority	Comments / Action
52	The hot work equipment has been safely shut down and isolated.	☐	☐	☐	CRITICAL	
53	The work area and all potentially affected levels have been inspected.	☐	☐	☐	CRITICAL	
54	The required post-work fire-watch period has been completed and recorded.	☐	☐	☐	CRITICAL	
55	Hot materials, electrode stubs, slag and waste have been safely removed.	☐	☐	☐	STANDARD	
56	Temporary barriers, covers and fire protection controls are removed only when safe.	☐	☐	☐	STANDARD	
57	The permit has been formally closed by the authorized persons.	☐	☐	☐	CRITICAL	

FINDINGS & CORRECTIVE ACTIONS

Total Items	YES	NO	N/A	Open Findings
_____	_____	_____	_____	_____

Finding	Action	Responsible	Due	Status

FINAL AUTHORIZATION

Inspector

Name / Signature / Date

Supervisor

Name / Signature / Date

Permit Issuer

Name / Signature / Date