

HVAC SCHEDULE (DRAFT) — DO NOT USE NOTES COLUMN

Project: Harborview Lab Expansion | Doc No. M-601D | WORKING COPY

The MCA (A) column is feeder sizing only. Capacity is the scheduled airflow or flow rate, not the MCA value. A reviewer note on AHU-01 says “confirm 250 kW feeder” — that is electrical, not mechanical capacity.

Tag	MCA (A)	Qty	Capacity	Manufacturer	Type
AHU-01	250	2	25,000 CFM	Trane	Air Handling Unit
AHU-02	180	1	18,000 CFM	Carrier	Air Handling Unit
P-101	32	4	250 GPM	Grundfos	Centrifugal Pump
P-102	18	2	120 GPM	Bell & Gossett	Centrifugal Pump
FCU-03	12	6	1,200 CFM	Daikin	Fan Coil Unit
EF-04	40	3	5,000 CFM	Greenheck	Exhaust Fan
VAV-12	8	8	800 CFM	Titus	VAV Box