

MECHANICAL EQUIPMENT SCHEDULE

Project: Harborview Lab Expansion | Doc No: M-601 | Rev. A

Tag	Type	Qty	Capacity	Manufacturer
AHU-01	Air Handling Unit	2	25,000 CFM	Trane
AHU-02	Air Handling Unit	1	18,000 CFM	Carrier
P-101	Centrifugal Pump	4	250 GPM	Grundfos
P-102	Centrifugal Pump	2	120 GPM	Bell & Gossett
FCU-03	Fan Coil Unit	6	1,200 CFM	Daikin
EF-04	Exhaust Fan	3	5,000 CFM	Greenheck
VAV-12	VAV Box	8	800 CFM	Titus

Notes: Capacities are design values at scheduled conditions. Verify nameplate data during commissioning.