

KITCHEN VENTILATION SCHEDULE

Project: Harborview Lab Expansion | Doc No. M-710 | Rev. A

Tag	Type	Qty	Capacity	Manufacturer
KE-01	Exhaust Hood	2	5,000 CFM	CaptiveAire
KE-02	Makeup Air Unit	2	4,500 CFM	Greenheck
KE-03	Dishwasher Exhaust	1	800 CFM	Greenheck