

# DIVISION 26 / 23 — OWNER PROJECT REQUIREMENTS

Harborview Lab Expansion | OPR-2024-08

## Emergency Power

Emergency generator must have minimum capacity of 500 kW. The unit shall be diesel standby rated and serve life-safety loads.

## Air Handling

Each air handling unit shall provide a minimum capacity of 10000 CFM at design cooling conditions.

## Hydronic Pumps

Centrifugal pumps serving primary chilled water shall have a quantity of at least 2 (duty plus standby or multiple duty).

Compliance is determined by comparing scheduled equipment values against these thresholds. Field verification remains required.