

FIRESAFETY CERTIFICATE

NO.

Dated 20/5/26

Certified that the Channawars vidya mandir school building (name of the building or premises) at yelakeli tail selu dist Wardha comprised of Zen basement and(s) 3 floors(upper floors) owned / occupied by Channawars vidya mandir (Name of Institution) have compiled with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on 20/5/26(Date of inspection) in the presence Of Channawars vidya mandir school principal Survey No 102/03 Sawangi Meghe (Name and addresses of the Manager/Secretary or his representative) and that the building/ premises is fit for occupancy upto classes Xth Month (X/XII) with effect from 20/5/26 for a period of 6 month in accordance with rule and subject to compliance of the specific conditions as appended

1. Maharashtra Fire Prevention and Life Saving Measures Act 2006 and All the provisions of the Measures Rules 2009 should be complied with. In this regard, the Fire Fighting System should be kept ready.
2. Sprinklers pumping, hydrate, detection and fire suppression systems should be kept ready at high temperature locations.
3. Trained personnel, Fire Fighting Equipment and Systems should be kept ready for disaster management.
4. Care should be taken that accidents and loss of life do not occur at the electricity supply site.
5. If there is any objection from Maharashtra Fire Service Directorate or higher authority, the said non-invalidation certificate will be cancelled.
6. It will be mandatory to comply with the provisions of the Maharashtra City Councils, Nagar Panchayats and Industrial Cities Act, 1965.
7. The said fire proof certificate will remain valid for 6 month from the date of issue.

Issued on 20/5/26. (date of issue) at Wardha (place) by



Signature with Seal:-

Name :-

Ashok Lokhande

Designation:-

Name & Address of Department Office

अग्निशमन अधिकारी
अग्निशमन विभाग
नगर परिषद, वर्धा

To

Channawars vidya mandir school building
(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to



VISHWAKARMA & ASSOCIATES

IN FIRE & SAFETY SINCE -1979

- Fire Engineer (NFSC)
- Member Of Fire Expert Committee (MSBTE)
- Authorised Safety Auditor (DISH)
- Breathing Apparatus
- Qualified Fire Auditor – MFPR – 2009
- Expert Panelist (NSC)
- Safety Diploma (CLI)
- Experties in NFPA/NBC/Factories Act
- Advisory On Concession

FORM - A

CERTIFICATE

(See section 3(3) and rule 4(19) Certificate by The Licensed Agency Regarding the Compliance of
The Fire Prevention and Life Safety Measures
Certificate

Certificate that we have executed the work towards compliance in relation to Fire Prevention and life safety Measures to be Provided and Performed Other related activities required to be carried out, in the following building or premises as required under the provisions of Maharashtra Fire Prevention and Life Safety Measures Act 2006 (Mah III of 2007)

CATALYST PLAZA

Address: BACHELOR ROAD, WARDHA-442001


The details of the work and related activities which we have executed or performed are mentioned in the list appended here with .

Place: Bachelor Road, WARDHA-442001

Date of Issue: 12.05.2026

KAILASH KANDUJI
VISHWAKARMA

Digitally signed by KAILASH
KANDUJI VISHWAKARMA
Date: 2026.05.12 07:21:18
+05'30'



Authorized Signatory
Address of the Licensed Agency
M/s. Vishwakarma & Associates
Survey No. 32, Flat No. 103, Plot No. 48,
Tulip Apartment,
Tingre Nagar, Pune-411032
Ex-Faculty – National Fire Service College, Nagpur
Advance Diploma In fire engineering - NFSC
Grade-I fire engineer (India)



VISHWAKARMA & ASSOCIATES

IN FIRE & SAFETY SINCE 1979

- Fire Engineer (NFSC)
- Member Of Fire Expert Committee (MSBTE)
- Authorised Safety Auditor (DISH)
- Breathing Apparatus
- Qualified Fire Auditor – MFPR – 2009
- Expert Panelist (NSC)
- Safety Diploma (CLI)
- Experties in NFPA/NBC/Factories Act
- Advisory On Concession

To,
Fire officer

Annexure – FORM - A

CATALYST PLAZA

Address: BACHELOR ROAD, WARDHA-442001

Sub: Equipment Installed in the Premises –


SR.	PARTICULARS	QTY	Status
1	HYDRANT VALAVE	4 NOS	OKAY
2	HOSE PIPE	4 NOS	OKAY
3	HOSE REEL	4 NOS	OKAY
4	SPRINKLER	25 NOS	OKAY
5	FIRE EXTINGUISHER CO2 4.5KG	1 NOS	OKAY
6	FIRE EXTINGUISHER ABC 6KG	4 NOS	OKAY
7	2-WAY INLET	1 NOS	OKAY

Place: Bachelor Road, WARDHA-442001

Date of Issue: 12.05.2026

KAILASH KANDUJI
VISHWAKARMA

Digitally signed by KAILASH
KANDUJI VISHWAKARMA
Date: 2026.05.12 07:21:37
+05'30'



Address of the Licensed Agency
M/s. Vishwakarma & Associates
Survey No. 32, Flat No. 103, Plot No. 48,
Tulip Apartment,
Tingre Nagar, Pune-411032
Ex-Faculty – National Fire Service College, Nagpur
Advance Diploma In fire engineering – NFSC,
Grade-I fire engineer (India)