Solid, Liquid & E-Waste Management Audit Report 2024-25

Institution: Vidyapath Institute of Technology (VITEC) | Academic Year: **2024-25** | Department: **Estate Office**

Document ID: DOC-ACCR-027	**Criterion: Criterion 7**	**Status: ACTIVE**
Subcriterion: 7.1 Institutional Values & Environmental Responsibility	**Lead Officer: Er. D. Madhav Rao, Estate Officer**	**Approved Date: 2025-05-08**

EXECUTIVE SUMMARY & ACCREDITATION SCOPE

Audit of campus sewage treatment plant (STP), organic composting, hazardous waste disposal, and certified e-waste recycling MOUs.

Section 1: Waste Processing and Water Recycling Systems

The on-campus Sewage Treatment Plant (STP) with 100 KLD capacity operates continuously, recycling 85 KLD of treated grey water for campus landscaping and toilet flushing.

Electronic waste is systematically segregated and handed over bi-annually to authorized recyclers under an institutional disposal agreement with Earth-Sense Recycle Ltd.