Annexure 4A

OFFICE OF THE SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY,ALWAR

Lab/Tech/(Private)/2025-26/ 444 Dated : 15/9/25

EXAMINATION REPORT OF THE PRIVATE WATER SAMPLES

Issued To,

National Academy
Day Bording Eng.Medium School Vijay Mandir Road
Alwar

District: **Alwar**
Block/City: **Alwar**

Ref_ID :	89	**Lab Sample No. :**	**89**
Reference :Your Letter No.:	0	Source :	Tank
Reference Dated :	09.09.25	Source Location :	Day Bording Eng.Medium School Vijay Mandir Road
Date of Receipt :	09.09.25	Habitation/Ward No. :	Alwar
Name of Sample Taker :	Mr.Neeraj Sharma	Village/Colony/Town :	Alwar
Desig. of Sample Taker :	Principal	Gram Panchayat/City Area :	Alwar
GA-55 Book No. :	019763	Date of Collection :	09.09.25
GA-55 Receipt No. :	0082	Date of Examination :	09.09.25
Amount in Rs. :	297.00	Amount Deposited for :	Chem/Bact Testing of Water Sample

	Test Parameters	*IS-10500:2012* Requirement (Acceptable Limit)	*IS-10500:2012* Permissible limit in the absence of alternative sources	Test Values of Samples
1	pH	6.5 to 8.5	No Relaxation	7.0
2	Turbidity(NTU)	5	15	Clear
3	Colour (Hazen Unit)	1	5	-
4	Odour	Unobjectionable	-	-
5	Total Alkalinity (as $CaCO_3$) mg/L	200	600	120
6	Total Hardness (as $CaCO_3$) mg/L	300	600	240
7	Calcium (as Ca++) mg/L	75	200	
8	Magnesium (as Mg++) mg/L	30	100	
9	Chloride (as Cl^-) mg/L	600	1000	80
10	Sulphate (as $SO_4^{-2)}$ mg/L	200	400	0
11	Nitrates (as NO_3^-) mg/L	45	No Relaxation	18
12	Fluoride (as F^-) mg/L	1.00	1.50	0.42
13	Total Dissolved Solids (TDS) mg/L	500	2000	493
14	Residual Chlorine (mg/L)	0.20	1.00	-
15	Total Coli Form/100 ml.	NIL/100 ml.	NIL/100 ml.	0
16	E-Coli/ 100 ml.	NIL/100 ml.	NIL/100 ml.	-

(1) The Sample was not collected by this Laboratory.
(2) Not valid for water quality Legal Cases.

Senior Chemist
PHED, Lab, Alwar
Dated:

Lab/Tech/(Private)/2025-26/
Copy to:
1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.
2
3

Senior Chemist

Safe Water is Life *Save Water Save Life*