

**STATE WATER TESTING LABORATORY, R.W.S.&S. ODISHA
KHANDAGIRI, BHUBANESWAR.**

Phone – (0674) 2951880; E-mail – rwsscentrallabodisha@gmail.com

No. 1777 (WE) Dt. 29.09.26

To

**Sai International School
Infocity Road, Patia, Bhubaneswar, 751024**

Sub: Test report of water samples0

Ref: Your letter No. Nil/ Dt. 28.09.2026

Sir,

The test report of the water samples sent to this Laboratory for testing of Chemical Parameters Analysis is enclosed herewith for your information.

//Enclosed: - As above.

Yours faithfully,


Analyst (Chemist)

State Water Testing Laboratory,
RWSS(O)Khandagiri, Bhubaneswar.

C.C. Submitted to:

- Engineer-in-Chief, RWS&S(O), Bhubaneswar for favour of kind information.
- Chief Engineer-I, RWS&S/Chief Engineer-II, RWS&S Odisha, Bhubaneswar for favour of kind information.
- Nodal Officer (WQ), State Water Testing Laboratory, RWSS (O)Khandagiri, Bhubaneswar for favour of information.

STATE WATER TESTING LABORATORY, R.W.S.&S., ODISHA KHANDAGIRI, BHUBANESWAR

Phone – (0674) 2951880; E-mail. – rwsscentrallabodisha@gmail.com



WATER ANALYSIS REPORT

TEST REPORT NO.- SWTL-TR/1995/2026/S1-S1

ULR - TC60942600001653

DATE OF ISSUE – 29.09.2026



TC-6094

Sample Particulars		Details of Sampling	
Name of the Customer :-	Sai International School Infocity Road, Patia, Bhubaneswar, 751024	Type of Source:-	Drinking Water/Tap
		Date of Sampling:-	26.09.2026
Sample Package Condition:-		Sample receive date: -	28.09.2026 / Vide letter No. Nil /
		Vide letter No.	Dated/28.09.2026
a) Quantity of Sample Received -1 ltr. b) Type of Container - pp		Sample Registration Date:-	28.09.2026
		Sampling Protocol:-	Samples are not collected by this laboratory.
		Sample Collected by:-	Kalinga Swain
		Sample Location:-	Sai International School Infocity Road, Patia, Bhubaneswar, 751024

TEST RESULT

Test Started on-		29.09.2026		Test Completed on-		29.09.2026	
Sl.	Test Parameters	Units	Results	Requirements IS 10500 : 2012		Test Method	
				Acceptable Limit	Permissible Limit in absence of alternate source		
1	Colour	Hazen Unit	1- 4.0	5	15	APHA 24 th Ed., 2023 - 2120 B [Visual Comparison Method]	
2	pH	pH Unit	1- 7.55	6.5 to 8.5	No relaxation	APHA 24 th Ed. 4500-H ⁺ B (Electrometric Method)	
3	Total Dissolve Solid (TDS)	mg/l	1- 118.49	500	2000	APHA 24 th Ed., 2023 – 2540 TDS C [TDS Dried at 180°C]	
4	Chloride	mg/l	1- 28.0	250	1000	APHA 24 th Ed. 4500 Cl- B (Argentometric Method)	
5	Total Hardness (as CaCO ₃)	mg/l	1- 76.0	200	600	APHA 24 th Ed. 2340 C (EDTA Titration Method)	
6	Total Alkalinity (as CaCO ₃)	mg/l	1- 24.0	200	600	APHA 24 th Ed. 2320 B (Titration Method)	
7	Fluoride (as F ⁻)	mg/l	1- <0.10	1.0	1.5	APHA 24 th Ed. 4500 F ⁻ C (Ion -Selective Electrode Method)	
8	Iron	mg/l	1- 0.176	1.0	No relaxation	APHA 24 th Ed. 3500 Fe B; (Phenanthroline Method)	
9	Turbidity	NTU	1- 2.59	1.0	5.0	APHA 24 th Ed. 2130 B (Nephelometric Method)	
10	Calcium (as Ca)	mg/l	1- 14.43	75	200	APHA 24 th Ed. 3500 Ca B (EDTA Titrimetric Method)	

Note :- The samples were tested with dilution.

Information on Test Report :

Results relates only to samples received in the Laboratory.

The test report shall not be reproduced except in full without written approval of SWTL.

APHA – American Public Health Association

Reviewed by

Chemist II

Analyst (Chemist) & Quality Manager,
State Water Testing Laboratory
Authorised Signatory

***** End of Report*****

**STATE WATER TESTING LABORATORY, R.W.S.&S., ODISHA
KHANDAGIRI, BHUBANESWAR**

Phone – (0674) 2951880; E-mail. – rwsscentrallabodisha@gmail.com



WATER ANALYSIS REPORT

TEST REPORT NO.- SWTL-TR/1995/2026/S1

DATE OF ISSUE – 29.09.2026

Sample Particulars		Details of Sampling	
Name of the Customer :-	Sai International School Infocity Road, Patia, Bhubaneswar, 751024	Type of Source:-	Drinking Water/Tap
		Date of Sampling:-	26.09.2026
		Sample receive date:- Vide letter No.	28.09.2026 / Vide letter No. Nil / Dated/28.09.2026
Sample Package Condition:- a) Quantity of Sample Received – 1 ltr. b) Type of Container - pp		Sample Registration Date:-	28.09.2026
		Sampling Protocol:-	Samples are not collected by this laboratory.
		Sample Collected by:-	Kalinga Swain
		Sample Location:-	Sai International School Infocity Road, Patia, Bhubaneswar, 751024

TEST RESULT

Test Started on-		29.09.2026		Test Completed on-		29.09.2026
Sl.	Test Parameters	Units	Result	Requirements IS 10500 : 2012		Test Method
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	Odour	-----	1- Agreeable	Agreeable	Agreeable	IS3025(Part 5):2018
2	Nitrite (as NO ₂ ⁻)	mg/l	1- Not Detected	---	---	APHA 24 th Ed. – 4500 NO ₂ [Colourimeter Method]
3	Residual Chlorine	mg/l	1- Not Detected	0.2	1.0	Visual Comparison Method (O T Method)

Note :- The samples were tested with dilution.

Information on Test Report:

Results relates only to samples received in the Laboratory.

The test report shall not be reproduced except in full without written approval of SWTL.

APHA – American Public Health Association // IS Indian Standard

Reviewed by

Chemist II

Analyst (Chemist)

State Water Testing Laboratory,
RWSS (O)Khandagiri, Bhubaneswar

***** End of Report*****

**Orissa Industrial Infrastructure
Development Corporation**

(A Government of Orissa Undertaking)
Phones: (0674) 542784, 540820, Fax-542956
E-Mail: mdidco @ dte.vsnl.net.in
No. BCD-I/Civil/ E-3645/01-99/

Idco

Your power to grow
ISO 9001 & 14001 CORPORATION

3401 Date. 06/05/08

To,

M/s.SAI International School,
Plot No.5/A,Industrial Estate,Chandaka,
Bhubaneswar,Dist:Khurda.

Sub: Certificate for issuance of affiliation from CBSE.

Dear Sir,

With reference to your letter No.SIS/2007-08/052,dt.30.04.2008 on the above noted subject, it is to inform you that the infrastructure facilities such as roads, drainage system, water supply & street light facilities are provided & maintained by IDCO in Chandaka Industrial Estate & the same has been obtained/availed by M/s.SAI International School, Plot No.5/A,Industrial Estate, Chandaka, Bhubaneswar.

This is to further certify that the sanitary and water supply system with PHD plans have been approved by us keeping in view the existing Government Guidelines.

This is for your information & necessary action.

Yours faithfully,

[Signature]
Divisional Head, BCD-I

Memo No. /Dt.

Copy to the Chief General Manager(ID),IDCO, Bhubaneswar for favour of kind information.

[Signature]
Divisional Head, BCD-I

[Signature]

