

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382,

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT

SHEET 1 of 3

NAME AND ADDRESS OF CUSTOMER Savita Oil Technologies Limited. 17/17A, Thane Belapur Road, P.O. Vashi, Navi Mumbai.		REPORT No RP-2425-005920 DATE OF ISSUE 24/05/2024 CUSTOMER REF No. Letter DATED 06/05/2024 DATE OF SAMPLE RECEIPT 08/05/2025 DATES OF TESTING 13/05/2024 to 16/05/2024
SAMPLE DESCRIPTION (As provided by customer) Unused Synthetic Ester oil. TRANSOL SYNTH. 100 (Unused Synthetic Ester insulating fluid), Batch No. 01203SE24, Make : M/s Savita Oil Technologies Ltd., Date : 06/05/2024. Quantity of sample: 2.5 Litres. (1 No. x 2.5 litres in glass bottle)		SAMPLE IDENTIFICATION ERDA Sample Code No.: ERDA-00580662
Sr.No.	TEST DETAILS	TEST SPECIFICATION
1.	Colour #	ASTM D 1500-2012 #
2.	Crystallization	IEC 61099-2010
Notes: 1. This test report is in continuation of our test report RP-2425-005919 dtd. 24/05/2024 issued for accredited tests. These tests have been carried out on same sample ERDA Sample code no. ERDA-00580662 submitted to ERDA. 2. # Test as requested by the customer.		
Remarks : 1. * As requirement is not known, hence remarks about conformity has not been given. 2. Photos of box containing sample bottle and sample bottle in as received condition are provided on sheet 3 of 3.		
CHECKED BY 		APPROVED BY  (Mr. A.B.PATIL)
NOTE	1. This report relates only to the particular sample received for testing in good condition at ERDA, Vadodara 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, ERDA. 4. This report shall not be used for any purpose such as PR brochures, propaganda, advertisement and/or legal proceedings, unless for the granted purpose. 5. Only the tests asked for by the customer have been carried out. 6. Particulars of manufacturer/supplier, given in this report are based on information supplied by the customer, along with the test request/sample. ERDA does not assume any responsibility for the correctness of the information for above mentioned Sample under test (SUT). ERDA will not be responsible for any changes in SUT made after the test. This test report is given as per instrument status while testing. 7. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen.	
Caution :	ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA within 10 years of date of issue of report.	

2381255

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382,

E-mail : erda@erda.org

Web : http://www.erda.org



TEST REPORT No. RP-2425-005920		DATE OF ISSUE : 24/05/2024		SHEET 2 of 3
Sr. No.	Particular of tests & Cl. No.	Requirement as per specification	Obtained value	Remarks
1.	Colour # (Cl. No. 9)	*	L 0.5	*
2.	Crystallization (Cl. No. 7.1.7)	*	Crystal Absent	*
<i>semeal</i> CHECKED BY				



2381256

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33,

Fax : +91 (0265) 2638382,

E-mail : erda@erda.org

Web : <http://www.erda.org>



TEST REPORT No. RP-2425-005920

DATE OF ISSUE : 24/05/2024

SHEET 3 of 3



Photos of box containing sample bottle and sample bottle in as received condition.

semaal
CHECKED BY

***** End of Test Report *****



2381257