

ECHONET Lite Physical Property Test Report

Generated: 2025-05-22 13:03:28

EPC	Description	Initial Value	Updated Value	Verdict
0x80	Operation status	31	30	Pass
0x81	Installation location	00	01	Pass
0x97	Current time setting	0D02	1234	Pass
0x98	Current date setting	07E90516	07E90516	Fail
0xA0	Output power control setting 1	00	01	Pass
0xA1	Output power control setting 2	0000	0001	Pass
0xA2	Function to control purchase o	41	42	Pass
0xC1	FIT contract type	41	43	Pass
0xE2	Reset cumulative amount of ele	No response	No response	Fail
0xE4	Reset cumulative amount of ele	No response	No response	Fail
0xE5	Power generation output as % o	00	01	Pass
0xE6	Power generation output in wat	0000	0001	Pass
0xE7	Electricity sold in watts	0000	0001	Pass
0xE8	Rated power output (system-int	0000	0001	Pass
0xE9	Rated power output (independen	0000	0001	Pass