

# Learning Based Model Predictive Control

**Saket Adhau**

MIS: 121717001

Guide: Dr. Dayaram Sonawane

April 11, 2021




# Problem Statement

Administration of Anesthesia to control pain during surgery




# General Anesthesia

## Breathing Mask/Intubation



# General Anesthesia


## Breathing Mask/Intubation





## Intravenous (IV) line





# Measuring the Depth of Anesthesia





# Measuring the Depth of Anesthesia



# Measuring the Depth of Anesthesia



# Measuring the Depth of Anesthesia



The Difference Between  
**Normal Oxygen Levels**  
and Low Oxygen Levels


## BODY TEMPERATURE






# Bispectral Index (BIS)

- Depth of Anesthesia
- Scale 0 – 100




## Experience Based




# Drug Administration Strategies

## Experience Based



## Algorithm Based



- Proportional-Integral-Derivative (PID)
  1. Simplest Controller
- Model Predictive Control (MPC)
  1. Model based control
  2. Constraint handling
- Deep Neural Network based MPC
  1. Robustness to uncertainties in model
  2. Less Computational Complexity as compared to MPC

- Proportional-Integral-Derivative (PID)
  1. Simplest Controller
- Model Predictive Control (MPC)
  1. Model based control
  2. Constraint handling
- Deep Neural Network based MPC
  1. Robustness to uncertainties in model
  2. Less Computational Complexity as compared to MPC

# Available Control Schemes

- Proportional-Integral-Derivative (PID)
  1. Simplest Controller
- Model Predictive Control (MPC)
  1. Model based control
  2. Constraint handling
- Deep Neural Network based MPC
  1. Robustness to uncertainties in model
  2. Less Computational Complexity as compared to MPC

# Available Control Schemes

- Proportional-Integral-Derivative (PID)
  1. Simplest Controller
- Model Predictive Control (MPC)
  1. Model based control
  2. Constraint handling
- Deep Neural Network based MPC
  1. Robustness to uncertainties in model
  2. Less Computational Complexity as compared to MPC

# Available Control Schemes

- Proportional-Integral-Derivative (PID)
  1. Simplest Controller
- Model Predictive Control (MPC)
  1. Model based control
  2. Constraint handling
- Deep Neural Network based MPC
  1. Robustness to uncertainties in model
  2. Less Computational Complexity as compared to MPC



# Available Control Schemes


- Proportional-Integral-Derivative (PID)
  1. Simplest Controller
- Model Predictive Control (MPC)
  1. Model based control
  2. Constraint handling
- Deep Neural Network based MPC
  1. Robustness to uncertainties in model
  2. Less Computational Complexity as compared to MPC

# Available Control Schemes

- Proportional-Integral-Derivative (PID)
  1. Simplest Controller
- Model Predictive Control (MPC)
  1. Model based control
  2. Constraint handling
- Deep Neural Network based MPC
  1. Robustness to uncertainties in model
  2. Less Computational Complexity as compared to MPC


- Proportional-Integral-Derivative (PID)
  1. Simplest Controller
- Model Predictive Control (MPC)
  1. Model based control
  2. Constraint handling
- Deep Neural Network based MPC
  1. Robustness to uncertainties in model
  2. Less Computational Complexity as compared to MPC

# PK-PD Model of the Patient



Pharmacodynamics

# Model Predictive Control (MPC)



Use a dynamical **model** of the process to **predict** its future evolution and choose the “best” control action

# Embedded Control Systems: Main Requirements

- **Model-based**, **optimal** performance, **constraints**
- **Control law simple enough** for software certification
- Require **simple hardware** (e.g., **cheap** and **fast FPGA**)
- **Speed**: fast dynamics  $\Rightarrow$  **short sample time** ( $< 1 \mu s$ )
- Well defined worst-case execution time, to certify **hard real-time** system properties



# Main Drawbacks of On-line Optimization

😊 Excellent QP solvers available today

**but ...**

- 😞 Computation time may be too long
- 😞 Requires relatively expensive hardware
- 😞 Cannot handle uncertainties in the model
- 😞 Not suitable of safety critical applications

## How it works ?


A neural network consists of highly connected networks of neurons that relate the inputs to the desired outputs. The network is trained by iteratively modifying the strengths of the connections so that given inputs map to the correct response.



# Deep Neural Networks

## Best used for:

- For modeling highly nonlinear systems
- When data is available incrementally and you wish to constantly update the model
- When there could be unexpected changes in your input data



# Deep Neural Networks based MPC






Figure: Replacing MPC with deep neural network trained model.


# Implementation of a Real-time Explicit MPC




# Implementation of a Real-time Explicit MPC



# Implementation of a Real-time Explicit MPC



# Implementation of a Real-time Explicit MPC




# Training of the Controller

Scenario	Target Values	MSE
Training	35000	$6.28241 \times 10^{-9}$
Validation	7500	$1.14839 \times 10^{-6}$
Testing	7500	$1.40538 \times 10^{-8}$


**Table:** Training statistics with 50000 data-points in which 70% was allocated for training while 15% each for testing and validation

# Training Performance






# Training Auto-Correlation




## Atmel's ARM Cortex-M3:

- 32-bit microcontroller running at 84MHz.
- 512kB of program memory and 96kB of SRAM.
- Mostly prefer in embedded automotive applications.




# Hardware-in-loop (HIL) Work Flow




# Case Study

- Patient of age 25 years and 63 kg weight
- BIS between 40 – 60
- Input constraints 0 – 20 mg/kg/h


# HIL Simulations Results




# HIL Simulations Results



# HIL Simulations Results



# HIL Simulations Results





# Computational Time and Memory Calculations

Controller	Memory [%]		Run-time [ms]
	% Data Usage	% Program Usage	
Linear MPC	3.50	4.90	11.354
DNN MPC	3.01	3.92	2.999

**Table:** Memory footprints and run-time results of proposed DNN-MPC and LMPC.

# Conclusion

- This work proposes the use of deep neural networks to approximate linear MPC control law, efficiently and effectively with minimal computational efforts for real-time embedded implementation.
- Computational time reduced to as much as  $4\times$  times
- Promising approach for safety-critical applications running on embedded systems.
- Future work will include to make complex non-linear MPC solutions using deep neural networks to use them on embedded hardware.

- [1] S. Adhau, S. Patil, D. Ingole, and D. Sonawane, "Embedded Implementation of Deep Learning-based Linear Model Predictive Control," (*Submitted*).
- [2] S. Adhau, S. Patil, D. Ingole, and D. Sonawane, "Implementation and Analysis of Nonlinear Model Predictive Controller on Embedded Systems for Real-Time Applications," in *2019 European Control Conference (ECC)*, Naples, Italy. IEEE, 2019.
- [3] S. Adhau, K. Phalke, A. Nalawade, D. Ingole, S. Patil and D. Sonawane, "Implementation and Analysis of Offset-Free Explicit Model Predictive Controller on FPGA," in *2019 Fifth Indian Control Conference (ICC)*, New Delhi, India, 2019, pp. 231-236.
- [4] S. Adhau, S. Dani, D. Ingole, S. Patil and D. Sonawane, "Embedded Model Predictive Controller on Low-Cost Low-End Microcontroller for Electrical Drives," in *2018 I2CT*, India, 2018.

- [1] S. Lucia, D. Navarro, B. Karg, H. Sarnago, and O. Lucia, “Deep Learning-Based Model Predictive Control for Resonant Power Converters,” *arXiv preprint arXiv:1810.04872*, 2018..
- [2] U. Rosolia and F. Borrelli, “Learning model predictive control for iterative tasks. a data-driven control framework,” *IEEE Transactions on Automatic Control*, pp. 1883–1896, 2017.
- [3] Y. Sawaguchi, E. Furutani, G. Shirakami, M. Araki, and K. Fukuda, “A model-predictive hypnosis control system under total intravenous anesthesia,” *IEEE transactions on biomedical engineering*, pp. 874– 887, 2008.
- [4] D. Ingole and M. Kvasnica, “FPGA implementation of explicit model predictive control for closed loop control of depth of anesthesia,” *IFAC-PapersOnLine*, pp. 483–488, 2015.

# Back-up Slides

$$A = \begin{bmatrix} -\frac{k_1 + k_2 + k_3 + k_4}{V_1} & \frac{k_2}{V_1} & \frac{k_3}{V_1} & \frac{k_4}{V_1} \\ \frac{k_2}{V_2} & -\frac{k_2}{V_2} & 0 & 0 \\ \frac{k_3}{V_3} & 0 & -\frac{k_3}{V_3} & 0 \\ \frac{k_4}{V_4} & 0 & 0 & -\frac{k_4}{V_4} \end{bmatrix},$$

$$B = \begin{bmatrix} \frac{1}{V_1} & 0 & 0 & 0 \end{bmatrix}^T, C = \begin{bmatrix} 0 & 0 & 0 & 1 \end{bmatrix}^T, \text{ and } D = \begin{bmatrix} 0 \end{bmatrix}.$$

# Model Parameters

Parameter	Value
$k_1$	$0.0595^{0.75}$ L/min (age $\leq 60$ ) $(0.0595BW^{0.75} - 0.45AGE + 2.7)$ L/min (age $> 60$ )
$k_2$	$0.0969BW^{0.62}$ L/min
$k_3$	$0.0889BW^{0.55}$ L/min
$k_4$	0.12 L/min
$V_1$	$1.72BW^{0.71}AGE^{-0.39}$ L
$V_2$	$3.32BW^{0.61}$ L
$V_3$	266 L
$V_4$	$0.01V_1$ L