




A STUDY IN TEAK

Particulars of the room

DOORS — MADE IN VENEER

Same design · Planted mouldings · Construction only

SCALE	DATE
AS NOTED @ A3	23.09.2026
REV	DWG
2 — the design unchanged; only the construction differs	AST-DR-015

drawing

dimension line


5'-2 1/2" measurement

Aa note

All sizes in feet and inches. Go by the written sizes — never measure the paper.

1 · THROUGH THE LEAF

SECTION ACROSS A PANEL · EVERY MEMBER PLANTED ON



RELIEF

FACE OF THE VENEER = DATUM 0

Blockboard core	1½"
Veneer, each face	0.6
Solid lipping, four edges	0½" WIDE
Leaf overall	1¾"
Ovolo, planted	0¾" W · 0½" OUT
Shaped bead, planted	0⅜" W · 0¼" OUT
Roundel boss, glued on	Ø1" · 0¼" OUT
Panel field	FLAT · 0
Anything cut INTO the face	NONE

NOTES

REVISION 2

The design is not up for change here. If the shaped bead or the roundels ever change they change on AST-DR-001 and -009, and this sheet follows — it draws from the same code.

Lipping is solid teak on all four edges so the leaf can be trimmed

Veneer both faces of the core and balance it: same thickness back and front, or the leaf will bow.

Ovolo, bead and bosses in solid teak, polished to match. They are small enough to take solid without moving, and they give a crisper arris than a cut face would.

Set the bead out from the panel opening, not from the leaf edge, so the four roundels land exactly on the corners of the curve.

OPEN — glue and pin, or glue only? Pins need filling and the filler shows through polish. Glue and cramp if the shop can.

2 · WHAT CHANGES

on site and the hinges and lock screw into wood, not into boar

THE SAME MEMBERS, MADE SEPARATELY AND GLUED ON

Panel field

was: sunk 0½" into the solid

now: stays FLAT — the ovolo round it does the work
Ovolo sticking

was: worked on the stile edge

now: run as a separate 0¾" x 0½" moulding, mitred on
Shaped bead

was: carved into the panel face

now: bandsawn to the curve in 0⅜" x 0¼", planted on
Corner roundels

was: carved bosses

now: turned discs Ø1" x 0¼", glued on
The leaf

was: solid teak, 1¾"

now: 1½" blockboard, 0½" lipping, veneer both sides