



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
WATER RESOURCES DIVISION



PHILLIP D. ROOS
DIRECTOR

July 24, 2025

VIA EMAIL

Randall Retan, Supervisor
Blissfield Wastewater Treatment Plant
198 Mac Arthur Lane
Blissfield, MI 49228

Dear Randall Retan:

SUBJECT: Biosolids and PFAS Monitoring Results
National Pollutant Discharge Elimination System (NPDES)
Permit No. MI0021695
Designated Name: Blissfield WWTP

On April 14, 2025, the Blissfield Wastewater Treatment Plant (WWTP) submitted results to the Department of Environment, Great Lakes, and Energy (EGLE), Water Resources Division (WRD), of a biosolids sample collected from the Blissfield WWTP on January 22, 2025, for Per- and Polyfluoroalkyl substances (PFAS). The submittal was in accordance with the requirements set forth in the WRD's *Interim Strategy for Land Application of Biosolids Containing PFAS (Interim Strategy)* and the Residuals Management Program (RMP) Modification letter dated December 27, 2023, which became effective January 1, 2024, and part of the WWTP's approved RMP.

The laboratory results indicate that the PFAS analytes, Perfluorooctane Sulfonate (PFOS) and Perfluorooctanoic Acid (PFOA), concentrations in biosolids were 5.5 micrograms per kilogram ($\mu\text{g}/\text{kg}$) (parts per billion [ppb]) for PFOS and 3 $\mu\text{g}/\text{kg}$ for PFOA. Based on the analytical results for PFOS and PFOA in biosolids being 20 $\mu\text{g}/\text{kg}$ or below, no additional actions are required at this time and land application is approved to proceed as normal in accordance with the conditions of the Interim Strategy.

Please note the following PFAS requirements for Blissfield WWTP when land applying bulk biosolids in Michigan:

- Provide the most current PFOS and PFOA analytical results and additional information specific to PFAS and biosolids in Michigan to landowners and farmers prior to the land application of biosolids. Information on notification requirements and sample templates can be obtained from [Michigan Biosolids PFAS-related information and links](#).

- Continue to collect a minimum of one (1) annual biosolids PFAS sample prior to initial land application each **calendar year**, unless otherwise notified by the WRD's Biosolids Program staff. **Submit all PFAS data to EGLE WRD via MiEnviro Portal a minimum of two weeks prior to land application.**
- Please note that beginning calendar year 2024, generators who wish to obtain and/or maintain EQ designation for biosolids, must have **combined** PFOS and PFOA concentrations below 20 µg/kg. To demonstrate compliance with this standard, samples must be taken quarterly. These requirements are in addition to, and do not supersede or replace, in any way, other requirements for EQ designation as defined in the state and federal biosolids regulations.

EGLE continues to support a source reduction approach to reducing PFAS concentrations in effluent and biosolids generated from municipal WWTPs. Information on sampling and investigating potential PFAS sources can be obtained at [Industrial Pretreatment Program \(IPP\) PFAS Initiative](#). This link contains numerous documents, including Frequently Asked Questions, Wastewater PFAS Sampling Guidance, and Recommended PFAS Screening and Evaluation Guidance.

This Biosolids PFAS Monitoring Report acknowledgment does not constitute a release or waiver of liability for compliance with your NPDES Permit; your NPDES Permit Application; or Part 31, Water Resources Protection, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (NREPA). Please be advised that if new PFAS information becomes available or new standards or requirements are implemented, the WRD may require additional actions in accordance with the NREPA and its administrative rules.

Thank you for protecting Michigan's public health and environment from these emerging pollutants. Should you need further information, please feel free to contact me at 517-257-0251 or SmithC186@michigan.gov.

Sincerely,



Christian Smith, M.S.
Environmental Quality Analyst
Emerging Pollutants Section
Water Resources Division
517-257-0251
SmithC186@michigan.gov

cc: Sarah Campbell, EGLE
Spencer Mathews, EGLE
Steven Shields, Blissfield