

RSLogix Micro Project Report



Processor Information

Processor Type: Bul.1763 MicroLogix 1100 Series B

Processor Name: UNTITLED

Total Memory Used: 816 Instruction Words Used - 148 Data Table Words Used

Total Memory Left: 5840 Instruction Words Left

Program Files: 11

Data Files: 9

Program ID: d5f4

I/O Configuration

0	Bul.1763	MicroLogix 1100 Series B
1	1762-IF4	Analog 4 Chan. Input
2		
3		
4		

Channel Configuration

CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex

CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex Edit Resource/Owner Timeout: 60
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex Passthru Link ID: 1
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex Write Protected: No
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex Comms Servicing Selection: Yes
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex Message Servicing Selection: Yes
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex 1st AWA Append Character: \d
CHANNEL 0 (SYSTEM) - Driver: DF1 Full Duplex 2nd AWA Append Character: \a

Source ID: 1 (decimal)
Baud: 19200
Parity: NONE
Control Line : No Handshaking
Error Detection: CRC
Embedded Responses: Auto Detect
Duplicate Packet Detect: Yes
ACK Timeout(x20 ms): 50
NAK Retries: 3
ENQ Retries: 3

CHANNEL 1 (SYSTEM) - Driver: Ethernet

CHANNEL 1 (SYSTEM) - Driver: Ethernet Edit Resource/Owner Timeout: 60
CHANNEL 1 (SYSTEM) - Driver: Ethernet Passthru Link ID: 1
CHANNEL 1 (SYSTEM) - Driver: Ethernet Write Protected: No
CHANNEL 1 (SYSTEM) - Driver: Ethernet Comms Servicing Selection: Yes
CHANNEL 1 (SYSTEM) - Driver: Ethernet Message Servicing Selection: Yes

Hardware Address: 00:00:00:00:00:00
IP Address: 0.0.0.0
Subnet Mask: 0.0.0.0
Gateway Address: 0.0.0.0
Msg Connection Timeout (x 1mS): 15000
Msg Reply Timeout (x mS): 3000
Inactivity Timeout (x Min): 30
Bootp Enable: No
Dhcp Enable No
SNMP Enable: No
HTTP Enable: Yes
Auto Negotiate Enable: Yes
Port Speed Enable: 10/100 Mbps Full Duplex/Half Duplex
Contact:
Location:

Program File List

Name	Number	Type	Rungs	Debug	Bytes
[SYSTEM]	0	SYS	0	No	0
	1	SYS	0	No	0
MAIN	2	LADDER	9	No	75
IO	3	LADDER	13	No	444
HOA	4	LADDER	36	No	1228
CONTROLS	5	LADDER	16	No	665
RUNTIME	6	LADDER	6	No	258
BACKWASH	7	LADDER	16	No	437
ALARM	8	LADDER	17	No	547
SIMULATION	9	LADDER	9	No	304
SETTOAUTO	10	LADDER	3	No	213

Data File List


Name	Number	Type	Scope	Debug	Words	Elements	Last
OUTPUT	0	O	Global	No	12	4	O:3
INPUT	1	I	Global	No	39	13	I:12
STATUS	2	S	Global	No	0	66	S:65
BINARY	3	B	Global	No	9	9	B3:8
TIMER	4	T	Global	No	33	11	T4:10
COUNTER	5	C	Global	No	3	1	C5:0
CONTROL	6	R	Global	No	3	1	R6:0
INTEGER	7	N	Global	No	19	19	N7:18
FLOAT	8	F	Global	No	30	15	F8:14

LAD 2 - MAIN --- Total Rungs in File = 9





0009



0010

Pressure PT2
PT2

SCP

Scale w/Parameters

Input	I:1.1
	1875<
Input Min.	0.0
	0.0<
Input Max.	16383.0
	16383.0<
Scaled Min.	0.0
	0.0<
Scaled Max.	20.0
	20.0<
Output	F8:1
	2.288958<

Pressure Transmitter
PT2

Pressure PT2
PT2

GRT

Greater Than (A>B)

Source A	I:1.1
	1875<
Source B	16383
	16383<

MOV

Move

Source	20.0
	20.0<
Dest	F8:1
	2.288958<

Pressure Transmitter
PT2

Pressure PT2
PT2

LES

Less Than (A<B)

Source A	I:1.1
	1875<
Source B	0
	0<

MOV

Move

Source	0.0
	0.0<
Dest	F8:1
	2.288958<

0011

Tank Level Scaled
LT1

SCP

Scale w/Parameters

Input	I:1.2
	3000<
Input Min.	0.0
	0.0<
Input Max.	16383.0
	16383.0<
Scaled Min.	0.0
	0.0<
Scaled Max.	100.0
	100.0<
Output	F8:3
	18.31166<

Level Transmitter

Tank Level Scaled
LT1

GRT

Greater Than (A>B)

Source A	I:1.2
	3000<
Source B	16383
	16383<

MOV

Move

Source	100.0
	100.0<
Dest	F8:3
	18.31166<

Level Transmitter

Tank Level Scaled
LT1

LES

Less Than (A<B)

Source A	I:1.2
	3000<
Source B	0
	0<


MOV


Move


Source	0.0
	0.0<
Dest	F8:3
	18.31166<


0012


END

























PUMP CONTROL:


THE PUMP IS ON AS LONG AS THE HIGH TANK LEVEL SPECIFIED IS REACHED. WHEN THAT LEVEL IS REACHED, THE PUMP WILL SWITCH OFF, AND THE DRAINING PROCESS BEGINS.

WHEN THE TANK IS DRAINING, THE PUMP WILL REMAIN SWITCHED OFF UNTIL THE SPECIFIED TANK LOW LEVEL IS REACHED.

THE PUMP WILL NOT SWITCH ON IF THE HH LEVEL ALARM OR THE FLOW ALARM IS PRESENT.







0009

SYSTEM STATE
0=OFF
1=ON
SYSTEM STATE

SV2 STATE
0=OF
1=HAND
2=AUTO
SV2 STATE

BACKWASH STATE
0=INACTIVE
1=ACTIVE
BACKWASH STATE

SV2
SV2

B3:4
7

EQU
Equal
Source A N7:4
2<
Source B 2
2<

B3:5
6

B3:0
2

SV2 STATE
0=OF
1=HAND
2=AUTO
SV2 STATE

EQU
Equal
Source A N7:4
2<
Source B 1
1<

SYSTEM STATE
0=OFF
1=ON
SYSTEM STATE

SV3 STATE
0=OFF
1=HAND
2=AUTO
SV3 STATE

BACKWASH STATE
0=INACTIVE
1=ACTIVE
BACKWASH STATE

SV3
SV3

B3:4
7

EQU
Equal
Source A N7:6
2<
Source B 2
2<


B3:5
6

B3:0
3


SV3 STATE
0=OFF
1=HAND
2=AUTO
SV3 STATE

EQU
Equal
Source A N7:6
2<
Source B 1
1<

0010



LAD 5 - CONTROLS --- Total Rungs in File = 16



THIS WILL KEEP TRACK OF THE SYSTEM RUNTIME.
 RUNTIME IS MAINTAINED, EVEN IF THE SYSTEM IS DEACTIVATED, BUT THE TIMER WILL STOP TIMING WHEN THE SYSTEM IS NOT RUNNING.
 THE ONLY WAY TO RESET RUNTIME BACK TO ZERO IS BY PRESSING THE RUNTIME RESET PUSHBUTTON

SYSTEM STATE
 0=OFF
 1=ON

SYSTEM STATE

B3:4

7

Runtime-seconds

RTO
 Retentive Timer On
 Timer T4:2
 Time Base 1.0
 Preset 60<
 Accum 22<

EN
 DN

Runtime-seconds

T4:2

DN

Runtime-minutes

MINUTES

ADD
 Add
 Source A 1
 Source B N7:14
 Dest N7:14

Runtime-seconds

T4:2

RES

Runtime-minutes

MINUTES

EQU

Equal
 Source A N7:14
 Source B 60

Runtime-hours

HOURS

ADD
 Add
 Source A 1
 Source B N7:15
 Dest N7:15

Runtime-minutes


MINUTES


MOV


Move
 Source 0
 Dest N7:14


0000


0001






























LAD 10 - SETTOAUTO --- Total Rungs in File = 3



Offset	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0				
O:0.0	0	0	0	0	0	0	0	1	0	1	0	1	0	1	0	0	Bul.1763	MicroLogix 1100	Series B	
O:0.1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763	MicroLogix 1100	Series B	
O:0.2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763	MicroLogix 1100	Series B	
O:0.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763	MicroLogix 1100	Series B	

Data File I1 (bin) -- INPUT

Offset	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0		
I:0.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763	MicroLogix 1100 Series B
I:0.1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763	MicroLogix 1100 Series B
I:0.2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763	MicroLogix 1100 Series B
I:0.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763	MicroLogix 1100 Series B
I:0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763	MicroLogix 1100 Series B-Analog
I:0.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Bul.1763	MicroLogix 1100 Series B-Analog
I:1.0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	1	0	1762-IF4	- Analog 4 Chan. Input
I:1.1	0	0	0	0	0	1	1	1	0	1	0	1	0	0	1	1	1762-IF4	- Analog 4 Chan. Input
I:1.2	0	0	0	0	1	0	1	1	1	0	1	1	1	0	0	0	1762-IF4	- Analog 4 Chan. Input
I:1.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1762-IF4	- Analog 4 Chan. Input
I:1.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1762-IF4	- Analog 4 Chan. Input
I:1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1762-IF4	- Analog 4 Chan. Input
I:1.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1762-IF4	- Analog 4 Chan. Input

Main

Processor Mode S:1/0 - S:1/4 = Remote Program Mode
On Power up Go To Run (Mode Behavior) S:1/12 = 0
First Pass S:1/15 = No
Free Running Clock S:4 = 0010-0010-0010-1101

Proc

OS Catalog Number S:57 = 1100 User Program Type S:63 = 8001h
OS Series S:58 = B Compiler Revision Number S:64 =
OS FRS S:59 =
Processor Catalog Number S:60 =
Processor Series S:61 = A
Processor FRN S:62 =

Scan Times

Maximum (x10 ms) S:22 = 20
Watchdog (x10 ms) S:3 (high byte) = 10
Last 100 uSec Scan Time S:35 = 0
Scan Toggle Bit S:33/9 = 0

Math

Math Overflow Selected S:2/14 = 0 Math Register (lo word) S:13 = 0
Overflow Trap S:5/0 = 0 Math Register (high word) S:14-S:13 = 0
Carry S:0/0 = 0 Math Register (32 Bit) S:14-S:13 = 0
Overflow S:0/1 = 0
Zero Bit S:0/2 = 0
Sign Bit S:0/3 = 0

Chan 0

Processor Mode S:1/0- S:1/4 = Remote Program Mode
Node Address S:15 (low byte) = 0 Outgoing Msg Cmd Pending S:33/2 = 0
Baud Rate S:15 (high byte) = ?
Channel Mode S:33/3 = 0
Comms Active S:33/4 = 0
Incoming Cmd Pending S:33/0 = 0
Msg Reply Pending S:33/1 = 0

Debug

Suspend Code S:7 = 0
Suspend File S:8 = 0

Errors

Fault Override At Power Up S:1/8 = 0 Fault Routine S:29 = 0
Startup Protection Fault S:1/9 = 0 Major Error S:6 = 0h
Major Error Halt S:1/13 = 0
Overflow Trap S:5/0 = 0 Error Description:
Control Register Error S:5/2 = 0
Major Error Executing User Fault Rtn. S:5/3 = 0
Battery Low S:5/11 = 0
Input Filter Selection Modified S:5/13 = 0
ASCII String Manipulation error S:5/15 = 0

Protection

Deny Future Access S:1/14 = No
Data File Overwrite Protection Lost S:36/10 = False

Mem Module

Memory Module Loaded On Boot S:5/8 = 0
Password Mismatch S:5/9 = 0
Load Memory Module On Memory Error S:1/10 = 0
Load Memory Module Always S:1/11 = 0
On Power up Go To Run (Mode Behavior) S:1/12 = 0
Program Compare S:2/9 = 0
Data File Overwrite Protection Lost S:36/10 = 0

Data File S2 (hex) -- STATUS

Forces

Forces Enabled S:1/5 = Yes
Forces Installed S:1/6 = No

Offset	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0	(Symbol)	Description
B3:0	0	0	0	0	0	0	0	0	0	0	1	0	1	0	1	0		
B3:1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
B3:2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
B3:3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
B3:4	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0		
B3:5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
B3:6	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0		
B3:7	0	0	0	1	0	0	0	1	0	0	0	0	0	0	0	0		
B3:8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		

Data File T4 -- TIMER

Offset	EN	TT	DN	BASE	PRE	ACC	(Symbol) Description
T4:0	0	0	0	1.0 sec	10	0	Tank high level timer
T4:1	1	0	1	1.0 sec	10	10	Tank low level timer
T4:2	1	1	0	1.0 sec	60	22	Runtime-seconds
T4:3	0	0	0	1.0 sec	10	0	Pending backwash start timer
T4:4	0	0	0	1.0 sec	60	0	Backwash timer
T4:5	0	0	0	1.0 sec	5	0	BW COUNT RESET PB TIMER
T4:6	0	0	0	1.0 sec	5	0	Flow alarm activation timer
T4:7	0	0	0	1.0 sec	10	0	HH tank level alarm activation timer
T4:8	0	0	0	1.0 sec	10	0	LL Tank level alarm trigger
T4:9	0	0	0	1.0 sec	10	0	High filter pressure alarm trigger timer
T4:10	1	1	0	1.0 sec	3	0	sim timer

Offset	CU	CD	DN	OV	UN	UA	PRE	ACC	(Symbol)	Description
C5:0	0	0	0	0	0	0	0	0		

Offset	EN	EU	DN	EM	ER	UL	IN	FD	LEN	POS	(Symbol)	Description
R6:0	0	0	0	0	0	0	0	0	0	0		

Data File N7 (dec) -- INTEGER

Offset	0	1	2	3	4	5	6	7	8	9
N7:0	2	2	2	2	2	2	2	2	2	0
N7:10	2	2	2	0	41	0	0	0	60	

Data File F8 -- FLOAT

Offset	0	1	2	3	4
F8:0	0.06103888	2.288958	0	18.31166	-2.227919
F8:5	2.227919	12	90	15	15
F8:10	80	20	0	0	0

Address/Symbol Database

Address	Symbol	Scope	Description	Sym Group	Dev. Code
B3:0/0	FS1	Global	Flow switch FS-1		
B3:0/1	SV1	Global	SV1		
B3:0/2	SV2	Global	SV2		
B3:0/3	SV3	Global	SV3		
B3:0/4	SV4	Global	SV4 ip		
B3:0/5	SV5	Global	SV5		
B3:0/6	SV6	Global	SV6		
B3:0/7	P1	Global	Pump		
B3:0/8	P1_HAND_PB	Global	P1 HAND PB		
B3:0/9			one		
B3:0/10			one		
B3:0/11			one		
B3:0/12			one		
B3:0/13	P1_AUTO_PB	Global	P1 AUTO PB		
B3:0/14			one		
B3:0/15	P1_OFF_PB	Global	P1 OFF PB		
B3:1/0			one		
B3:1/1	SV1_HAND_PB	Global	SV1 HAND PB		
B3:1/2			one		
B3:1/3			one		
B3:1/4			one		
B3:1/5			one		
B3:1/6	SV1_AUTO_PB	Global	SV1 AUTO PB		
B3:1/7			one		
B3:1/8	SV1_OFF_PB	Global	SV1 OFF PB		
B3:1/9	SV2_HAND_PB	Global	SV2 HAND PB		
B3:1/10			one		
B3:1/11			one		
B3:1/12			one		
B3:1/13			one		
B3:1/14	SV2_AUTO_PB	Global	SV2 AUTO PB		
B3:1/15			one		
B3:2/0	SV2_OFF_PB	Global	SV2 OFF PB		
B3:2/1			one		
B3:2/2	SV3_HAND_PB	Global	SV3 HAND PB		
B3:2/3			one		
B3:2/4			one		
B3:2/5			one		
B3:2/6			one		
B3:2/7	SV3_AUTO_PB	Global	SV3 AUTO PB		
B3:2/8			one		
B3:2/9	SV3_OFF_PB	Global	SV3 OFF PB		
B3:2/10			one		
B3:2/11	SV4_HAND_PB	Global	SV4 HAND PB		
B3:2/12			one		
B3:2/13			one		
B3:2/14			one		
B3:2/15			one		
B3:3/0	SV4_AUTO_PB	Global	SV4 AUTO PB		
B3:3/1			one		
B3:3/2	SV4_OFF_PB	Global	SV4 OFF PB		
B3:3/3			one		
B3:3/4	SV5_HAND_PB	Global	SV5 HAND PB		
B3:3/5			one		
B3:3/6			one		
B3:3/7			one		
B3:3/8			one		
B3:3/9	SV5_AUTO_PB	Global	SV5 AUTO PB		
B3:3/10			one		
B3:3/11	SV5_OFF_PB	Global	SV5 OFF PB		
B3:3/12			one		
B3:3/13	SV6_HAND_PB	Global	SV6 HAND PB		
B3:3/14			one		
B3:3/15			one		
B3:4/0			one		
B3:4/1			one		
B3:4/2	SV6_AUTO_PB	Global	SV6 AUTO PB		
B3:4/3			one		
B3:4/4	SV6_OFF_PB	Global	SV6 OFF PB		
B3:4/5			one		
B3:4/6			one		
B3:4/7	SYSTEM_STATE	Global	SYSTEM STATE 0=OFF 1=ON		
B3:4/8			PUMP START TRIGGER		
B3:4/9			one		
B3:4/10			PUMP OFF TRIGGER		
B3:4/11			PUMP ON		
B3:4/12	SYSTEM_START_PB	Global	SYSTEM START PB		
B3:4/13			one		
B3:4/15			SYSTEM STARTER		
B3:5/0	SYSTEM_STOP_PB	Global	SYSTEM STOP PB		
B3:5/1			one		
B3:5/2			SYSTEM STOPPER		
B3:5/3			Pending backwash trigger		
B3:5/4			one		

Address/Symbol Database

Address	Symbol	Scope	Description	Sym Group	Dev. Code
B3:5/5	BACKWASH_PENDING	Global	Pending backwash		
B3:5/6	BACKWASH_STATE	Global	BACKWASH STATE 0=INACTIVE 1=ACTIVE		
B3:5/7			one		
B3:5/8			one		
B3:5/9	BW_COUNT_RESET_PB	Global	Backwash Counht rest PB		
B3:5/10			one		
B3:5/11	BW_LOG_TRIGGER	Global	Backwash End Data Log Trigger		
B3:5/12			one		
B3:5/13			Flow alarm trigger		
B3:5/14			Flow alarm		
B3:5/15	ALARM_RESET	Global	ALARM RESET		
B3:6/0	ALARM_SILENCE	Global	ALARM SILENCE		
B3:6/1	FLOW_ALM_NOTIFY	Global	Flow alarm notfication		
B3:6/2			one		
B3:6/3			HH level alarm trigger		
B3:6/4			HH LEVEL ALARM		
B3:6/5	HH_LEVEL_NOTIFY	Global	HH level alarm notify		
B3:6/6			one		
B3:6/7			LL tank alarm trigger		
B3:6/8			LL Level alarm		
B3:6/9	LL_LEVEL_NOTIFY	Global	LL alarm notify		
B3:6/10			one		
B3:6/11			High Filter Pressure alarm trigger		
B3:6/12			High Filter Pressure Alarm		
B3:6/13	H_FILTER_PRES_NOTIFY	Global	High pressure alarm notify		
B3:6/14	BW_LOCKOUT_PB	Global	Lockout Backwash PB		
B3:7/0			one		
B3:7/1			Backwash lockout trigger		
B3:7/2	BW_LO_STATE	Global	BACKWASH LOCKOUT STATE 0=NOT LOCKED OUT 1=LOCKED OUT		
B3:7/3	BW_ENABLE_PB	Global	Enable backwash		
B3:7/4			one		
B3:7/5			Backwash Enable Trigger		
B3:7/6	MANUAL_BW_PB	Global	MANUAL BACKWASH PUSHBUTTON		
B3:7/7	ALL_AUTO_PB	Global	SET ALL TO AUTO		
B3:7/8			ALL AUTO MODE		
B3:7/9	RUNTIME_RESET_PB	Global	Runtime Reset PB		
B3:7/10			one		
B3:7/11			Runtime reset trigger		
B3:7/12	DISCHARGE_VALVE	Global	DISCHARGE VALVE		
B3:7/13			one		
B3:7/14			TRIGGER HH LEVEL ALARM		
B3:7/15			TRIGGER LL LEVEL ALARM		
B3:8/0			TRIGGER HIGH PRESSURE ALARM PT2		
F8:0	PT1	Global	Pressure PT1		
F8:1	PT2	Global	Pressure PT2		
F8:2					
F8:3	LT1	Global	Tank Level Scaled		
F8:4			Diff. pressure		
F8:5	DIFF_PRESS_ABS	Global	Diff Pressure- absolute		
F8:6	DIFF_PRES_SP	Global	Max. Diff Pressue (set from HMI)		
F8:7	HH_LEVEL_SP	Global	HH Tank level (set on the HMI)		
F8:8	LL_LEVEL_SP	Global	LL level (set from HMI)		
F8:9	H_PRES_SP	Global	High pressure (set from HMI)		
F8:10	H_LEVEL	Global	H TANK_LEVEL		
F8:11	L_LEVEL	Global	L_TANK_LEVEL		
F8:30					
I:0/0			SV1 ip		
I:0/1			SV1 ip		
I:0/2			SV2 ip		
I:0/3			SV3 ip		
I:0/4			SV4 ip		
I:0/5			SV5 ip		
I:0/6			SV6 ip		
I:1.0			Pressure transmitter PT1		
I:1/0			Pressure transmitter PT1 (psi)		
I:1.1			Pressure Transmitter PT2		
I:1.2			Level Transmitter		
N7:0	P1_STATE	Global	P1 STATE 0=OFF 1=HAND 2=AUTO		
N7:1			P1 state temporary storage		
N7:2	SV1_STATE	Global	SV1 STATE 0=OFF 1=HAND 2=AUTO		
N7:3			SV1 temporary storage bit		
N7:4	SV2_STATE	Global	SV2 STATE 0=OF 1=HAND 2=AUTO		
N7:5			SV2 temporary storage bit		
N7:6	SV3_STATE	Global	SV3 STATE 0=OFF 1=HAND 2=AUTO		
N7:7			SV3 state temporary storage bit		
N7:8	SV4_STATE	Global	SV4 STATE 0=OFF 1=HAND 1=AUTO		
N7:9			SV4 State temporary storage bit		
N7:10	SV5_STATE	Global	SV5 STATE 0=OFF 1=HAND 2=AUTO		
N7:11			SV5 state temporary storage bit		
N7:12	SV6_STATE	Global	SV6 STATE 0=OFF 1=HAND 2=AUTO		
N7:13			SV6 state temporary storage bit		
N7:14	MINUTES	Global	Runtime-minutes		
N7:15	HOURS	Global	Runtime-hours		
N7:16	THOUSAND_HOURS	Global	Runtime-thousands of hours		

Address/Symbol Database

Address	Symbol	Scope	Description	Sym Group	Dev. Code
N7:17	BACKWASH_COUNT	Global	Backwash Cycle Counter		
N7:18	BW_TIME_LEFT	Global	Backwash time left		
O:0/0			Pump OP		
O:0/1			FS-1		
O:0/2			SV1		
O:0/3			SV2		
O:0/4			SV3		
O:0/5			SV5		
O:0/6			SV5		
O:0/7			SV6		
O:0/8			DISCHARGE VALVE		
S:0			Arithmetic Flags		
S:0/0			Processor Arithmetic Carry Flag		
S:0/1			Processor Arithmetic Underflow/ Overflow Flag		
S:0/2			Processor Arithmetic Zero Flag		
S:0/3			Processor Arithmetic Sign Flag		
S:1			Processor Mode Status/ Control		
S:1/0			Processor Mode Bit 0		
S:1/1			Processor Mode Bit 1		
S:1/2			Processor Mode Bit 2		
S:1/3			Processor Mode Bit 3		
S:1/4			Processor Mode Bit 4		
S:1/5			Forces Enabled		
S:1/6			Forces Present		
S:1/7			Comms Active		
S:1/8			Fault Override at Powerup		
S:1/9			Startup Protection Fault		
S:1/10			Load Memory Module on Memory Error		
S:1/11			Load Memory Module Always		
S:1/12			Load Memory Module and RUN		
S:1/13			Major Error Halted		
S:1/14			Access Denied		
S:1/15			First Pass		
S:2/0			STI Pending		
S:2/1			STI Enabled		
S:2/2			STI Executing		
S:2/3			Index Addressing File Range		
S:2/4			Saved with Debug Single Step		
S:2/5			DH-485 Incoming Command Pending		
S:2/6			DH-485 Message Reply Pending		
S:2/7			DH-485 Outgoing Message Command Pending		
S:2/15			Comms Servicing Selection		
S:3			Current Scan Time/ Watchdog Scan Time		
S:4			Time Base		
S:5/0			Overflow Trap		
S:5/2			Control Register Error		
S:5/3			Major Err Detected Executing UserFault Routine		
S:5/4			M0-M1 Referenced on Disabled Slot		
S:5/8			Memory Module Boot		
S:5/9			Memory Module Password Mismatch		
S:5/10			STI Overflow		
S:5/11			Battery Low		
S:6			Major Error Fault Code		
S:7			Suspend Code		
S:8			Suspend File		
S:9			Active Nodes		
S:10			Active Nodes		
S:11			I/O Slot Enables		
S:12			I/O Slot Enables		
S:13			Math Register		
S:14			Math Register		
S:15			Node Address/ Baud Rate		
S:16			Debug Single Step Rung		
S:17			Debug Single Step File		
S:18			Debug Single Step Breakpoint Rung		
S:19			Debug Single Step Breakpoint File		
S:20			Debug Fault/ Powerdown Rung		
S:21			Debug Fault/ Powerdown File		
S:22			Maximum Observed Scan Time		
S:23			Average Scan Time		
S:24			Index Register		
S:25			I/O Interrupt Pending		
S:26			I/O Interrupt Pending		
S:27			I/O Interrupt Enabled		
S:28			I/O Interrupt Enabled		
S:29			User Fault Routine File Number		
S:30			STI Setpoint		
S:31			STI File Number		
S:32			I/O Interrupt Executing		
S:33			Extended Proc Status Control Word		
S:33/0			Incoming Command Pending		
S:33/1			Message Reply Pending		
S:33/2			Outgoing Message Command Pending		
S:33/3			Selection Status User/DF1		

Address/Symbol Database

Address	Symbol	Scope	Description	Sym Group	Dev. Code
S:33/4			Communicat Active		
S:33/5			Communicat Servicing Selection		
S:33/6			Message Servicing Selection Channel 0		
S:33/7			Message Servicing Selection Channel 1		
S:33/8			Interrupt Latency Control Flag		
S:33/9			Scan Toggle Flag		
S:33/10			Discrete Input Interrupt Reconfigur Flag		
S:33/11			Online Edit Status		
S:33/12			Online Edit Status		
S:33/13			Scan Time Timebase Selection		
S:33/14			DTR Control Bit		
S:33/15			DTR Force Bit		
S:34			Pass-thru Disabled		
S:34/0			Pass-Thru Disabled Flag		
S:34/1			DH+ Active Node Table Enable Flag		
S:34/2			Floating Point Math Flag Disable,Fl		
S:35			Last 1 ms Scan Time		
S:36			Extended Minor Error Bits		
S:36/8			DII Lost		
S:36/9			STI Lost		
S:36/10			Memory Module Data File Overwrite Protection		
S:37			Clock Calendar Year		
S:38			Clock Calendar Month		
S:39			Clock Calendar Day		
S:40			Clock Calendar Hours		
S:41			Clock Calendar Minutes		
S:42			Clock Calendar Seconds		
S:43			STI Interrupt Time		
S:44			I/O Event Interrupt Time		
S:45			DII Interrupt Time		
S:46			Discrete Input Interrupt- File Number		
S:47			Discrete Input Interrupt- Slot Number		
S:48			Discrete Input Interrupt- Bit Mask		
S:49			Discrete Input Interrupt- Compare Value		
S:50			Processor Catalog Number		
S:51			Discrete Input Interrupt- Return Number		
S:52			Discrete Input Interrupt- Accumulat		
S:53			Reserved/ Clock Calendar Day of the Week		
S:55			Last DII Scan Time		
S:56			Maximum Observed DII Scan Time		
S:57			Operating System Catalog Number		
S:58			Operating System Series		
S:59			Operating System FRN		
S:61			Processor Series		
S:62			Processor Revision		
S:63			User Program Type		
S:64			User Program Functional Index		
S:65			User RAM Size		
S:66			Flash EEPROM Size		
S:67			Channel 0 Active Nodes		
S:68			Channel 0 Active Nodes		
S:69			Channel 0 Active Nodes		
S:70			Channel 0 Active Nodes		
S:71			Channel 0 Active Nodes		
S:72			Channel 0 Active Nodes		
S:73			Channel 0 Active Nodes		
S:74			Channel 0 Active Nodes		
S:75			Channel 0 Active Nodes		
S:76			Channel 0 Active Nodes		
S:77			Channel 0 Active Nodes		
S:78			Channel 0 Active Nodes		
S:79			Channel 0 Active Nodes		
S:80			Channel 0 Active Nodes		
S:81			Channel 0 Active Nodes		
S:82			Channel 0 Active Nodes		
S:83			DH+ Active Nodes		
S:84			DH+ Active Nodes		
S:85			DH+ Active Nodes		
S:86			DH+ Active Nodes		
T4:0			Tank high level timer		
T4:0/DN					
T4:1			Tank low level timer		
T4:1/DN					
T4:2			Runtime-seconds		
T4:2.ACC	SECONDS	Global			
T4:2/DN					
T4:3			Pending backwash start timer		
T4:3/DN					
T4:4			Backwash timer		
T4:4.ACC					
T4:4/DN					
T4:4/TT					
T4:5			BW COUNT RESET PB TIMER		
T4:5/DN					

Address/Symbol Database

Address	Symbol	Scope	Description	Sym Group	Dev. Code
T4:6			Flow alarm activation timer		
T4:6/DN					
T4:7			HH tank level alarm activation timer		
T4:7/DN					
T4:8			LL Tank level alarm trigger		
T4:8/DN					
T4:9			High filter pressure alarm trigger timer		
T4:9/DN					
T4:10			sim timer		
T4:10/DN					
U:3			I/O		
U:4			HOA		
U:5			CONTROLS		
U:6			RUNTIME		
U:7			BACKWASH		
U:8			ALARM		
U:9			SIMULATION		
U:10			SETTOAUTO		

Instruction Comment Database

Address	Instruction	Description
---------	-------------	-------------

Group_Name	Description
------------	-------------