

Time-Adaptive Unit Commitment

INFORMS 2019

S. Pineda R. Fernández-Blanco J. M. Morales

OASYS group, University of Málaga (Spain)

Funded by the Spanish Ministry of Economy, Industry and Competitiveness
through projects ENE2016-80638-R and ENE2017-83775-P

October 20, 2019

Unit commitment problem

- For given:
 - Set of generating units $g = 1, \dots, N_G$
 - Set of time periods $t = 1, \dots, N_T$
 - Known electricity demand d_t

Unit commitment problem

- For given:
 - Set of generating units $g = 1, \dots, N_G$
 - Set of time periods $t = 1, \dots, N_T$
 - Known electricity demand d_t
- The unit commitment (UC) problem determines:
 - On/off status of generating units u_{gt}
 - Power dispatch of generating units p_{gt}

Unit commitment problem

- For given:
 - Set of generating units $g = 1, \dots, N_G$
 - Set of time periods $t = 1, \dots, N_T$
 - Known electricity demand d_t
- The unit commitment (UC) problem determines:
 - On/off status of generating units u_{gt}
 - Power dispatch of generating units p_{gt}
- Mathematically, UC is formulated as a mixed-integer program (MIP):

$$\begin{aligned} \min_{u_{gt}, p_{gt}} \quad & f(u_{gt}, p_{gt}) \\ \text{s.t.} \quad & g_j(u_{gt}, p_{gt}, d_t) \leq 0, \quad \forall j \\ & u_{gt} \in \{0, 1\} \end{aligned}$$

Unit commitment problem


- For given:
 - Set of generating units $g = 1, \dots, N_G$
 - Set of time periods $t = 1, \dots, N_T$
 - Known electricity demand d_t
- The unit commitment (UC) problem determines:
 - On/off status of generating units u_{gt}
 - Power dispatch of generating units p_{gt}
- Mathematically, UC is formulated as a mixed-integer program (MIP):

$$\begin{aligned} \min_{u_{gt}, p_{gt}} \quad & f(u_{gt}, p_{gt}) \\ \text{s.t.} \quad & g_j(u_{gt}, p_{gt}, d_t) \leq 0, \quad \forall j \\ & u_{gt} \in \{0, 1\} \end{aligned}$$

- UC problem is computationally expensive
- Increasing N_G or N_T may turn UC intractable


Motivation

- Traditionally: 24 hourly time periods
- Conventional hourly unit-commitment (CH-UC)



Motivation


- What happens if renewable penetration increases?



- FERC Order 764:** “hourly transmission scheduling protocols (...) are insufficient to provide system operators with the flexibility to manage their system effectively and efficiently”

Motivation

- What about increasing time resolution to 15 minutes?




- Existing approaches with finer time resolutions
 - Pandžić et al. 2014 (15 min)
 - Deane, Drayton, and Ó Gallachóir 2014 (5, 15, 30, 60 min)
 - Kazemi et al. 2016 (5, 10, 15, 30, 60 min)
 - Bakirtzis et al. 2014; Bakirtzis and Biskas 2017 (5-60 min)

👍 Operating cost savings

👎 Increase of computational time

Motivation

- What about using 24 time periods of different duration?
- Time-adaptive unit-commitment (TA-UC)



Can we determine the duration of 24 time periods to make
a more efficient use of the system flexibility
without increasing the computational burden of the UC?

- Proposed time-period aggregation
- Modifications of UC constraints
- Comparison: CH-UC vs. TA-UC
- Illustrative example
- Case study
- Conclusions

Proposed time-period aggregation

① Original data (5-min resolution)

[illegible]

Proposed time-period aggregation

- 1 Original data (5-min resolution)




- 2 Compute distance between each pair of adjacent clusters



9 7 4 2 5 8 3 2 4 5 4 6 7 7 1 9 6 2 5 2 9 3 2 6 2 9 4 4 3 2 8 3 7 5 9

Proposed time-period aggregation

- 1 Original data (5-min resolution)



- 2 Compute distance between each pair of adjacent clusters



- 3 Merge the two closest adjacent clusters and update distances



Proposed time-period aggregation

- 1 Original data (5-min resolution)



- 2 Compute distance between each pair of adjacent clusters



- 3 Merge the two closest adjacent clusters and update distances



- 4 Repeat 2 and 3 until the final number of clusters is obtained



Modifications of UC constraints

- Generating unit constraints
 - Minimum output
 - Ramping limits
 - Minimum up/down times

Type	Pmin	Ramp	Min time
Base (nuclear)	↑↑	↓	↑↑
Medium (coal)	↑	↑	↑
Peak (gas)	↓	↑↑	↓

Modifications of UC constraints

- Ramping limits (100MW/h)

p_1	p_2	p_3
1h	1h	1h

$$|p_1 - p_2| \leq 100$$

$$|p_2 - p_3| \leq 100$$

p_1	p_2	p_3
2h	0.5h	0.5h

$$|p_1 - p_2| \leq 125 = 100 \cdot 0.5 \cdot (2 + 0.5)$$

$$|p_2 - p_3| \leq 50 = 100 \cdot 0.5 \cdot (0.5 + 0.5)$$

Modifications of UC constraints

- Ramping limits (100MW/h)

p_1	p_2	p_3
1h	1h	1h

$$|p_1 - p_2| \leq 100$$

$$|p_2 - p_3| \leq 100$$

p_1	p_2	p_3
2h	0.5h	0.5h

$$|p_1 - p_2| \leq 125 = 100 \cdot 0.5 \cdot (2 + 0.5)$$

$$|p_2 - p_3| \leq 50 = 100 \cdot 0.5 \cdot (0.5 + 0.5)$$

- Minimum up time (2h)

u_1	u_2	u_3
1h	1h	1h

0 0 0

1 1 0

0 1 1

1 1 1

u_1	u_2	u_3
2h	0.5h	0.5h


0 0 0

1 0 0

- - -

1 1 1

Comparison: CH-UC vs. TA-UC



Illustrative example

Technology	\underline{P}_g^G (MW)	\overline{P}_g^G (MW)	C_{gt}^M (€/MWh)	# units
Base	150	200	10	4
Medium	50	100	30	1
Peak	0	50	50	1

Time period	$t1$	$t2$	$t3$	$t4$	$t5$	$t6$
Duration (h)	0.5	0.5	0.5	0.5	0.5	0.5
Demand (MW)	500	500	500	500	650	850
Solar (MW)	300	300	300	300	200	0
Net demand (MW)	200	200	200	200	450	850

- Limited flexible generation (minimum output)
- Demand increases when solar decreases

Illustrative example

Table: CONVENTIONAL HOURLY UNIT COMMITMENT (CH-UC) – EXAMPLE

Day-ahead dispatch						
Time periods	$t1 + t2$		$t3 + t4$		$t5 + t6$	
Net demand	200		200		650	
Base	200		200		600	
Medium	0		0		50	
Peak	0		0		0	
Real-time operation						
Time periods	$t1$	$t2$	$t3$	$t4$	$t5$	$t6$
Net demand	200	200	200	200	450	850
Base	200	200	200	200	600	600
Medium	0	0	0	0	50	100
Peak	0	0	0	0	0	50
Load shed	0	0	0	0	0	100
Solar spillage	0	0	0	0	200	0

Illustrative example

Table: TIME-ADAPTIVE UNIT COMMITMENT (TA-UC) – EXAMPLE

Day-ahead dispatch						
Time periods	$t1 + t2 + t3 + t4$				$t5$	$t6$
Net demand	200				450	850
Base	200				400	800
Medium	0				50	50
Peak	0				0	0
Real-time operation						
Time periods	$t1$	$t2$	$t3$	$t4$	$t5$	$t6$
Net demand	200	200	200	200	450	850
Base	200	200	200	200	400	800
Medium	0	0	0	0	50	50
Peak	0	0	0	0	0	0
Load shed	0	0	0	0	0	0
Solar spillage	0	0	0	0	0	0

Case study

- Demand is 10% of that in Spain in 2017 (3800 MW peak demand)
- Wind and solar capacity factors in Spain in 2017
- Renewable penetrations from 20% to 60%
- Start-up costs, ramp limits and minimum times of thermal units
- Three generation portfolios:

	Base (MW)	Medium (MW)	Peak (MW)
Base case	1200	1200	1500
High-flex case	-	2400	1500
Low-flex case	2400	-	1500

Table: RELATIVE COST SAVINGS (%)

Wind (%)	Solar (%)	<i>Base case</i>	<i>High-flex case</i>	<i>Low-flex case</i>
10	10	0.01	0.00	0.27
20	0	0.01	0.01	0.30
0	20	0.12	0.07	0.53
30	30	2.35	1.04	3.49
60	0	0.56	0.08	1.02
0	60	2.56	1.43	4.76

Table: RELATIVE COST SAVINGS (%)

Wind (%)	Solar (%)	Base case	High-flex case	Low-flex case
10	10	0.01	0.00	0.27
20	0	0.01	0.01	0.30
0	20	0.12	0.07	0.53
30	30	2.35	1.04	3.49
60	0	0.56	0.08	1.02
0	60	2.56	1.43	4.76

- More renewables ➡ Higher savings

Case study

Table: RELATIVE COST SAVINGS (%)

Wind (%)	Solar (%)	Base case	High-flex case	Low-flex case
10	10	0.01	0.00	0.27
20	0	0.01	0.01	0.30
0	20	0.12	0.07	0.53
30	30	2.35	1.04	3.49
60	0	0.56	0.08	1.02
0	60	2.56	1.43	4.76

- More renewables ➡ Higher savings
- More solar ➡ Higher savings

Case study

Table: RELATIVE COST SAVINGS (%)

Wind (%)	Solar (%)	Base case	High-flex case	Low-flex case
10	10	0.01	0.00	0.27
20	0	0.01	0.01	0.30
0	20	0.12	0.07	0.53
30	30	2.35	1.04	3.49
60	0	0.56	0.08	1.02
0	60	2.56	1.43	4.76

- More renewables ➡ Higher savings
- More solar ➡ Higher savings
- Low flexibility ➡ Higher savings

Summary

- The conventional-hourly UC is proven inadequate for high penetration of renewables (Duck curve)
- Finer time discretizations reduce operating costs while increasing computational time
- The proposed time-adaptive UC reduces operating costs without increasing computational time
- The cost savings increase with renewable (solar) penetration and decrease with generation flexibility

Thanks!! Questions??



website: oasys.uma.es

S. Pineda, R. Fernández-Blanco and J.M. Morales, "*Time-Adaptive Unit Commitment*", in **IEEE Transactions on Power Systems**, 34(5), 3869-3878, 2019.



References I

- Bakirtzis, Emmanouil A. and Pandelis N. Biskas (2017). “Multiple Time Resolution Stochastic Scheduling for Systems With High Renewable Penetration”. In: *IEEE Transactions on Power Systems* 32.2, pp. 1030–1040.
- Bakirtzis, Emmanouil A. et al. (2014). “Multiple time resolution unit commitment for short-term operations scheduling under high renewable penetration”. In: *IEEE Transactions on Power Systems* 29.1, pp. 149–159.
- Deane, J. P., G. Drayton, and B. P. Ó Gallachóir (2014). “The impact of sub-hourly modelling in power systems with significant levels of renewable generation”. In: *Applied Energy* 113, pp. 152–158.
- Kazemi, Mehdi et al. (2016). “Evaluating the impact of sub-hourly unit commitment method on spinning reserve in presence of intermittent generators”. In: *Energy* 113, pp. 338–354.

- Pandžić, Hrvoje et al. (2014). “Effect of time resolution on unit commitment decisions in systems with high wind penetration”. In: *2014 IEEE PES General Meeting — Conference & Exposition*. IEEE, pp. 1–5.