

UNIT	HOUSE TYPE	DOCUMENT REF	ISSUE DATE
34 Bayly	BAYLY-3B	BY-034-SPEC-HP	5 January 2026

SPECIFICATION

Heat Pump Specification and Guide

MAKE AND MODEL	Mitsubishi Ecodan PUZ-WM85VAA
TYPE	air source heat pump
DESIGN SPF	3.2

Running it well

The heat pump is most efficient when it runs low and constant. Set a steady flow temperature and let the weather compensation curve do the work. Short bursts in cold weather, sometimes called short-cycling, force the unit to work harder and use more electricity for the same heat.

Hot water

- Schedule the hot water cylinder to heat on the night rate where possible.
- A weekly cylinder cycle keeps the water safe and the system healthy.

If something looks off

Fault codes appear on the controller. Note the code and report it through the portal. Most issues during the early period are settings rather than faults and are quick to resolve.