

UNIT	HOUSE TYPE	DOCUMENT REF	ISSUE DATE
34 Bayly	BAYLY-3B	BY-034-SPEC-MVHR	5 January 2026

SPECIFICATION

Ventilation Specification and Guide

MAKE AND MODEL	Zehnder ComfoAir Q350
TYPE	MVHR, heat recovery
MODE	continuous

How it works

The ventilation system supplies fresh filtered air and recovers heat from the air it extracts. It is designed to run continuously at a low rate. Leaving it on keeps humidity in check, protects the building fabric and supports the energy rating.

Boost and away

- Use boost when cooking or after a shower to clear moisture quickly.
- Away mode lowers the rate when the home is empty for a longer period.

Filters

Check the filters roughly every three months and replace them when due. The unit shows a filter reminder. Reset it after a change so the schedule stays accurate.