



Annexure C


SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Rc.No. 069 / SHP / DM&HO / Medchal / 2024 - 25

Dated: 29 / 04 / 2024.

It is certified that an inspection team headed by Y. Vijay Kumar, Health Inspector, Medchal Malkajigiri District, from DM&HO Office (Health Department) and Vision Labs - certified PHED have inspected **Sanskar School**, Located at Railway Colony, Near Durgamma Temple, Medchal, Medchal Mandal, Medchal - Malkajigiri District on 29-04-2024 and on the basis of Water Test Report (Attached) bearing No TC-506424000001640F, dated: 27-04-2024 from Vision Labs Musarambagh, Malakpet, Hyderabad(PHED Lab) certified that the **Sanskar School**, Medchal has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This Certificate is valid for a period of One year from date of issue.



District Medical & Health Officer
Medchal Malkajigiri District

To

The Principal,
Sanskar School,
Railway Colony,
Near Durgamma Temple,
Medchal, Medchal Mandal,
MedchalMalkajigiri District.



Principal
Sanskar Innovative School
Railway Colony, Medchal



CORRESPONDENT
Sanskar Innovative School
Medchal



VISION LABS

Environmental Consultants & Analytical Services

Accredited by NABL vide certificate number TC-5064
MoEF & CC, ISO 9001 : 2015 & OHSAS 45001 : 2018



TC-5064

TEST REPORT

Issued To: M/s. SANSKAR INNOVATIVE SCHOOL, Medchal Near Railway Colony, R.R. District, Medchal, Hyderabad, Telangana 501401		Issued Date	27.04.2024
		Our Ref No (ULR No)	TC506424000001640F
		Your Ref No	Verbal
		Your Ref Date	22.04.2024
Sample description & Location given by Customer	Drinking Water	Mode of Packing	Pet Bottles
Product	Water		
Appearance of the Sample	Clear Liquid	Sample condition of testing	Found Ok
		Sample Quantity	1 ltr
Sample Registration Date	23.04.2024	Analysis Start Date	23.04.2024
Sample Registration Time	09:10 am	Analysis Completion Date	27.04.2024
Sampling done by Customer		Sample Tested As Received Basis	

TEST RESULTS

S. No	Parameters	Test Method	Units of Measurement	Test Results	Drinking Water Limits As per IS: 10500; 2012	
					Acceptable Limits	Permissible limits in absence of alternative Source

PHYSICAL EXAMINATION

1.	pH at 25°C	IS:3025 part 11 :2022	--	6.54	6.50 – 8.50	No relaxation
2.	Conductivity at 25°C	IS: 3025 Part 14 2013, RA-2019	µmhos/cm	46	--	--
3.	Total Dissolved Solids	IS: 3025 Part 16:2023	mg/L	29	500 max	2000 max
4.	Turbidity	IS: 3025 Part 10:2023	NTU	<1.0	1 max	5 max
5.	Color	IS: 3025 Part 4:2021	CU	<01	5 max	15 max

CHEMICAL EXAMINATION

6.	Total Hardness as CaCO ₃	IS: 3025 Part 21 2009, RA-2019	mg/L	08	200 max	600 max
7.	Alkalinity – Phenolphthalein	IS: 3025 Part 23 1986, RA-2019	mg/L	Nil	---	---
8.	Alkalinity – Methyl Orange	IS: 3025 Part 23 1986, RA-2019	mg/L	08	200 max	600 max
9.	Calcium as Ca	IS: 3025 Part 40 1991, RA-2019	mg/L	1.6	75 max	200 max
10.	Magnesium as Mg	IS: 3025 Part 46 1994, RA-2019	mg/L	0.96	30 max	100 max
11.	Chloride as Cl	IS: 3025 Part 32 1988, RA-2019	mg/L	6.0	250 max	1000 max
12.	Sodium as Na	IS: 3025 Part 45 1993, RA-2019	mg/L	5.7	---	---
13.	Potassium as K	IS: 3025 Part 45 1993, RA-2019	mg/L	0.4	---	---
14.	Sulphate as SO ₄	APHA 24 th Edn 4500 SO ₄ E, 2023	mg/L	4.8	200 max	400 max
15.	Nitrate as NO ₃	IS: 3025 Part 34 1988, RA-2019	mg/L	0.6	45 max	No relaxation
16.	Silica as SiO ₂	IS: 3025 Part 35 1988, RA-2019	mg/L	<0.02	--	--
17.	Iron as Fe	IS: 3025 Part 53 2003, RA-2019	mg/L	<0.04	1.0 max	No relaxation
18.	Fluoride as F	APHA 4500 F B, D 24 th Edition	mg/L	<0.10	1.0 max	1.5 max

Microbiological Analysis

1.	Total Plate Count	IS:5402-2012, RA-2018	CFU/mL	Not Detected	--
2.	Coli form Bacteria	IS 15185:2016, RA-2021	CFU/100mL	Not Detected	Shall Not be Detectable in any 100 mL
3.	E. Coli	IS 15185:2016, RA-2021	CFU/100mL	Not Detected	

Page 1 of 1

 Sr. Chemist VL/QM/7.8/TP	 Sr. Microbiologist	 CORRESPONDENT Sanskar Innovative School Medchal Authorized Signatory Technical Manager – T. Laxmikanth Reddy
---------------------------------	------------------------	--

H.No. 16-11-23/37/A, Flat No. 205, 2nd Floor, Opp. R.T.A. Office, Musarambagh, Malakpet, Hyderabad - 500 036.
 Tel : 040-24544320, 24541338, Mob : 98491 10019 / 94408 41338, E-mail : Info@visionlabs.com, vision.labs@gmail.com

NOTE : This Report is subject to the terms and conditions mentioned overleaf.