



- تتحدد بتأمين السلامة العامة بموجب المادة ٨ من المرسوم رقم ٢٢٩١ - ٩٢ بالنسبة الى غرف المازوت و الشويبيرات
- (حاجز الورشة ) سفايح حديد سماكة ٢ متر مع دعامر حديد
- داعمون الشويبير (الحراق) يصل الى اعلى البناء و مجهز بمصافي فتحة
- طفاية حريق عدد ٢ سعة الواحدة ٥ ليتر
- جميع الابواب في غرفة المازوت و غرفة الشويبيرات تفتح للخارج و مغطاة بملبطين من السفايح المعدنية سماكة ٢ متر تفصلها مادة عازلة
- جميع الادرار منخفضة بموجب القرار ٢٧م
- ان جميع المتحكات يملو متر واحد
- الابواب و المفايح مطابقة للقرار ٧٣ - ٧٣٠
- ان جميع الصناعات مجهزة بمخفاط كهربائي متصل بالهواء الطلق بواسطة خاروق قطر ٥٢سم



Facilities Planning and Design Unit

PROJECT NAME:  
RESEARCH SCIENCE BUILDING  
PROJECT NO:

LOCATION:  
LOT 496,497,498  
AIN-AL-MRAYSE

* No.	REVISION	DATE
REFERENCE DRAWING:		

DRAWN BY: ARCHITECTURAL: ELECTRICAL:	STRUCTURAL: SAMER DEEB MECHANICAL:
APPROVAL OF END USER:	
APPROVAL OF EHS&RM:	
OTHER APPROVALS:	
APPROVAL OF FPDU:	

TITLE:  
REVISION NUMBER:  
NORTH-EAST  
ELEVATION

DATE OF DWG: 07/12/2004 SCALE: 1/100

A 14  
SHEET: 15 OF 16