PHARMACEUTICAL ENVIRONMENTAL MONITORING EXCURSION REPORT
Facility: Sterile Fill-Finish Complex A | Cleanroom Grade B
Report ID: EM-EXC-2026-118

Title: Viable Particulate Excursion in Aseptic Filling Room B-104
Date of Occurrence: 22-09-2026
Source: Facilities / Environmental Monitoring
Product: Ciprofloxacin Infusion 0.2%
Batch Number: CIPRO-2609-01
Batch Size: 5000 vials

INCIDENT SUMMARY:
During active filling operations of batch CIPRO-2609-01 on 22-Sep-2026, active air sampling at sampling location SAS-04 (Grade B background directly adjacent to laminar airflow cart) recovered 18 CFU/m3 against an action limit of 10 CFU/m3. Concurrently, settle plates placed for 4 hours at settling point SP-02 recorded 12 CFU/4hr against an action limit of 5 CFU/4hr.

INVESTIGATION DETAILS:
Differential pressure between Grade B Room B-104 and corridor Grade C remained positive at 17.4 Pa throughout the shift. HEPA filter integrity test data from previous certification (August 2026) verified 99.997% efficiency. Personnel movement logging showed 4 operators were present during fill changes instead of standard 2 operators.

SEVERITY ASSESSMENT:
Severity: Critical
Impact Category: Patient Safety / Sterility Assurance
Given the direct impact on aseptic filling environment, sterility assurance is compromised.

IMMEDIATE CONTAINMENT:
1. Filling halted immediately and line purged.
2. Batch CIPRO-2609-01 placed on physical and electronic QA quarantine lock.
3. Comprehensive vaporized hydrogen peroxide (VHP) room decontamination scheduled.

Investigator: Dr. R. Menon (Microbiology Quality Control)
Reviewed: H. Vance (Head of Sterile Quality Operations)