

§ 47 · Habitable Rooms (Aufenthaltsräume) — Musterbauordnung (MBO)

R REQUIREMENT <i>The rule itself</i>	A APPLICABILITY <i>When / to what it applies</i>	S SELECTION <i>Which option applies</i>	E EXCEPTION <i>Cases excluded from rule</i>
--	--	---	---

(Satz 1) GENERAL CLEAR HEIGHT RULE

A APPLICABILITY	Aufenthaltsräume (habitable rooms) Metric: type = Aufenthaltsraeume
R REQUIREMENT	Must have a minimum clear room height of at least 2.40 m. Metric: lichteRaumhoehe >= 2.40 m

(Satz 2) SPECIAL RULE — HABITABLE ROOMS IN THE ROOF SPACE

A APPLICABILITY	Aufenthaltsräume im Dachraum (habitable rooms in the roof space) Metric: type = AufenthaltsraeumeImDachraum
R REQUIREMENT <i>— clear height</i>	Must have a clear room height of at least 2.20 m Metric: lichteRaumhoehe >= 2.20 m
R REQUIREMENT <i>— floor area</i>	Over at least half (>= 50 %) of the net floor area. Metric: nettoRaumflaeche >= 0.50 ratio
S SELECTION <i>— roof location</i>	Room parts located in the roof space with a clear height up to 1.50 m Metric: location = RoofSpace
E EXCEPTION <i>— 1.50 m zone</i>	Room parts with a clear height of up to 1.50 m are disregarded (excluded from the net floor area calculation). Metric: lichteRaumhoehe <= 1.50 m -> excluded from area

(Satz 3) EXCEPTION — RESIDENTIAL BUILDINGS OF CLASSES 1 AND 2

A
APPLICABILITY

Aufenthaltsräume in Wohngebäuden (habitable rooms in residential buildings)

Metric: type = AufenthaltsraeumeInWohngebaeuden

E
EXCEPTION
— GK 1

Sentences 1 and 2 do *not* apply to residential buildings of **Gebäudeklasse 1**.

Metric: gebaeudeKlasse = GK1

E
EXCEPTION
— GK 2

Sentences 1 and 2 do *not* apply to residential buildings of **Gebäudeklasse 2**.

Metric: gebaeudeKlasse = GK2

§ 47

Habitable Rooms (Aufenthaltsräume)

R REQUIREMENT

A APPLICABILITY

S SELECTION

E EXCEPTION

- ¹ Aufenthaltsräume müssen eine lichte Raumhöhe von mindestens 2,40 m haben.
- ² Aufenthaltsräume im Dachraum müssen eine lichte Raumhöhe von mindestens 2,20 m über mindestens der Hälfte ihrer Netto-Raumfläche haben; Raumteile mit einer lichten Raumhöhe bis zu 1,50 m bleiben außer Betracht.
- ³ Die Sätze 1 und 2 gelten nicht für Aufenthaltsräume in Wohngebäuden der Gebäudeklassen 1 und 2.

Requiremen
t

Applicabil
ity

Selection

Exception

Source: Musterbauordnung
(MBO) § 47 – RASE mark-up by
Aryana Hami, Othman & Samih,
SS 2026