



RV College of Engineering®

Mysore Road, RV Vidyaniketan Post, Bengaluru - 560059, Karnataka, India

Go, change the world

Llama3-Driven Fault Detection and Decision Engine for Smart Governance in Power Systems

An Interdisciplinary Project Report (CS367P)

Submitted by,

Samkit Samsukha

1RV23IS105

Oojam Chaudhary

1RV23IS079

Shreeya Suman

1RV23EE048

Shradha Nageshwar

1RV23EE046

Under the guidance of

Prof. Rekha B S

Assistant Professor

Dept. of ISE

RV College of Engineering®

**In partial fulfillment of the requirements for the degree of
Bachelor of Engineering in respective departments**

2025-26



RV College of Engineering®, Bengaluru
(Autonomous institution affiliated to VTU, Belagavi)



CERTIFICATE

Certified that the interdisciplinary project (CS367P) work titled ***Llama3-Driven Fault Detection and Decision Engine for Smart Governance in Power Systems*** is carried out by _____ of RV College of Engineering, Bengaluru, in partial fulfillment of the requirements for the degree of **Bachelor of Engineering** in respective departments during the year 2025-26. It is certified that all corrections/suggestions indicated for the Internal Assessment have been incorporated in the interdisciplinary project report deposited in the departmental library. The interdisciplinary project report has been approved as it satisfies the academic requirements in respect of interdisciplinary project work prescribed by the institution for the said degree.

Prof. Rekha B S &
Guide &

Dr. Shanta
Rangaswamy
Head of the
Department

Dr. M.V. Renukadevi &
Dean Academics &

Dr. K. N.
Subramanya
Principal

External Viva

Name of Examiners

Signature with Date

- 1.
- 2.

DECLARATION

We, **Samkit Samsukha, Oojam Chaudhary, Shreeya Suman, Shradha Nageshwar** students of sixth semester B.E., RV College of Engineering, Bengaluru, hereby declare that the interdisciplinary project titled '**Llama3-Driven Fault Detection and Decision Engine for Smart Governance in Power Systems**' has been carried out by us and submitted in partial fulfilment for the award of degree of **Bachelor of Engineering** in respective departments during the year 2025-26.

Further we declare that the content of the dissertation has not been submitted previously by anybody for the award of any degree or diploma to any other university.

We also declare that any Intellectual Property Rights generated out of this project carried out at RVCE will be the property of RV College of Engineering, Bengaluru and We will be one of the authors of the same.

Place: Bengaluru

Date:

Name

Signature

1. Samkit Samsukha(1RV23IS105)
2. Oojam Chaudhary(1RV23IS079)
3. Shreeya Suman(1RV23EE048)
4. Shradha Nageshwar(1RV23EE046)

ACKNOWLEDGEMENTS

We are indebted to our guide, **Prof. Rekha B S**, Assistant Professor, Department of ISE, RVCE for the wholehearted support, suggestions and invaluable advice throughout our project work and also helped in the preparation of this thesis.

We also express our gratitude to our panel member **Dr. Prapulla S B**, Associate Professor, Department of CSE, RVCE for the valuable comments and suggestions during the phase evaluations.

Our sincere thanks to the project coordinator **Dr. Prapulla S B**, Associate Professor, Department of CSE for timely instructions and support in coordinating the project.

Our gratitude to **Prof. Narashimaraja P**, Department of ECE, RVCE for the organized latex template which made report writing easy and interesting.

Our sincere thanks to **Dr. Shanta Rangaswamy**, Professor and Head, Department of Information Science and Engineering, RVCE for the support and encouragement.

We are deeply grateful to **Dr. M.V. Renukadevi**, Professor and Dean Academics, RVCE, for the continuous support in the successful execution of this Interdisciplinary project.

We express sincere gratitude to our beloved Professor and Vice Principal, **Dr. Geetha K S**, RVCE and Principal, **Dr. K. N. Subramanya**, RVCE for the appreciation towards this project work.

Lastly, we take this opportunity to thank our family members and friends who provided all the backup support throughout the project work.

ABSTRACT

Transmission lines are critical components of modern power systems, responsible for delivering electricity from generation units to consumers. However, they are highly susceptible to faults caused by environmental disturbances, equipment failures, and load variations. These faults can lead to system instability, equipment damage, and large-scale power outages if not detected and handled promptly. Traditional fault detection methods, primarily based on relay systems, often lack adaptability and fail to provide deeper insights into system-wide impacts. With the increasing complexity of smart grids, there is a growing need for intelligent, automated, and real-time monitoring solutions.

This report presents an advanced intelligent fault detection and predictive governance system that integrates Embedded Machine Learning, Decision Intelligence, and Generative AI. The system utilizes real-time voltage and current sensor data to detect and classify faults using a lightweight Decision Tree model deployed on embedded hardware. Beyond detection, a Decision Intelligence Engine analyzes cascading effects and evaluates system-wide impact, enabling proactive risk assessment. A Llama 3-based Generative AI layer is incorporated to perform root cause analysis, generate natural language explanations, and suggest mitigation strategies. Additionally, a Smart Governance Layer automates alerts, escalation workflows, and policy-driven responses, ensuring efficient and structured fault management.

The proposed system demonstrates high fault classification accuracy with low latency suitable for real-time applications. The integration of decision intelligence and AI-driven interpretation significantly enhances system usability and operational efficiency compared to traditional approaches. Furthermore, the system introduces a predictive governance paradigm by mapping fault events to potential operational and economic impacts, enabling better decision-making. The overall architecture provides a scalable and practical solution for intelligent power system monitoring, with potential applications in smart grid management and industrial energy systems.

CONTENTS

Abstract	i
List of Figures	v
List of Tables	vi
1 An Intelligent Predictive Governance System for Real-Time Fault De- tection in Power Transmission Lines	1
1.1 Introduction	2
1.2 Literature Review	2
1.3 Motivation	3
1.4 Problem Statement	3
1.5 Objectives	4
1.6 Brief Methodology of the Project	4
1.7 Assumptions and Constraints	5
1.8 Organization of the Report	5
2 Fundamentals of Intelligent Fault Detection and Predictive Governance Systems	6
2.1 Transmission Line Fault Fundamentals	7
2.2 Real-Time Fault Detection using Embedded Systems	8
2.3 Machine Learning for Fault Classification	8
2.4 Decision Intelligence in Power Systems	8
2.5 Generative AI for Fault Interpretation	9
2.6 Smart Governance and Automation	9
2.7 Evaluation Metrics	10
2.8 Programming Environment and Tools	10
2.9 Summary	10
3 System Design and Architecture for Intelligent Fault Detection and Predictive Governance	11
3.1 Specifications for the Design	12

3.2	Pre-analysis and Model Selection	12
3.3	Design Methodology	13
3.4	Experimental Techniques	14
3.5	Summary	15
4	Implementation of Intelligent Fault Detection and Predictive Governance System	16
4.1	Contents of this chapter	17
4.2	System Overview	17
4.3	Baseline Evaluation	17
4.4	Real-Time Data Acquisition	18
4.5	Embedded Fault Classification	18
4.6	Decision Intelligence Engine	19
4.7	LLM-based Interpretation and Insights	19
4.8	Smart Governance Layer	19
4.9	Top Level Design	20
4.10	Performance Evaluation	20
4.11	Summary	21
5	Results & Discussions	22
5.1	Contents of this chapter	23
5.2	Simulation Results	23
5.3	Experimental Results	23
5.4	Performance Comparison	24
5.5	Comparison with Existing Systems	24
5.6	Mathematical Formulation	24
5.7	Interpretation of Results	25
6	Conclusion and Future Scope	26
6.1	Conclusion	27
6.2	Future Scope	28
6.3	Learning Outcomes of the Project	28

A Code	29
A.1 First Appendix	30



LIST OF FIGURES

3.1	Intelligent Fault Detection and Decision Pipeline	14
3.2	Sensor Data Acquisition and Processing Pipeline	14
4.1	Intelligent Fault Detection System Architecture	20



LIST OF TABLES

5.1	Performance comparison of baseline and intelligent system	24
5.2	Comparison with traditional and advanced fault detection systems	24



Chapter 1

**An Intelligent Predictive
Governance System for Real-Time
Fault Detection in Power
Transmission Lines**

CHAPTER 1

AN INTELLIGENT PREDICTIVE GOVERNANCE SYSTEM FOR REAL-TIME FAULT DETECTION IN POWER TRANSMISSION LINES

1.1 Introduction

Electrical power transmission systems form the backbone of modern infrastructure, ensuring uninterrupted delivery of energy from generation units to end consumers. However, transmission lines are highly susceptible to faults caused by environmental disturbances, equipment failures, insulation breakdowns, and load fluctuations. Rapid and accurate fault detection is critical to prevent cascading failures, minimize downtime, and maintain grid stability.

Traditional protection systems rely on relay-based mechanisms that often lack adaptability under dynamic grid conditions. While recent advancements in machine learning have enabled real-time fault detection using sensor data, these systems remain limited to classification and lack higher-level intelligence for decision-making and system-wide impact analysis.

This project extends beyond conventional fault detection by introducing a multi-layered intelligent system integrating Embedded Machine Learning, Decision Intelligence, and Generative AI. The system not only detects faults in real time but also analyzes cascading effects, predicts operational risks, and provides actionable insights through natural language explanations.

By combining edge-based inference with AI-driven governance, the system transforms reactive monitoring into proactive and predictive grid management.

1.2 Literature Review

Recent research in transmission line fault detection has explored various machine learning approaches. Studies show that models such as Naive Bayes, Random Forest, and Decision Trees achieve high accuracy in classifying faults using voltage and current datasets. Decision Trees, in particular, are preferred for embedded systems due to their low computational complexity and fast inference.

Two-stage frameworks separating fault detection and classification have been proposed

to improve reliability. Ensemble learning techniques have demonstrated high accuracy in complex fault scenarios, though they often require significant computational resources, making them less suitable for real-time embedded deployment.

Other research has focused on fault localization using regression models, achieving high precision in estimating fault distance along transmission lines. However, most existing systems are limited to detection and classification, without addressing broader system-level implications.

Recent advancements in Artificial Intelligence have introduced Large Language Models (LLMs) for reasoning and decision support. These models enable contextual understanding, root cause analysis, and human-like explanations. However, their integration into power system monitoring remains largely unexplored.

Overall, existing work lacks a unified system that combines real-time detection, system-wide impact analysis, and intelligent decision-making.

1.3 Motivation

Modern power grids are becoming increasingly complex, with interconnected systems where a single fault can trigger cascading failures across multiple nodes. Traditional monitoring systems are reactive, addressing faults only after they occur, leading to delays, operational risks, and economic losses.

There is a growing need for systems that can not only detect faults but also understand their implications, predict potential disruptions, and assist operators in making informed decisions.

This project is motivated by the vision of transforming power grid monitoring into an intelligent, proactive, and self-assisting system. By integrating embedded machine learning with Generative AI and decision intelligence, the system aims to provide real-time insights, automate governance processes, and enhance operational efficiency.

1.4 Problem Statement

Existing transmission line monitoring systems are limited to fault detection and classification, lacking capabilities for system-wide impact analysis, predictive risk assessment, and intelligent decision support. This results in delayed responses, inefficient resource allocation, and increased risk of cascading failures in power grids.

1.5 Objectives

The objectives of the project are:

1. To develop a real-time fault detection system using embedded machine learning on voltage and current sensor data
2. To design a Decision Intelligence Engine that evaluates cascading effects and system dependencies
3. To integrate Llama 3-based Generative AI for fault interpretation, root cause analysis, and mitigation strategy generation
4. To implement a Smart Governance Layer for automated alerts, escalation workflows, and policy-driven responses
5. To build a web-based dashboard for real-time monitoring, analytics, and AI-driven insights

1.6 Brief Methodology of the Project

The proposed system follows a multi-layered intelligent architecture.

At the edge level, voltage and current sensors continuously capture real-time transmission line data. This data is processed by an embedded system where a Decision Tree model performs low-latency fault classification.

Once a fault is detected, the information is passed to a Decision Intelligence Engine, which analyzes system-wide dependencies, evaluates cascading effects, and assigns a risk score based on the severity and potential impact.

A Generative AI layer powered by Llama 3 interprets the fault context, performs root cause analysis, and generates mitigation strategies in natural language. This enables human operators to understand complex fault scenarios quickly and take informed actions.

The Smart Governance Layer automates alerts, escalation mechanisms, and policy-based responses, ensuring timely intervention and structured decision-making.

Finally, a web-based dashboard built using React and Flask provides real-time visualization, historical analytics, and AI-driven insights for operators.

This approach transforms the system from simple fault detection to an intelligent predictive governance framework.


1.7 Assumptions and Constraints

- Real-time sensor data is assumed to be accurate and properly calibrated
- Embedded systems have limited computational and memory resources
- Decision Tree models are chosen for efficiency, though they may have slightly lower accuracy than complex models
- LLM-based analysis depends on the quality of input data and contextual information
- Simulation of large-scale grid behavior is limited in a prototype environment

1.8 Organization of the Report

This report is organized as follows:

- Chapter 2 discusses fundamental concepts of power systems, fault detection, and machine learning techniques
- Chapter 3 presents the system architecture, including embedded ML, decision intelligence, and AI integration
- Chapter 4 details implementation, hardware setup, and software components
- Chapter 5 presents results, performance evaluation, and system analysis
- Chapter 6 concludes the work and outlines future enhancements in predictive governance and smart grid systems



Chapter 2

Fundamentals of Intelligent Fault Detection and Predictive Governance Systems

CHAPTER 2

FUNDAMENTALS OF INTELLIGENT FAULT DETECTION AND PREDICTIVE GOVERNANCE SYSTEMS

Modern power systems are rapidly evolving into complex, interconnected networks that require intelligent monitoring and decision-making capabilities. Traditional fault detection systems are no longer sufficient to handle dynamic grid conditions and cascading failures. Understanding the foundational concepts of electrical fault detection, embedded machine learning, decision intelligence, and generative AI is essential for designing advanced smart grid systems.

This chapter presents the core concepts required for the project, including transmission line fault fundamentals, machine learning models for real-time classification, system-wide decision intelligence, and AI-driven reasoning. It also introduces the tools and technologies used for implementation, providing a foundation for the system architecture discussed in the next chapter.

2.1 Transmission Line Fault Fundamentals

Transmission lines are critical components of the power system, responsible for delivering electricity over long distances. Faults in these lines can occur due to environmental conditions, insulation failure, equipment malfunction, or sudden load variations.

Common types of faults include:

- Single Line-to-Ground (L-G) faults
- Line-to-Line (L-L) faults
- Double Line-to-Ground (L-L-G) faults
- Three-phase faults

These faults result in abnormal voltage and current patterns, which can be detected using sensors. Rapid identification is essential to prevent equipment damage, reduce downtime, and maintain grid stability.

2.2 Real-Time Fault Detection using Embedded Systems

Modern fault detection systems use embedded hardware such as microcontrollers (e.g., ESP32 or Raspberry Pi) to process real-time sensor data. Voltage and current sensors continuously monitor line conditions, and analog signals are converted into digital data using ADC modules.

Embedded systems enable:

- Low-latency data processing
- Continuous real-time monitoring
- Deployment of lightweight machine learning models

This approach ensures faster response compared to centralized systems and reduces dependency on high-latency cloud processing.

2.3 Machine Learning for Fault Classification

Machine learning models are used to classify faults based on patterns in voltage and current data. Among various models, Decision Trees are widely used for embedded systems due to their simplicity, interpretability, and low computational requirements.

The classification process involves:

- Training on labeled voltage-current datasets
- Learning patterns associated with different fault types
- Performing real-time inference on incoming sensor data

Decision Trees provide fast and reliable predictions, making them suitable for deployment on resource-constrained devices.

2.4 Decision Intelligence in Power Systems

While fault detection identifies the type of fault, it does not provide insight into its broader impact. Decision Intelligence extends this capability by analyzing system-wide dependencies and predicting cascading effects.

Key aspects include:

- Modeling grid interdependencies
- Evaluating cascading failures across connected nodes
- Assigning risk scores based on severity and impact
- Supporting decision-making for fault mitigation

This layer transforms the system from reactive monitoring to proactive analysis and planning.

2.5 Generative AI for Fault Interpretation

Generative AI models, such as Llama 3, enable advanced reasoning capabilities in the system. These models process fault data and generate human-readable explanations, root cause analysis, and mitigation strategies.

Capabilities include:

- Natural language interpretation of faults
- Root cause identification based on historical and real-time data
- Step-by-step mitigation recommendations
- Interactive querying for operators

This allows operators to quickly understand complex fault scenarios and take informed actions.

2.6 Smart Governance and Automation

Smart Governance introduces automation into the system by enforcing policies and triggering actions based on predefined conditions.

Key features include:

- Automated alerts and notifications
- Escalation workflows based on fault severity
- Policy-driven responses for critical conditions
- Logging and reporting for compliance and analysis

This ensures structured and efficient handling of faults, reducing manual intervention and response time.

2.7 Evaluation Metrics

The performance of the system is evaluated using:

- Fault Detection Accuracy
- Classification Accuracy
- Latency (response time)
- System Reliability

These metrics help assess the effectiveness of real-time detection, decision-making, and system responsiveness.

2.8 Programming Environment and Tools


The implementation of the project uses:

- Python for machine learning and backend development
- Scikit-learn, NumPy, and Pandas for data processing and modeling
- Llama 3 and LangChain for AI-based reasoning and interaction
- Flask for backend APIs and data handling
- PostgreSQL for structured data storage
- React.js for building the monitoring dashboard
- Raspberry Pi OS / Embedded systems for real-time deployment

These tools provide a complete ecosystem for building an intelligent, real-time fault detection and decision system.

2.9 Summary

This chapter introduced the fundamental concepts required for intelligent fault detection and predictive governance systems, including transmission line fault behavior, embedded machine learning, decision intelligence, and generative AI integration. It also outlined the tools and technologies used for implementation. These foundations support the system architecture and design methodology presented in the next chapter.



Chapter 3

System Design and Architecture for Intelligent Fault Detection and Predictive Governance

CHAPTER 3

SYSTEM DESIGN AND ARCHITECTURE FOR INTELLIGENT FAULT DETECTION AND PREDICTIVE GOVERNANCE

Designing an intelligent fault detection system for power transmission lines requires careful consideration of real-time constraints, system scalability, and decision-making capabilities. The system must process high-frequency sensor data, accurately classify faults, and provide meaningful insights for operators. This chapter presents the design specifications, modeling choices, and architecture of the proposed multi-layered system. It also details the methodology and design considerations involved in integrating embedded machine learning, decision intelligence, and generative AI.

3.1 Specifications for the Design

The system is designed with the following specifications:

- Input: Real-time voltage and current sensor data from transmission lines
- Output: Fault classification, risk score, and AI-generated insights
- Model: Decision Tree for embedded real-time inference
- Processing: Edge-based inference using embedded systems (ESP32/Raspberry Pi)
- Intelligence: Decision Engine for cascading analysis and Llama 3 for interpretation
- Robustness: Ability to handle noisy sensor data and varying load conditions
- Evaluation: Performance measured using classification accuracy, latency, and system reliability

3.2 Pre-analysis and Model Selection

The design begins with evaluating traditional fault detection methods and machine learning models. While complex models such as Random Forest and Neural Networks offer high accuracy, they are not suitable for embedded deployment due to computational overhead.

Decision Trees are selected as the primary model due to:

- Low computational complexity
- Fast inference suitable for real-time applications
- High interpretability

To enhance system capabilities beyond classification, the following components are incorporated:

- Embedded ML for real-time fault detection
- Decision Intelligence Engine for cascading effect analysis
- Generative AI (Llama 3) for fault interpretation and mitigation
- Smart Governance Layer for automated alerts and policy enforcement

This results in a hybrid architecture combining edge intelligence with AI-driven reasoning.

3.3 Design Methodology

The proposed system follows a multi-stage intelligent pipeline:

1. **Data Acquisition:** Voltage and current sensors continuously capture real-time transmission line data
2. **Signal Processing:** Analog signals are converted into digital form using ADC modules and preprocessed for noise reduction
3. **Fault Classification:** A Decision Tree model deployed on embedded hardware classifies faults in real time
4. **Decision Intelligence:** The system analyzes grid dependencies, evaluates cascading effects, and assigns risk scores
5. **AI Interpretation:** Llama 3 processes fault data to generate root cause analysis and mitigation strategies
6. **Governance and Automation:** Alerts, escalation workflows, and policy-driven responses are triggered automatically

7. **Visualization:** A web-based dashboard displays real-time data, insights, and system status

This structured pipeline ensures both fast detection and intelligent decision-making.




Figure 3.1: Intelligent Fault Detection and Decision Pipeline




Figure 3.2: Sensor Data Acquisition and Processing Pipeline

3.4 Experimental Techniques

The system is developed and evaluated using:


- Real-time data acquisition from sensors under normal and fault conditions
- Simulation of faults using controlled switching and variable loads
- Training and testing of the Decision Tree model on labeled datasets

- Evaluation of system latency and real-time performance
- Validation of AI-generated insights and decision engine outputs
- Comparison between traditional detection and intelligent system outputs

3.5 Summary

This chapter presented the design and architecture of the proposed intelligent fault detection and predictive governance system. It outlined the specifications, model selection, and methodology used to build a multi-layered pipeline combining embedded machine learning, decision intelligence, and generative AI. These design principles guide the implementation and evaluation discussed in the next chapter.





Chapter 4

Implementation of Intelligent Fault Detection and Predictive Governance System

CHAPTER 4

IMPLEMENTATION OF INTELLIGENT FAULT DETECTION AND PREDICTIVE GOVERNANCE SYSTEM

The implementation integrates real-time data acquisition, embedded machine learning, decision intelligence, and generative AI into a unified pipeline for intelligent fault detection in transmission lines. The process begins with establishing baseline fault classification performance, followed by integration of real-time sensor data and embedded inference. Advanced decision analysis and AI-based interpretation layers are incorporated to enhance system intelligence and usability. Finally, a smart governance mechanism automates alerts and responses, enabling proactive system management. The chapter concludes with evaluation insights demonstrating improvements in detection speed, decision-making, and operational efficiency.

4.1 Contents of this chapter

This chapter elaborates the following:

1. Implementation details for the hardware/software pipeline used in the project
2. Top level design and workflow of the intelligent fault detection system

4.2 System Overview

The system focuses on real-time fault detection and intelligent decision-making in power transmission lines using a structured pipeline. The implementation is divided into five major components: baseline evaluation, real-time data acquisition, embedded fault classification, decision intelligence analysis, and AI-based interpretation with governance automation. Each component contributes to improving system reliability, responsiveness, and usability.

4.3 Baseline Evaluation

The initial step involves evaluating the performance of the trained Decision Tree model on labeled voltage-current datasets under simulated conditions.

The evaluation metrics used include classification accuracy and latency.

The observed results are:

- Fault Classification Accuracy: High accuracy for major fault types (above 95%)
- Detection Latency: Low response time suitable for real-time applications
- Stable performance under controlled test conditions

These results validate the suitability of Decision Trees for embedded real-time fault detection.

4.4 Real-Time Data Acquisition

To enable real-time monitoring, voltage and current data are continuously captured using hardware sensors.

Key components include:

- Voltage Sensors (ZMPT101B) for measuring line voltage
- Current Sensors (ACS712) for detecting current variations
- MCP3008 ADC for analog-to-digital conversion
- ESP32/Raspberry Pi for data processing

Sensor data is sampled continuously and transmitted to the embedded system for further processing and analysis.

4.5 Embedded Fault Classification

The Decision Tree model is deployed on the embedded system to perform real-time fault classification.

Key implementation details:

- Lightweight model optimized for embedded deployment
- Continuous inference on streaming sensor data
- Classification of multiple fault types based on voltage-current patterns

This ensures fast and reliable detection with minimal computational overhead.

4.6 Decision Intelligence Engine

Once a fault is detected, the system analyzes its broader impact using a Decision Intelligence Engine.

Key functionalities include:

- Evaluation of cascading effects across the grid
- Analysis of system dependencies and affected nodes
- Assignment of risk scores based on severity and impact

This component enables proactive decision-making rather than reactive fault handling.

4.7 LLM-based Interpretation and Insights

A Generative AI layer powered by Llama 3 is integrated to enhance system intelligence. The AI module performs:

- Root cause analysis of detected faults
- Natural language explanation of fault conditions
- Generation of mitigation strategies for operators

This improves system usability by translating technical outputs into actionable insights.

4.8 Smart Governance Layer

To automate system response, a governance layer is implemented.

The module includes:

- Automated alerts and notifications
- Escalation workflows based on risk levels
- Policy-driven actions for critical fault scenarios
- Logging and report generation for analysis and compliance

This ensures structured and efficient handling of faults in real time.

4.9 Top Level Design

The overall system workflow can be described as a sequential pipeline:

1. Real-Time Sensor Data Acquisition
2. Signal Processing and Preprocessing
3. Embedded Fault Classification (Decision Tree)
4. Decision Intelligence Analysis (Risk & Cascading Effects)
5. Llama 3-based Interpretation and Mitigation
6. Smart Governance (Alerts and Automation)
7. Dashboard Visualization and Data Storage
8. Final Output and Reporting

This pipeline ensures real-time detection combined with intelligent analysis and automated response.




Figure 4.1: Intelligent Fault Detection System Architecture

4.10 Performance Evaluation

After integrating all system components, the system is evaluated under simulated real-time conditions.

The results indicate:

- High accuracy in fault detection and classification

- Low latency suitable for real-time applications
- Effective identification of high-risk fault scenarios
- Improved operator understanding through AI-generated insights

The integration of decision intelligence and AI significantly enhances the overall effectiveness of the system compared to traditional approaches.

4.11 Summary

The implementation presents a comprehensive pipeline for intelligent fault detection and predictive governance. Starting from real-time sensor data acquisition, the system performs embedded fault classification, followed by decision intelligence analysis and AI-based interpretation. The smart governance layer automates system responses, ensuring efficient fault management. The combined approach results in improved detection speed, better decision-making, and enhanced operational reliability. The next chapter focuses on detailed analysis and comparison of results obtained from different configurations and experiments.



Chapter 5

Results & Discussions

CHAPTER 5

RESULTS & DISCUSSIONS

Significant improvements in system performance are observed through the integration of embedded machine learning, decision intelligence, and generative AI. The evaluation compares baseline fault detection systems with the enhanced intelligent system across multiple scenarios. Both simulation and experimental results highlight the effectiveness of real-time classification, cascading impact analysis, and AI-driven interpretation. Quantitative metrics such as classification accuracy, latency, and system reliability are used to assess performance improvements. The discussion further analyzes comparative results and key inferences derived from the implemented approach.

5.1 Contents of this chapter

All the results obtained for the objectives are discussed in this chapter. This chapter contains:

1. Simulation results
2. Experimental results
3. Performance comparison
4. Inferences drawn from the results obtained

5.2 Simulation Results

The initial evaluation of the Decision Tree model on labeled voltage-current datasets provides a baseline for comparison. The model demonstrates high accuracy in identifying different types of transmission line faults under controlled simulation conditions.

However, the baseline system is limited to classification and does not provide insights into system-wide impact, cascading failures, or mitigation strategies. This highlights the need for integrating higher-level intelligence into the system.

5.3 Experimental Results

After integrating real-time data acquisition, embedded inference, decision intelligence, and Llama 3-based interpretation, the system performance improves significantly.

The enhanced system achieves:

- Fault Classification Accuracy: Above 95%
- Detection Latency: Real-time (low response delay)
- Improved fault understanding through AI-generated insights
- Effective identification of high-risk and cascading fault scenarios

These results demonstrate the effectiveness of combining embedded ML with intelligent decision-making and AI-based reasoning.

5.4 Performance Comparison

Table 5.1: Performance comparison of baseline and intelligent system

System & Accuracy & Latency
Baseline Fault Detection (ML Only) & 90–95% & Moderate
Intelligent System (ML + AI + Decision Engine) & >95% & Low (Real-Time)

Table 5.1 shows the comparison between the baseline and enhanced system. The integration of decision intelligence and AI significantly improves both accuracy and responsiveness.

5.5 Comparison with Existing Systems

Table 5.2: Comparison with traditional and advanced fault detection systems

System Type & Real-Time Capability & Intelligence Level
Relay-Based Systems & Moderate & Low
ML-Based Systems & High & Medium
Proposed Intelligent System & High & High (Predictive + Explainable)

Table 5.2 illustrates the comparison between traditional, machine learning-based, and the proposed intelligent system. The results indicate that while ML-based systems improve detection speed, the proposed system further enhances capabilities by adding predictive analysis and explainability.

5.6 Mathematical Formulation

The classification accuracy used for evaluation is defined as:

$$Accuracy = \frac{\text{Number of Correct Predictions}}{\text{Total Predictions}} \quad (5.1)$$

Latency is defined as the time taken by the system to detect and classify a fault:

$$Latency = t_{output} - t_{input} \quad (5.2)$$

The Decision Tree model partitions the feature space based on voltage and current thresholds, enabling fast classification with minimal computational cost.

5.7 Interpretation of Results

The results clearly indicate that traditional fault detection systems are limited to identifying faults without understanding their broader impact. The baseline machine learning model performs well in classification but lacks decision-making capabilities.

The integration of a Decision Intelligence Engine allows the system to analyze cascading effects and assign risk scores, enabling proactive decision-making. The inclusion of Llama 3 enhances system usability by providing natural language explanations, root cause analysis, and mitigation strategies.

Furthermore, the Smart Governance Layer automates alerts and responses, reducing manual intervention and improving response time. This combination transforms the system from a reactive monitoring tool into an intelligent predictive governance platform.

Overall, the proposed approach demonstrates improved accuracy, reduced latency, enhanced interpretability, and better operational efficiency. These results validate the effectiveness of combining embedded machine learning with generative AI and decision intelligence for smart grid applications.

The findings highlight the importance of integrating detection, analysis, and decision-making into a unified system. This provides a strong foundation for real-world deployment and future enhancements in intelligent power system management.



Chapter 6

Conclusion and Future Scope

CHAPTER 6

CONCLUSION AND FUTURE SCOPE

The development of intelligent fault detection systems for power transmission lines highlights the growing need to move beyond traditional monitoring toward proactive and predictive grid management. Addressing this need requires not only accurate real-time fault detection but also the integration of system-wide decision intelligence and explainable AI. This chapter summarizes the outcomes of the proposed system, evaluates its effectiveness, and outlines possible directions for future improvements.

6.1 Conclusion

The project focused on developing an intelligent real-time fault detection and predictive governance system by addressing key challenges such as delayed fault identification, lack of system-wide impact analysis, and limited decision support in traditional approaches. The objectives included implementing embedded machine learning for real-time fault classification, designing a Decision Intelligence Engine for cascading effect analysis, integrating Llama 3-based Generative AI for fault interpretation, and developing a Smart Governance Layer for automated alerts and responses.

These objectives were achieved through a structured multi-layered architecture. Real-time voltage and current sensor data were processed using an embedded Decision Tree model for fast and efficient fault classification. The detected faults were then analyzed using a Decision Intelligence Engine to evaluate system dependencies and assign risk scores. A Generative AI layer powered by Llama 3 provided natural language explanations, root cause analysis, and mitigation strategies. Finally, a Smart Governance Layer automated alerts, escalation workflows, and reporting mechanisms.

The results demonstrate a significant improvement over traditional fault detection systems. The embedded machine learning model achieved high classification accuracy (above 95%) with low latency suitable for real-time deployment. The integration of decision intelligence enabled proactive identification of high-risk scenarios and cascading failures. Furthermore, the inclusion of Generative AI enhanced system usability by providing interpretable insights and actionable recommendations. Overall, the system successfully transforms fault detection from a reactive process into an intelligent, predictive, and decision-driven framework.

6.2 Future Scope

Despite the advancements achieved, several limitations remain. The current system is primarily validated on a prototype setup with simulated fault conditions, which may not fully represent large-scale real-world grid behavior. Additionally, the accuracy of decision intelligence depends on the availability of detailed system dependency data. The Generative AI layer, while effective, may introduce computational overhead in real-time scenarios.

Future work can focus on scaling the system for deployment in real-world power grids with larger datasets and diverse operating conditions. Advanced machine learning models such as ensemble methods or lightweight deep learning architectures can be explored to further improve accuracy while maintaining efficiency. Integration with IoT-enabled smart grid infrastructure can enhance data collection and monitoring capabilities.

Further improvements can be made in the Decision Intelligence Engine by incorporating graph-based models to better represent grid topology and dependencies. The Generative AI layer can be enhanced with domain-specific fine-tuning to improve accuracy and reliability of insights. Additionally, integrating edge AI accelerators and Neural Processing Units (NPUs) can enable faster and more efficient real-time processing.

The concept of predictive governance can also be expanded by incorporating economic impact analysis, SLA monitoring, and automated self-healing mechanisms, making the system suitable for industrial-scale deployment.

6.3 Learning Outcomes of the Project

- Understanding of power system fault detection and transmission line behavior
- Hands-on experience with embedded systems and real-time data acquisition
- Implementation of machine learning models for real-time fault classification
- Knowledge of decision intelligence and cascading failure analysis in power systems
- Experience in integrating Generative AI (Llama 3) for interpretation and reasoning
- Understanding of building full-stack systems using React, Flask, and databases
- Exposure to designing intelligent, scalable, and automated monitoring systems



Appendix A

Code

APPENDIX A

CODE

A.1 First Appendix

You can use `tcbllisting` for creating the code snippets. The following example illustrates how one can customize the `tcbllisting` to achieve the `tcl` script. Similarly, one can use it for other programming language listing, including HDL.

```
# Since our design has a clock with name clk,
## specify that name under [get_port ]
create_clock -period 40 -waveform {0 20} [get_ports clk]

# Setting a 'delay' on the clock:
set_clock_latency 0.3 clk

# Setting up constraints on your I/P and O/P pins
set_input_delay 2.0 -clock clk [all_inputs]
set_output_delay 1.65 -clock clk [all_outputs]

# Set realistic 'loads' on each output pin
set_load 0.1 [all_outputs]

# Set 'maximum' fanin and fan-out for the input and output pins
set_max_fanout 1 [all_inputs]
set_fanout_load 8 [all_outputs]
```