Standard Operating Procedure

SOP – AZ 101 Environmental Climate Controls

Author:	**Ruben Urias**	(SIGNATURE)	Date:
Revised By:	**Ruben Urias**	(SIGNATURE)	Date: 5/7/2024

Review & Approval

Functional Manager	**Corbin Christian**	(SIGNATURE)	Date:

1.0 Scope:

This procedure applies to the AZ HubStarr Logistics facility storing client finished goods and/or raw materials.

2.0 Purpose:

The purpose of this procedure is to establish a documented process to monitor environmental conditions at the HubStarr Logistics AZ warehouse.

3.0 Responsibility:

HubStarr Logistics AZ management is responsible for ensuring compliance with this procedure.

4.0 References:

None

5.0 Definitions and Abbreviations:

5.1. None

6.0 Process:

6.1. It is the responsibility of HubStarr Logistics to monitor and record ambient temperatures. Per Axle Quality Department climate-controlled products are to be stored in Dry Storage conditions:

6.1.1. Prevailing conditions controlled to avoid absorption of humidity from air. Temperature range +15 to +26.6 ℃ / 59 to 80 ℉, relative humidity > 15% < 60%.

6.2. Finished Products and/or raw materials will be stored in an area compatible with the environmental requirements.

6.2. At least three (3) thermometer(s) and/or hygrometer(s), if applicable, will be installed in each area within the facility where clients finished product and/or raw materials will reside or temporarily held.

6.3. Types and frequencies of recordings are as follows:

6.3.1. HubStarr Logistics AZ will be using multiple Elitech 800 Wi-Fi Temperature/Humidity loggers. All data recorded (1-hour intervals) is transmitted via Wi-Fi network infrastructure. Upon request client will be provided access and user capability to track, search or record any historical data up to 3 years.

6.4. All temperature and humidity data will be maintained for at least three (3) years.

7.0 Document History:

Revision	Change	Effective date
ORG	**Original Issue**	10/10/20
Rev A	**Update company change of name and Logo,** all references of Axle to HubStarr. Process Reviewed.	5/7/2024

This process is required to be reviewed, at a minimum, on a 3-year cycle. If there are no changes to the previous revision the signature below is evidence of the review and approval of this procedure.

Reviewed By: _____ Date _____

Reviewed By: _____ Date_____