SOP – AZ 190 Li-Ion Battery Cell Handling and Storage

Author:	**Sam Vargas**	(SIGNATURE)	Date: 12/2/2025
Revised By:		(SIGNATURE)	Date:

Review & Approval

Functional Manager	**Ruben Urias**	(SIGNATURE)	Date: 12/2/2025

1. Purpose To ensure lithium-ion battery cells are handled and stored in accordance with NFPA 855 and applicable fire protection standards (NFPA 13 / facility ESFR systems) to protect personnel, property, and operations.

2. Scope Applies to the receipt, storage, handling, and emergency response for lithium-ion battery cells at HubStarr facilities.

3. Responsibilities

- Management and Compliance are responsible for ensuring NFPA 855 compliance and maintaining required documentation.
- Operations personnel are responsible for following approved procedures for handling and storage.
- All personnel must report damage, leaks, or thermal events immediately.

4. Key Requirements

- Li-ion battery cells shall be stored and handled in accordance with NFPA 855.
- Storage locations and fire protection must align with the facility's approved ESFR sprinkler systems (as documented in as-built plans).
- A risk assessment shall be performed prior to accepting new cell types or large volumes.
- Damaged, leaking, or compromised cells must be quarantined and reported.
- Charging of cells is not permitted unless specifically authorized.
- Temperature and environmental conditions shall be monitored as required to maintain safe storage.
- Personnel handling Li-ion cells must be trained on the hazards and required controls.

5. Records The following records shall be maintained in accordance with AZ-130 Document Control:

- Risk assessments and approvals
- Inspection and incident records
- Training records

- Environmental monitoring data (as applicable)

6. References

- NFPA 855 – Standard for the Installation of Stationary Energy Storage Systems
- Facility as-built fire sprinkler plans (ESFR systems)
- AZ-130 Document Control SOP
- Related HubStarr SOPs (Quarantine, Receiving, Risk Review, Emergency Action Plan)

7. Document History

This

Revision	Change	Effective date

process is required to be reviewed, at a minimum, on a 3 year cycle. If there are no changes to the previous revision the signature below is evidence of the review and approval of this procedure.

Reviewed By: _____ Date _____

Reviewed By: _____ Date_____