

FUNCTIONAL PERFORMANCE TEST - P-3

Heating hot water pump, Boiler 103

Step 4: Simulate lead pump failure - lag pump did not start (FAIL)

See issue CX-003.

Sample document for the Cx Ledger demo.