

GOVERNMENT OF TELANGANA

INTERNAL WATER QUALITY MONITORING LABORATORY

INTERNAL WATER QUALITY MONITORING LABORATORY
MB,INTRA- DIVISION :: NARAYANPET-(Dist) NARAYANPET

BACTERIOLOGICAL ANALYSIS REPORT

Sample collected by :											
Sl.No.	Date	Name of the Mandal	Panchayath	Habitation	Location	Source	Residual Chlorine (0.2-1.0ppm)	H2S Vials (Negative/Positive) (24 Hours)	Coliform Bacteria/100 ml sample	E Coli/100 ml Sample	Remarks
1	2	3	4	5	6	7	8	9	10	11	12
1	30.09.2026	Marikal	Marikal	Marikal	OXFORD GRAMMAR SCHOOL	RO	NULL	Negative	0	Absent	Satisfactory

Yashwanth
MB,INTRA- DIVISION
MB,INTRA- DIVISION

Microbiologist
MB,INTRA- DIVISION
MB,INTRA- DIVISION

GOVERNMENT OF TELANGANA
INTERNAL WATER QUALITY MONITORING LABORATORY

MB, INTRA-DIVISION :: NARAYANPET

CHEMICAL ANALYSIS REPORT AS Per IS:10500-2012

Sample collected by :

Sl.No.	Date	Name of the Mandal	Panchayath	Habitation	Location	Source	Turbidity (1-5 NTU)	PH limits between (6.5-8.5)	Electrical Conductivity	Total Dissolved Solids Desirable limit 500 mg/lt & Permissible limit 2000 mg/lt	Total Alkalinity as CaCO3 Desirable limit 200 mg/lt & Permissible limit 600 mg/lt		Total Hardness as CaCO3 Desirable limit 300 mg/lt & Permissible limit 600 mg/lt	Fluoride as F Desirable limit 1.0 mg/lt & Permissible limit 1.50 mg/lt	Chloride Desirable limit 250 mg/lt & Permissible limit 1000 mg/lt	Nitrate as NO3 Desirable limit 45 mg/lt & Permissible limit 100 mg/lt	Sulphate as SO4 Desirable limit 200 mg/lt & Permissible limit 400 mg/lt	Iron as Fe Desirable limit 0.3 mg/lt & Permissible limit 1.0 mg/lt	Remarks
1	2	3	4	5	6	7	8	9		10	11	12	13	14	15	16	17	18	19
1	30.09.2026	Marikal	Marikal	Marikal	OXFORD GRAMMAR SCHOOL	RO	NILL	6.89	124	56		20	28	0.02	16	1.02	12.36	0.01	Satisfactory

తెలంగాణ ప్రభుత్వం
ఆరోగ్య శాఖ
హైదరాబాద్

Sauy
Chemist
MB Intra Sub Division,
Narayanpet