PRODUCED BY AN AUTODESK STUDENT VERSION

FROM MAIN DISTRIBUTION PANEL
4x6+2x2.5 Sq.mm ZHLS Cu. Wire

NAME:RPDB-301 (8 WAY TPN DB)
LOC-IN FRONT OF MEETING ROOM

40A FP RCCB

R1	R2	R3	R4	R5	R6	R7	R8	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	B1	B2	B3	B4	B5	B6	B7	B8
10A SP MCB	10A SP MCB	10A SP MCB	10A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB
2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE
SB301, SB302, SB303	SB304, SB305, SB306, SB307	SB308, SB309, SB310, SB311	SB312, SB313, SB314,	PP301, PP302	PP303, PP304	PP305,	AC301	AC302	AC303	AC304	AC305	AC306	AC307	AC308	PAC301 PROVISIONAL AC	D301, D302, D303, D304	D305, D306, D307, D308	D309, D310, D311	D312, D313, D314	D315	D316	G301	SPARE

FROM UPS O/G DB
2x6+2x2.5 Sq.mm ZHLS Cu. Wire

NAME:UPSDB-301(12 WAY SPN DB)
LOC-IN FRONT OF MEETING ROOM

25A DP RCCB 30mA

1	2	3	4	5	6	7	8	9	10
16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB
2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x1.5 Sq mm Cu FRLS WIRE
ESB301, ESB302, ESB303, ESB304	ESB305, ESB306,	UPP301, UPP302	UPP303, UPP304	D301, D302, D303, D304	D305, D306, D307, D308	D309, D310, D311	D312, D313, D314	D315	SPARE

FROM MAIN DISTRIBUTION PANEL
4x6+2x2.5 Sq.mm ZHLS Cu. Wire

NAME:RPDB-201 (8 WAY TPN DB)
LOC-KITCHEN AREA

40A FP RCCB

R1	R2	R3	R4	R5	R6	R7	R8	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	B1	B2	B3	B4	B5	B6	B7	B8
10A SP MCB	10A SP MCB	10A SP MCB	10A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB
2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE							2x2.5+1x1.5 Sq mm Cu FRLS WIRE						
SB201, SB202, SB203, SB204	SB205, SB206, SB207, SB208, SB209	SB205A, SB210, SB211, SB212, SB213	SB214, SB215, SB216, SB217	SB218, SB219, SB220, SB221	PP201, PP202, PP203	PP204, PP205, PP206	PP207, PP208	PP209, D201	PP210, D202	PP211, D203	PAC201 PROVISIONAL AC	PAC202 PROVISIONAL AC	PAC203 PROVISIONAL AC	PAC204 PROVISIONAL AC	PAC205 PROVISIONAL AC	PAC206 PROVISIONAL AC	STAIRCASE -1 LIGHTING CIRCUIT	SPARE	SPARE	SPARE	SPARE	SPARE	SPARE

FROM UPS O/G DB
2x6+2x2.5 Sq.mm ZHLS Cu. Wire

NAME:UPSDB-201(8 WAY SPN DB)
LOC-KITCHEN AREA

25A DP RCCB 30mA

1	2	3	4	5	6
16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB
2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE			
ESB201, ESB202	ESB203, ESB204	ESB205, ESB206, ESB207	SPARE	SPARE	SPARE

FROM MAIN DISTRIBUTION PANEL
4x6+2x2.5 Sq.mm ZHLS Cu. Wire

NAME:RPDB-01 (8 WAY TPN DB)
LOC-COMMON PASSAGE

40A FP RCCB

R1	R2	R3	R4	R5	R6	R7	R8	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	B1	B2	B3	B4	B5	B6	B7	B8
16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB
2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE
SB01, SB02, SB03, SB04	SB05, SB06, SB07, SB08, SB09	SB10, SB11, SB12, SB13	SB14, SB15	SB16, SB17, SB18, SB19, SB20	SB21, SB22, SB23, SB24, SB25, SB26	SB27, SB28, SB29, SB30, SB31, SB32	SB33, SB34, SB35, SB36, SB37, SB38	SB39, SB40, SB41,	SB42, SB43, SB44, SB45	PP01	PP02, PP03	G01	G02	G03	G04	G05	PAC01	PAC02	PAC03	PAC04	PAC05	SPARE	SPARE

FROM UPS O/G DB
2x4+1x2.5 Sq.mm ZHLS Cu. Wire

NAME:UPSDB-01
(4 WAY SPN DB)
LOC-COMMON PASSAGE

25A DP RCCB 30mA

1	2
16A SP MCB	16A SP MCB
2x2.5+1x1.5 Sq mm Cu FRLS WIRE	
ESB01 TO ESB07	SPARE

FROM MAIN DISTRIBUTION PANEL
4x6+2x2.5 Sq.mm ZHLS Cu. Wire

NAME:RPDB-02 (8 WAY TPN DB)
LOC-COMMON PASSAGE

40A FP RCCB

R1	R2	R3	R4	R5	R6	R7	R8	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	B1	B2	B3	B4	B5	B6	B7	B8
16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	16A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB	20A SP MCB
2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x2.5+1x1.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE	2x4+1x2.5 Sq mm Cu FRLS WIRE
SB01, SB02, SB03, SB04	SB05, SB06, SB07, SB08, SB09	SB10, SB11, SB12, SB13	SB14, SB15	SB16, SB17, SB18, SB19, SB20	SB21, SB22, SB23, SB24, SB25, SB26	SB27, SB28, SB29, SB30, SB31, SB32	SB33, SB34, SB35, SB36, SB37, SB38	SB39, SB40, SB41,	SB42, SB43, SB44,	PP01	PP02, PP03	G01	G02	G03	G04	G05	PAC01	PAC02	PAC03	PAC04	PAC05	SPARE	SPARE

FROM UPS O/G DB
2x4+1x2.5 Sq.mm ZHLS Cu. Wire

NAME:UPSDB-02
(4 WAY SPN DB)
LOC-COMMON PASSAGE

25A DP RCCB 30mA

1	2
16A SP MCB	16A SP MCB
2x2.5+1x1.5 Sq mm Cu FRLS WIRE	
ESB01 TO ESB07	SPARE

KEY PLAN

NOTE :

SUFFIX	DATE	REVISIONS
R0	05/04/2021	GOOD FOR CONSTRUCTION

DWG ISSUED FOR
☐ COMMENTS ☐ APPROVAL ☐ TENDER
☐ ADVANCE COPY ☐ RECORD ☑ G.F.C

ARCHITECT :
I N D E S I G N Architects And Interior Designers D-9, Saket Apartment, Patwardhan Baug, Karvenagar, Pune 411052
Tel : 020 - 25455830

ELECTRICAL CONSULTANTS:
abhiyanta CONSULTING ENGINEERS LLP
Shree Swami Krupa, Plot No.-6, Neelkamal Housing Society, Karve nagar. Pune - 411052 . Tel/Fax.- 25462173, 25410691.
design@abhiyantaconsultants.com,
www.abhiyantaconsultants.com

CLIENT:
ARC. AUTISM RESEARCH CENTER

PROJECT:
AUTISM RESEARCH CENTER.

TITLE:
SINGLE LINE DIAGRAM OF LOWER SPLIT PLAN.

SCALE : 1:110 | DATE : 01/04/2021 | DRAWN SHUBHAM | CHECKED AMRUTA | APPROVED VIVEK

DWG.NO. 2021/EL/---- | SUFFIX R0

REF. DWG
ARCH DWG REF:

THIS DRAWING IS THE PROPERTY AND COPYRIGHT OF ABHIYANTA CONSULTING ENGINEERS. ALL RIGHTS RESERVED. NO PART MAY BE REPRODUCED OR USED WITHOUT WRITTEN CONSENT. DO NOT SCALE THE DRAWING.

PRODUCED BY AN AUTODESK STUDENT VERSION