

FIRE ALARM RISER DIAGRAM

N.T.S.

1. REFER TO ELECTRICAL POWER FLOOR PLANS FOR LOCATIONS AND EXACT QUANTITIES OF DEVICES.
2. REFER TO MECHANICAL PLANS FOR QUANTITY AND LOCATIONS OF DUCT MOUNTED SMOKE DETECTORS, DAMPER CONTROL REQUIREMENTS AND FAN SHUT-DOWN REQUIREMENTS.
3. REFER TO FIRE PROTECTION PLANS FOR QUANTITY AND LOCATIONS OF WATERFLOW AND TAMPER SWITCHES.

SYMBOLS LIST

- F — MANUAL PULL STATION
- F — SPEAKER/HORN/STROBE COMBINATION
- F — STROBE LIGHT
- TS — TAMPER SWITCH
- WF — WATER FLOW SWITCH
- D — AREA SMOKE DETECTOR
- D D — DUCT MOUNTED SMOKE DETECTOR
- R — FIRE ALARM RELAY
- TD — TERMINATION/DATA PANEL
- DH — DOOR HOLDER
- EOL — END OF LINE
- FCO — FUSE CUT OUT
- FACP — FIRE ALARM CONTROL PANEL
- S — F.A. STAIR SPEAKER (6)
- FIRE FIGHTER'S TEL. JACK



UPON ALARM CONDITION, FIRE ALARM RELAY SHALL BREAK SECURITY SYSTEM CONTROL/POWER CIRCUIT AND CAUSE ELECTRIC STRIKES TO RELEASE FAIL-SAFE



UPON ALARM CONDITION, FIRE ALARM SYSTEM SHALL CAUSE CONTROL ZONE MODULE (CZ) TO DE-ENERGIZE FIRE ALARM RELAY AND THUS BREAK PRIMARY POWER TO DOOR HOLDER TRANSFORMER CAUSING DOOR HOLDERS TO RELEASE FAIL-SAFE

TYPICAL FIRE ALARM ELECTRIC DOOR HOLDER/STRIKE FAIL-SAFE RELEASE



WIRING DIAGRAM FOR FANS REQUIRING CONTROL FROM FIRE ALARM SYSTEM



WIRING DIAGRAM FOR FIRE/SMOKE DAMPER MONITORING AND CONTROL

M.E. RINKER, SR. SCHOOL OF BUILDING CONSTRUCTION

M.E. RINKER, Sr. HALL
SCHOOL OF BUILDING CONSTRUCTION

UNIVERSITY OF FLORIDA-GAINESVILLE
PROJECT NO. BR-191

ARCHITECTS
CROXTON COLLABORATIVE/
GOULD EVANS ASSOCIATES

CROXTON COLLABORATIVE ARCHITECTS
475 FIFTH AVENUE
NEW YORK, NY 10017
TEL 212.683.1998
FAX 212.683.2799

GOULD EVANS ASSOCIATES
5405 WEST CYPRESS STREET
TAMPA, FL 33607
TEL 813.288.0729
FAX 813.288.0231

MECHANICAL ENGINEERS
LEHR ASSOCIATES
130 WEST 30TH STREET
NEW YORK, NY 10001-4092
TEL 212.947.8050
FAX 212.967.2059

STRUCTURAL ENGINEERS
WALTER P. MOORE
201 EAST KENNEDY BOULEVARD
TAMPA, FL 33602
TEL 813.221.2424
FAX 813.221.2289

CIVIL ENGINEERS
BROWN & CULLEN, INC.
3530 NW 43 STREET
GAINESVILLE, FL 32605
TEL 352.375.8999
FAX 352.375.8933

LANDSCAPE ENGINEERS
McCLAIN DESIGN GROUP, INC.
1843 NW 39 DRIVE
GAINESVILLE, FL 32605
TEL 352.372.2808
FAX 352.372.6622

CONSULTANT
SEEGY-BISCH
AUSSERE SULZBACHER STR. 118
NURNBERG, GERMANY
TEL 0911/59 90 99
FAX 0911/59 98 05

LOUIS J. LEHR CERTIFIED No. 21935 STATE OF FLORIDA PROFESSIONAL ENGINEER

THIS DRAWING, AS AN INSTRUMENT OF SERVICE, IS AND SHALL REMAIN, PROPERTY OF CROXTON COLLABORATIVE ARCHITECTS. THIS DRAWING SHALL NOT BE REPRODUCED, PUBLISHED, USED ON OTHER PROJECTS, USED FOR ADDITIONS, OR USED IN COMPLETION OF THIS PROJECT BY OTHERS EXCEPT BY AGREEMENT IN WRITING. ©2001 CROXTON COLLABORATIVE ARCHITECTS/ GOULD EVANS ASSOCIATES.

NO.	ISSUE/REVISION	DATE

100% CONSTRUCTION DOCUMENTS

DRAWING NAME
FAIRE ALARM RISER DIAGRAM

DATE 11/21/01
SCALE NONE
DRAWN BY/CHECKED BY NA/JH
DRAWING NUMBER E006

G:\1440\ELEC\1440E006FAR.dwg Nov 19, 2001 - 10:51:59 nopostol