

Suraksha Chemicals Pvt. Ltd.

Unit 4 – Specialty Chemicals & Intermediates, Ambarnath, Maharashtra

PERMIT TO WORK POLICY

Document SOP-PTW-01

Document No.	SOP-PTW-01
Issued By	Meera Iyer, Safety Officer (EHS)
Effective Date	01-Jan-2024
Applies To	All personnel and contractors, Unit 4

1. Purpose

This policy defines when a Permit to Work (PTW) is required at Unit 4, who is authorised to issue and approve one, and the conditions under which work may proceed. It applies to all maintenance, modification, and non-routine activity carried out on plant equipment.

2. When a Permit Is Required

- Any work involving isolation of pressurized or rotating equipment (e.g. pumps, compressors, reactors);
- Any confined space entry, including vessels, tanks, or enclosed process equipment;
- Any hot work – welding, cutting, grinding, or other spark-producing activity;
- Any electrical work requiring Lock-Out, Tag-Out of a circuit;
- Any excavation within the plant boundary.

3. Permit Categories

Permit Type	Applies To
General Work Permit	Routine maintenance not involving special hazards
Hot Work Permit	Welding, cutting, grinding, or spark-producing activity
Confined Space Entry Permit	Entry into vessels, tanks, or enclosed process equipment
Electrical Isolation Permit	Work requiring Lock-Out, Tag-Out of electrical systems
Excavation Permit	Any ground-breaking activity within the plant boundary

4. Issuance and Approval

Permits are issued only by an authorised Permit Issuer – a role restricted to Department Heads and the Safety Officer. Before issuing a permit, the Permit Issuer must verify site conditions, confirm isolation status where applicable, and confirm atmospheric testing has been completed for confined space work. No permit may be issued retroactively for work already in progress.

5. Validity and Closure

All permits carry a maximum validity of one shift (12 hours). A permit must be formally closed, with the work area returned to a safe condition, before expiry or extension. Extensions require re-verification of site conditions by the original or an alternate authorised Permit Issuer.

6. Permit Register

A permit register is maintained at the Unit 4 control room and reviewed by the Safety Officer on a weekly basis to confirm all issued permits have been correctly closed. Any permit found open beyond its validity window is escalated immediately to the Safety Officer.

This policy is referenced by the Unit 4 Plant Safety Policy Manual (SC-SP-001, Section 8) and applies to all work orders and SOPs issued at Unit 4.