



Work smarter with UL Product iQ™
Improved access to UL's certification data.

Create your FREE ACCOUNT today!

JDYX2.E221465 Fuses, Supplemental - Component

If you notice a change to your JDYX2 Listing Card, click [here](#) to learn more.

[Page Bottom](#)

Fuses, Supplemental - Component

[See General Information for Fuses, Supplemental - Component](#)

SHENZHEN LANSON ELECTRONICS CO LTD

E221465

A18TH BLDG
3 INDUSTRIAL ZONE
FUQIAO FUYONG TOWN, BAO'AN DISTRICT
SHENZHEN, GUANGDONG 518133 CHINA

Supplemental fuses

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
5D	5.2 x 20 (0.20 x 0.79)	4 - 7	125Vac	100
		4 - 7	250Vac	100
		8 - 10	125Vac	100
		8 - 10	250Vac	100
5F	5.2 x 20 (0.20 x 0.79)	0.125 - 0.315	125Vac	35
		0.125 - 0.315	250Vac	35
		0.4 - 0.8	125Vac	35
		0.4 - 0.8	250Vac	35
		1 - 6.3	125Vac	35
		1 - 6.3	250Vac	35
5K	5.2 x 20 (0.20 x 0.79)	0.2 - 0.8	125Vac	35
		0.2 - 0.8	250Vac	35
		1 - 6.3	125Vac	63
		1 - 6.3	250Vac	63
		8 - 15	125Vac	50
		8 - 15	250Vac	50
5M	5.2 x 20 (0.20 x 0.79)	0.5 - 0.8	250Vac	1500
		1.0 - 3.15	250Vac	1500
		4.0 - 6.3	250Vac	1500
5T	5.2 x 20 (0.20 x 0.79)	0.25 - 3.15	250Vac	1500

		4 - 6.3	250Vac	1500
6N	-	12 - 30	125Vac	10000
		12 - 30	250Vac	750
6S	-	4 - 10	250Vac	100
SRT	8.35 x 7.2 (0.33 x 0.28)	0.25 - 3.15	250Vac	35
		4	250Vac	40
		6.3	250Vac	63

Supplemental fuses: pigtail leads, cartridge enclosed

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
3N	4 x 11 (0.16 x 0.43)	0.1 - 3.15	250Vac	35
		4.0 - 5.0	250Vac	50
		6.3	250Vac	63
		8 - 10	125Vac	100
		8 - 10	250Vac	100

Supplemental fuses: pigtail leads, filled-tube

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
6HV(P)	6.85 x 33 (0.27 x 1.30)	0.1 - 40	250Vac	1500
		0.1 - 40	660Vac	1000
		0.1 - 40	600Vdc	10000
		0.1 - 40	1000Vdc	10000
		0.1 - 40	660Vdc	1000

Supplemental fuses: cartridge enclosed

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
5J	5.2 x 20 (0.20 x 0.79)	0.1 - 15	250Vac	100
		0.1 - 6.3	250Vac	63
		0.1 - 3.15	250Vac	35
6E	-	12 - 30	125Vac	150
		12 - 30	250Vac	150

Supplemental fuses: filled-tube

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
6HV	6.35 x 31.8 (0.25 x 1.25)	0.1 - 40	250Vac	1500
		0.1 - 40	660Vac	1000
		0.1 - 40	600Vdc	10000
		0.1 - 40	1000Vdc	10000
		0.1 - 40	660Vdc	1000

Supplemental fuses: filled-tube, cartridge enclosed

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
5HV	5.2 x 20 (0.20 x 0.79)	0.1 - 25	600Vac	200
		-	-	-
		0.1 - 25	500Vdc	300
		0.1 - 15	400Vdc	2000
5N	5.2 x 20 (0.20 x 0.79)	0.1 - 15	250Vac	1500

Supplemental fuses: pigtail leads

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
4D	-	1.25 - 1.6	250Vac	25
		2 - 3.5	250Vac	50
4E	-	4 - 6.3	250Vac	100
5G	-	4 - 8	125Vac	100
		4 - 8	250Vac	100
5H	-	4 - 6.3	250Vac	100
		4 - 6.3	125Vac	10000

Supplemental fuses: pigtail leads, cartridge enclosed

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
5J(P)	5.4 x 21.5 (0.21 x 0.85)	0.1 - 15	250Vac	100
		0.1 - 6.3	250Vac	63
		0.1 - 3.15	250Vac	35
6E(P)	-	12 - 30	125Vac	150
		12 - 30	250Vac	150

Supplemental fuses: pigtail leads, filled-tube, cartridge enclosed

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
5HV(P)	5.5 x 21 (0.22 x 0.83)	0.1 - 25	600Vac	200
		-	-	-
		0.1 - 25	500Vdc	300
		0.1 - 15	400Vdc	2000
5N(P)	5.4 x 21.5 (0.21 x 0.85)	0.1 - 15	250Vac	1500

Supplemental micro fuses

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
06D	1.6 x 0.8 x 0.48 (0.06 x 0.03 x 0.02)	0.25 - 1	32Vdc	50
		1.25 - 5	32Vdc	35

06H	1.6 x 0.8 x 0.48 (0.06 x 0.03 x 0.02)	1 - 5	32Vdc	50
12B	3.2 x 1.6 x 0.65 (0.13 x 0.06 x 0.03)	0.25 - 1.5	125Vac	50
		0.25 - 1.5	125Vdc	50
12D	3.2 x 1.6 x 0.65 (0.13 x 0.06 x 0.03)	0.25 - 3	32Vac	50
		0.25 - 3	63Vdc	50
		4 - 7	32Vac	50
		4 - 7	32Vdc	50
		7.5 - 20	24Vdc	150
12T	0.65 (0.03)	1 - 4	63Vdc	50
		4.5 - 5	32Vdc	100

Supplemental micro fuses: pigtail leads

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
3J	3.6 x 10 (0.14 x 0.39)	0.1 - 0.4	125Vac	35
		0.1 - 0.4	250Vac	35
		0.5 - 5	125Vac	35
		0.5 - 5	250Vac	35
3K	3.6 x 10 (0.14 x 0.39)	0.2 - 0.8	125Vac	35
		0.2 - 0.8	250Vac	35
		1 - 6.3	125Vac	35
		1 - 6.3	250Vac	35
3NT	3.6 x 10 (0.14 x 0.39)	0.1 - 1	125Vac	25
		0.1 - 1	250Vac	25
		1.25 - 5	250Vac	25
		1.25 - 5	125Vac	25

Supplemental micro fuses: pigtail leads, filled-tube

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
3R	4.3 x 12.5 (0.17 x 0.49)	0.1 - 10	300Vac	100
		0.1 - 10	350Vac	100

Supplemental micro fuses: filled-tube

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
SNT	8.4 x 4.0 x 7.2 (0.33 x 0.16 x 0.28)	0.1 - 6.3	250Vac	100
		0.1 - 6.3	300Vac	100
		0.1 - 6.3	350Vac	100

Supplemental micro fuses: pigtail leads

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
3T	-	3.15 - 5	125Vac	25
		3.15 - 5	250Vac	25
SMT	8.4 x 4 x 7.7 (0.33 x 0.16 x 0.30)	0.1 - 15	250Vac	130
		0.1 - 15	300Vac	50
		0.1 - 15	400Vac	50
SPT	8.4 x 4 x 7.7 (0.33 x 0.16 x 0.30)	0.5 - 5	125Vac	35
		0.5 - 5	250Vac	35
		6.3	250Vac	63
SQT	8.4 x 4 x 5 (0.33 x 0.16 x 0.20)	0.1 - 15	250Vac	130
		0.1 - 15	300Vac	50
		0.1 - 15	400Vac	50

Supplemental micro fuses: surface mount

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
12H	3.2 x 1.6 x 0.65 (0.13 x 0.06 x 0.03)	0.1 - 5	125Vac	50
		0.1 - 5	125Vdc	50
		0.1 - 5	63Vdc	50
		6 - 10	32Vdc	100
		12 - 30	24Vdc	300

Supplemental micro fuses: surface mount, cartridge enclosed

Cat. No.	Size mm(in)	Amps (A)	Volts (V)	Interrupting Rating (A)
24E	6.1 x 2.6 x 2.6 (0.24 x 0.10 x 0.10)	0.1 - 20	350Vac	50
		0.1 - 20	300Vac	50
		0.1 - 20	250Vac	50
		0.1 - 20	125Vac	50
		0.1 - 20	125Vdc	50
24S	6.1 x 2.6 x 2.6 (0.24 x 0.10 x 0.10)	0.1 - 7	125Vac	50
		0.1 - 7	250Vac	50
		0.1 - 7	125Vdc	50

Marking: Company name and model designation.

Last Updated on 2018-11-13[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".