



Amador
(209) 283-9375

El Dorado
(530) 621-2635

Date: 3-12-26

Well Report

1. Address of the property: 7230 Latigo Street
2. This well produces: **21.2** gallons per minute
3. Tank(s) air pressure in psi: 47
4. Tank(s) size: 86 gallon
5. Pressure switch setting and condition: 50/70 good
6. Pump horsepower: 2
7. Drop pipe: 1.25" rigid
8. Depth of well: N/A Static Level: N/A
9. Number of gallons pumped during test: 2550
10. Potability sample collected for tested: Yes

Comments: All equipment in proper working order at this time.

Actual water production depends on hydrological conditions beyond the control of the Contractor, which are subject to dramatic changes in short periods of time. Therefore, the Contractor does not warrant the continued production of any quantity or quality of water observed or reported at any stage or at the conclusion of the project.

TEST PERFORMED BY: Kevin Tempel, Sierra Pump
15780 Butte Mountain Road, Jackson CA 95642

Well Log

Time Collected	GPM
905	21.2
930	21.5
1000	21.2
1030	21.5
1100	21.2