

PARRIS SCOTT ROOFING, INC.

ROOF INSPECTION REPORT

Elizabeth Dawson - 499 Hwy. 4, Murphys, CA

Date of Inspection: 06/22/2026

Roof Type:

- House - 25 year composition shingle roof
- Studio - Metal wide hi panel roof
- Garage - Rusty corrugated metal roof

Roof Age:

- House - 18 to 20 years
- Studio - 20 to 30 years
- Garage - 30 to 40 years

Roof Condition:

- House - Fair
- Studio - Good
- Garage - Fair

Estimated Remaining Life:

- House - 2 to 4 years
- Studio - 15 to 20 years
- Garage - 10 to 15 years with maintenance

Areas of Concern:

- House - Roof shows granular loss and fiberglass showing.
- Studio - All screws are tight.
- Garage - Roof has a few nails and screws sticking up.

Suggested Repairs:

- House - Need to replace roof in 2 to 4 years.
- Studio - No suggested repairs on roof.*
- Garage - Tighten screws, hammer down nails, and apply caulk where needed. \$350.00 for a roof tune up on garage only.

Comments: Keep all roofs free of debris for a longer life.

*Repair leaking water line to the studio swamp cooler.

****Invoice Attached along with pictures.***

Parris Scott Roofing, Inc. will make every attempt to find any and all possible leak areas that might be of concern, however, some areas can go unnoticed because they are covered by roofing material, debris, snow, etc. Although roof coverings, skylights, chimneys, pipes, etc. may appear to be without leaks, Parris Scott Roofing, Inc. cannot guarantee against leaks that develop at any time. Leaks can develop after inspection due to any number of reasons, for example rain and /or wind intensity, tree, snow, ice damage, etc. The home owner should disclose if there are any known active or inactive leaks. This inspection is an opinion only; it is not a guarantee this roof won't leak now or in the future. This report does not exactly predict the life expectancy of the roofing materials and/or its components.

Parris Scott

Parris Scott, CEO

Parris Scott Roofing, Inc.

Lic. #740594

P.O. Box 3204

Arnold, CA 95223

209-795-2073 - Office