



245 New York Ranch Rd, Suite A, Jackson, CA 95642 (209) 868-2100
email: shane@49erwaterlab.com / www.49erwaterlab.com

03/14/2026

Sierra Pump
15780 Butte Mountain Rd
Jackson, CA 95642

Please find the attached report for your water analysis for **Order #34281**. Your sample(s) were received on 03/13/2026 12:42. Your sample(s) were analyzed in accordance with your request with use of AWWA, EPA, ISO/IEC 17025:2017, 2016 TNI Standard and/or approved ELAP methods. All Quality Control results are within acceptable limits except where noted as a notation and/or case summary.

Please feel free to contact us if you have any questions regarding your report(s) or invoice.

We value and thank you for your business.

Sincerely,

Shane Burr
Lab Director

CA ELAP Certification #3036



245 New York Ranch Rd, Suite A, Jackson, CA 95642 (209)868-2100
 shane@49erwaterlab.com / www.49erwaterlab.com

Client: Sierra Pump
Report To: 15780 Butte Mountain Rd
 Jackson, CA 95642

Reported: 03/14/2026
Order No: 34281

Analysis Report

Sample Description: Sierra Pump - Drinking Water

Sample No: 89256

Location: 7230 Latigo St, San Andreas

Point of Collection: Well

Sampled: 03/12/2026 12:00

Received: 03/13/2026 12:42

<u>Analyte</u>	<u>Category</u>	<u>Results</u>	<u>Units</u>	<u>MDL</u>	<u>RL</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Method</u>
Total Coliform Bacteria P/A (Colilert-24)	Bacteriological	Absent	P/A			03/13/26 14:10	03/14/26 14:15	SM 9223B Colilert
E.Coli P/A (Colilert-24)	Bacteriological	Absent	P/A			03/13/26 14:10	03/14/26 14:15	SM 9223B Colilert

Quality Control Data

<u>Analyte</u>	<u>Result</u>	<u>RL</u>	<u>Units</u>	<u>Spike Level</u>	<u>Source Result</u>	<u>MDL</u>	<u>% REC</u>	<u>% REC Limits</u>	<u>RPD</u>	<u>RPD Limit</u>	<u>Notes</u>
----------------	---------------	-----------	--------------	--------------------	----------------------	------------	--------------	---------------------	------------	------------------	--------------

Signature of Completion:

Shane Burr
 Lab Director

Definitions

J - Detection of analyte above MDL but below RL
 ND - Non-Detection of analyte at MDL
 MDL - Method detection limit for analyte
 RL - Reporting limit for analyte
 RPD - Recovery % Different
 LCS/BS - Laboratory Control Sample or Blank Standard
 MS/MSD - Matrix Spike
 ICV - Initial Calibration Value
 CCV - Completion Calibration Value
 TNTC - Too Numerous to Count

Notations

Absent - Absent or Non-Detect for bacteriological testing

Conclusion

Sample 89256 - Sample is potable as per bacteriological testing for Total Coliform and/or E.Coli.



A FULL SERVICE ENVIRONMENTAL LAB

245 New York Ranch Rd, Suite A
Jackson, CA 95642
phone (209) 418-3175
email: atranle@49erwaterlab.com
www.49erwaterlab.com

CHAIN-OF-CUSTODY RECORD AND ANALYSIS REQUEST

[illegible]

49er Water Laboratory Forms	Doc. No.: FNW-FR035
	Revision No.: 1.4 Initials: SB
	Active Date: 10/1/2024 Approved by: LT
	Reference SOP: FNW-QM22
TITLE: SAMPLE RECEIVING AND INTEGRITY LOG SHEET	

Work Order # (Sample #): _____

Sample Receiving/Integrity

Received By: SB Logged By: SB Sample Accepted: ☒ Yes / ☐ No (if No explain in Comment/Status section reason for rejection of sample)

Date/Time: 3/13/26 12:00Customer Info: Stern PumpSample Transport: ☐ ONTRAC ☐ UPS ☐ USPS ☐ Walk-in ☒ Courier ☐ FedEx ☐ Other: _____Transported in: ☒ Ice Chest ☐ Box ☐ Ziploc/Plastic Bag ☐ Hand Delivery ☐ Other: _____

Has Chilling Process begun: ☒ Y / ☐ N Samples Received: ☐ Chilled to Touch ☐ Ambient ☒ On Ice
☐ In Storage Fridge

Temperature of Sample (°C): 5.3 Ice Chest Temperature: 0.4 Field Temperature: _____

*Corrected temperature is recorded, after taking temp, make the +/- from IR1 label & record temperature. (O) Observed (C) Corrected

Bottle/Sample Analysis Information

	Yes	No	N/A	Comments
Did bottles arrive unbroken and intact?	X			
Sample is within Hold Time?	X			
Did bottle labels agree with COC?	X			
Correct containers used?	X			Bottle Lot# if from Lab:
Were correct preservatives used for tests requested?	X			
Was there a sufficient sample volume?	X			
Were bubbles present in VOA Vials? (Volatile methods only)			X	
Chlorine Residual Check (Bacteriological ONLY)	X		SB	0.00 ND

Turn-Around Time: ☐ 1 Day Rush ☐ 5 Day Rush ☒ Standard COC completed: ☒ Y / ☐ N / ☐ N/APayment Information: Paid ☐ Y / ☒ N Bill ☒ Y / ☐ N _____Report Request via: ☐ Mail ☒ Email ☒ Portal Email: _____

	Comments/Status
Due Date:	
Samples in Order:	COC/Sample Receiving and Integrity: Scanned and Attached
Notification needed? (for bacteria and exceed of limits for Drinking H2O)	☐ Yes ☐ No ☐ N/A

Active Date: 10/1/2024

Page 1 of 1

Confidential Controlled Document