

PRECISION POWER EQUIPMENTS

*2058/59 E ShrikrishnaChembers
11 th Lane Rajarampuri, Kolhapur
Phone:(0231)2523232
Mobile:9822390717*

Quotation

To,

Date:30/01/2024

**The Additional Executive Engineer
Geeta Bhavan
Near Savitri Phule Hospital
Kolhapur**

Sub : Request for charging of 3 KW Ongrid Solar rooftop system.

Respected Sir ,

As per your testing team suggestions (Mr. Mulla Saheb), We had done corrections regarding 2 Pole MCB ,we have fitted 16A main switch. Also for negative DC , we have used DC Fuse and For Islanding Switch we have connection through RCCB Connection

We have fulfilled the suggestions given by testing team. Hence, I kindly request you to give permissions to charge the rooftop of 3 KW

Consumer Details:

Consumer name: Pradeep Shivilal Jain

Consumer No: 266516066571

Address: 2804B Bungalow No E2 Bhakti Pooja Nagar Kolhapur-416012

Thanking you,

**Yours Faithfully
(A.B.Kulkarni)**