T/A T/B — SUPPLY AIR DUCTWORK, RISING OR DROPPING
OPTIONAL NOTES — T/A = TO ABOVE, T/B = TO BELOW

T/A T/B — RETURN OR EXHAUST AIR DUCTWORK, RISING OR DROPPING
OPTIONAL NOTES — T/A = TO ABOVE, T/B = TO BELOW

SIZE L/S — SUPPLY AIR REGISTER

SIZE L/S — 4–WAY BLOW DIFFUSER

SIZE L/S — CIRCULAR FACE DIFFUSER

SIZE L/S — 2–WAY BLOW DIFFUSER

SIZE L/S — 2–WAY BLOW DIFFUSER

SIZE L/S — 4–WAY BLOW DIFFUSER BLANKED TO 3–WAY

SIZE L/S, SIZE L/S — RETURN OR EXHAUST GRILLE, FITTED WITH VOLUME DAMPERS UNLESS OTHERWISE SPECIFIED.

BEAM PENETRATION

FLEXIBLE ROUND DUCTWORK

FLEXIBLE DUCT CONNECTION

VCD VCD VCD — VOLUME CONTROL DAMPER

F D, F D — FIRE DAMPER WITH ACCESS PANEL

A P — ACCESS PANEL IN DUCT

M — MOTORISED DAMPER

NON RETURN DAMPER
NRD

PNEUMATIC DAMPER 520L/S SUPPLY AIR
P.D. 520L/S

SU — SET IN DUCTWORK IN DIRECTION OF ARROW
SU = SET UP
SD = SET DOWN

EDH L/S — ELECTRIC DUCT HEATER

WDH SIZE L/S — DUCT MOUNTED HOT WATER COIL

SDH SIZE L/S — DUCT MOUNTED STEAM COIL

ACCESS REQUIRED IN OTHERWISE INACCESSIBLE CEILING FOR HEATING COILS ETC.

ACCESS DOOR

VIBRATION ISOLATORS – SPRING

VIBRATION ISOLATORS

0.2 — 0.2 SQ.M GROSS AREA DOOR GRILLE WITH MIN. FREE AREA 55%

U/C — 25mm UNDERCUT TO DOOR

6 / 25 — SECTION 6 ON DRAWING No 25

W.L. W.L. — WATERPROOF FLUORESCENT LIGHT FITTING IN CONDITIONER HOUSING

VSD — MOTOR VARIABLE SPEED DRIVE

LO–SELECT — CONTROL SIGNAL SELECTOR

HI–SELECT — CONTROL SIGNAL SELECTOR

HUMIDIFIER

PITOT TUBE TRAVERSE STATION

SP — STATIC PRESSURE SENSOR

25mm INTERNAL INSULATION

50mm INTERNAL INSULATION

75mm INTERNAL INSULATION

FIRE RATED DUCTWORK

T — THERMOSTAT

T — TEMPERATURE SENSOR

H — HUMIDISTAT

H — HUMIDITY SENSOR

FG — FLOOR GRATE BY OTHERS

FLOOR GRATE

CW — COLD WATER POINT BY OTHERS FINISHED AT A STOP COCK

SINGLE–SIDED AIR DIFFUSER ON LIGHT FITTING

DOUBLE SIDED AIR DIFFUSER ON LIGHT FITTING

SUMP

SMOKE DETECTOR

SMOKE DETECTOR IN AIR DUCT

SMOKE DETECTOR IN CONCEALED SPACE

1LD–2800 80L/S — ONE SLOT LINEAR DIFFUSER, 2800mm LONG WITH 80L/S SUPPLY AIR

NOTES:

1. ALL DUCT DIMENSIONS ARE CLEAR INTERNAL SIZES
2. THE FIRST DUCT DIMENSION IS THE DIMENSION SEEN ON THE VIEW AS DRAWN.

REV.	REVISION DESCRIPTION		DATE
A	PRELIMINARY	A.S.	23/04/2018

AWP PROJECTS

Title
AIR CONDITIONING
SYMBOLS

Drawn G.K.	Date 23/04/2018	File AWP TITLE BLOCK.dwg	
Checked	Date	Approved	Date
Scale N.T.S		Plotted Date 24/04/2018	
Drawing Number AWP-M-01		Revision A	