

Annexure C

Appendix-XIII


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. MC/23-24/0113

Dated: 01.02.2024

It is certified that an inspection team headed by Mr. Rakesh Kitkule Health Officer (Name of Officers with designation) from Health department of municipality of Thane (Name of Department/ Office) inspected the Gagangiri Maharaj International School, Khopoli (Name & Address of the school) on 01.02.2024 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 01 (One) Year.

Signature with Seal:  Deputy Engineer,
P.W. Sub Div. No-3,
Thane

Name :

Designation : Sr. Health Officer

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

.....

.....

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

THANE COUNCIL OF SCIENTIFIC AND INDUSTRIAL RESEARCH(TCSIR)

Institute Name: Institute of National Analytical Research & Service (INARS)

Analysis Report

Analytical Service Call Reference No :Apr12589	Unit(Lab/Inst.)Ref. No – A-87
Lab Id – INS- 87	Sample Reciving Date – 18.04.2024
Sample ID- A-87	Submission Date -20.04.2024
	Report Delivery Date- 28.04.2024
Sample Description	Test Of Drinking Water
Client Details	Institution Name-Gangir International School, Khopoli
Number of Sample	02

Report Details :

Lab ID	Particulars of Supplied Sample	Parameters	Concentration	Portable Water Standard Limit(ECR1997)	Test Method(AHPA)
A-87	Drinking Water	Arsenic(As)	0.038 mg/L	0.05 mg/L	3114.C
		Hardness as CaCO ₃	279 mg/L	200-500 mg/L	2540.C
		Iron(Fe)	2.92 mg/L	0.3-1.0 mg/L	3111.B
		pH at 25.1°C	7.02	6.5-8.5	4500-H* . B
		TDS(Total Dissolved solids)	343 mg/L	1000 mg/L	2340.C


Analyst

Section/Division In-Charge


Executive Engineer,
P.W. Division No-1,
Thane