



केन्द्रीय प्रदूषण नियंत्रण बोर्ड
CENTRAL POLLUTION CONTROL BOARD

पर्यावरण, वन एवं जलवायु परिवर्तन मंत्रालय भारत सरकार
MINISTRY OF ENVIRONMENT, FOREST & CLIMATE CHANGE GOVT. OF INDIA

SPEED POST

F. No. B-190193/NGRBA (RG)/CPCB/P&P/7/2016-17

Date: 16.06.2017

To,

Sh. R. C. Saxena
Regional Director
Regional Directorate (E)
Central Pollution Control Board
South End Conclave, Block 502, 5th & 6th floors,
1582, Rajdanga Main Road,
Kolkata-700107

Subject: Re- Inspection of M/s Ballavpur Paper Manufacturing Ltd., P.O.- Ballavpur, Ranigunge, Burdwan (W.B.)

Sir,

This is in reference to the show cause notice dated 03-03-2017 issued under section 5 of Environment (Protection) Act 1986 to M/s Ballavpur Paper Manufacturing Ltd., P.O. - Ballavpur, Ranigunge, Burdwan (W.B.)

The unit has replied through letter dated 11-04-2017 (as annexed) regarding the OCEMS connectivity with CPCB server.

You are requested to carry out inspection to verify the compliance status of the unit including ETP performance analysis and forward the inspection report along with recommendations within 15 days.

Yours faithfully

(A.K. Vidyarthi)

Addl. Director & I/c
WQM-II

Encl: As above.

‘परिवेश भवन’ पूर्वी अर्जुन नगर, दिल्ली-110032

Parivesh Bhawan, East Arjun Nagar, Delhi-110032

दूरभाष/Tel : 43102030, 22305792, वेबसाइट/Website : www.cpcb.nic.in



BALLAVPUR PAPER MFG. LTD.

CIN - U22219WB2006PLC111265

Our Ref.: BPML/KOL/CPCB/008/2017-18.
Date: 4th April, 2017

The Chairman,
Central Pollution Control Board
Parivesh Bhawan, East Arjun Nagar
Delhi - 110 032.

CHAIRMAN OFFICE
C. P. C. B.
No. 10529
Date 11/4

Comments on
letter to M.
IPC #11 14.04

Sub: Reply against Inspection Report of the treated water collected from ETP of our Paper Plant, Raniganj, Burdwan, West Bengal, by the Additional Director, Central Pollution Control Board.

Respected Sir,

This has reference to your letter F No.B-190193/NGRBA(RG)/CPCB/P&P/07/2016-17/24550 dt.03-03-2017 regarding Inspection Report of the treated water collected from ETP of our Paper Plant, Raniganj, Burdwan, West Bengal, by the Additional Director, Central Pollution Control Board.

We are surprised to get your aforesaid letter in which the analysis report of the treated effluent sample collected by your Additional Director on 11-01-2017 including his observations. We are giving below our remarks:-

	Your observations	Our remarks
1	The unit along with the ETP was found operational.	OK
2	The unit has valid consent under Water & Air Acts up to January 31, 2016.	OK. Consent has been further extended for another 5 years by the Chief Engineer, WBPCB (up to 31-01-2021).
3	The water consumption of the unit is 650-700 KLD (6.56KL/T of paper produced) and waste water generation is 2.81 KL/T of paper produced.	OK
4	The ETP is upgraded up to tertiary treatment.	OK
5	OCEMS was installed in the unit and is connected to the CPCB server. OCEMS readings of pH - 7.49, BOD - 10.83 mg/l, COD-89.80 mg/l and TSS-19.70 mg/l were displayed.	OK

.....2..



(2)

	Your observations	Our remarks
6	The analysis report of treated effluent sample showed pH-7.91, BOD-72 mg/l (as against 30 mg/l), COD-1800 mg/l (as against 250 mg/l) and TSS-52 mg/l (as against 50 mg/l) which indicate non-compliance with respect to notified standards.	The analysis report of treated effluent sample collected by your Additional Director is showing a wide variation from OCEMS. Sir, we are regularly monitoring the report of treated effluent sample but we could not understand how the analysis report is showing so much variation. <u>We feel that there may be some variations from our figures but we cannot understand the reason for wide variation in the readings.</u> In this respect we are attaching herewith the reports of our treated samples taken by the officials of WBPCB (Feb'16 to Dec'16) which is showing that all the readings are within the prescribed norms of Pollution Control Board (Xerox copy enclosed). <u>Anyhow, we are taking this matter very seriously and we are instructing our Engineer who is looking after ETP to have more vigilance.</u> We also request you to give necessary instruction to your officials to have another visit for collecting samples.

We are also attaching herewith the readings of OCEMS dt.10-01-2017 & 11-01-2017 installed in our ETP which also indicates that all the figures are within the prescribed limit.

Thanking you,

Yours faithfully

For Ballavpur Paper Manufacturing Ltd.

Managing Director

Encl: as above.

Cc: The Additional Director
Central Pollution Control Board
Southend Conclave, 502, 5th Floor, 1582, Rajdanga Main Road
Kolkata - 700 107.