

VENUS



# VENUS TESTING & RESEARCH LABORATORY

(Accredited as per ISO/IEC - 17025 : 2005)

Venus House, Near Nagar Palika Office, Ayodhya By Pass Road, Village Damkheda, Bhopal (M.P.) 462041  
Ph. : 0755-2800181, Mob. : 9425019482, 9425425873, Email : vtrlbhopal@gmail.com

## TEST REPORT

Description of Sample : Drinking Water

Report No.: VTRL/BPL/1306/102/2018

Sub. : Testing of Water

Date of Receipt: 12/02/2018

Date of Report: 15 /02/2018

Issued To,

प्रशासनिक अधिकारी

ऐशिया पैसिफिक इंटरनेशनल स्कूल,

भोपाल (म० प्र०)

प्राचार्य/ PRINCIPAL

S.No.	Essential Characteristics	Test Value	Requirement as per IS:10500:2012		Method of Test
			Desirable Limit Max.	Permissible Limit in the Absence of Alternate Source Max.	
1.	pH Value	7.12	6.5 - 8.5	---	IS:3025:2005
2.	Color, Hazen unit	<5	5	15	IS:3025:2005
3.	Odour	Agreeable	Agreeable	---	IS:3025:2005
4.	Taste	Agreeable	Agreeable	---	IS:3025:2005
5.	Turbidity, NTU	0.2	1.0	5.0	IS:3025:2005
6.	Total Hardness, as CaCO <sub>3</sub> , mg/l	100	200	600	IS:3025:2005
7.	Chloride as Cl, mg/l	42	250	1000	IS:3025:2005
8.	Residual Free Chlorine, Cl mg/l	Nil	0.2	1	IS:3025:2005
9.	Iron as-Fe, mg/l	0.028	0.3	-	IS:3025:2005
10.	Fluoride, F mg/l	0.21	1.0	1.5	IS:3025:2005
Bacteriological Test					
1.	Total Coliform, (MPN)/100 ml	Nil	Shall not be detectable in any 100-ml.sample		IS-1622-2005
2.	E.Coli.	Negative	Shall not be detectable in any 100-ml.sample		IS-1622-2005

Remark: - Water sample confirms IS: 10500 and can be used for drinking purpose.

End of Page

(Authorised Signatory)

1. This report is valid only for the sample tested and for the purpose specified. It is not valid for any other purpose.  
2. This report is not valid for the sample tested and for the purpose specified. It is not valid for any other purpose.  
3. This report is not valid for the sample tested and for the purpose specified. It is not valid for any other purpose.

Central Laboratory : Certified by 'STQC' Government of India  
Khurai Road, Industrial Area, Bina, Distt. Sagar (M.P.) Pin 470113  
Ph.: 07580-221542, E-mail : vtrlbina@yahoo.co.in


PRINCIPAL  
ASIA PACIFIC INTERNATIONAL SCHOOL  
KOLAR ROAD, BHOPAL

## प्रमाण-पत्र

प्रमाणित किया जाता है कि श्रीमती रामादेवी स्मृति संस्थान के अन्तर्गत ऐशिया पेसिफिक इंटरनेशनल स्कूल खसरा क्रमांक 8 एवं 9 ग्राम काकरिया नगर पालिका कोलार क्षेत्रान्तर्गत स्थित है। जिसका रकबा 5.58 एकड़ में स्कूल बिल्डिंग का निरीक्षण किया गया है। निरीक्षण के दौरान देखा गया कि स्कूल परिसर में पर्याप्त साफ सफाई एवं छात्र-छात्राओं के लिए पृथक शौचालयों की उत्तम व्यवस्था है।


उपरोक्तानुसार सूचनार्थ ।


दिनांक : 16/06/2018

  
स्वच्छता प्रभारी  
प्रमुख अधिकारी  
जून-19

नगर निगम, भोपाल

नगर पालिका निगम, भोपाल

  
PRINCIPAL  
ASIA PACIFIC INTERNATIONAL SCHOOL  
KOLAR ROAD, BHOPAL



प्राचार्य/ PRINCIPAL

केन्द्रीय विद्यालय/ KENDRIYA VIDYALAYA

सीहोर (म.प्र.)/ SEHORE (M.P.)