



OISD – STD – 152

**SAFETY INSTRUMENTATION FOR PROCESS SYSTEM
IN HYDROCARBON INDUSTRY**

UPDATION-01

Date: 23.02.2022

Clause No.	Existing description	Updated description
4.2.11 STORAGE TANKS	Following safety instrumentation shall be provided in line with OISD-STD-108: Tanks shall be provided with at least two numbers of level instruments working on different principles and one level indicator shall be Radar gauge type for at least class A Storage tanks. One of the above shall be used for High-High and Low level alarms.	Following safety instrumentation shall be provided in line with OISD-STD-108: Tanks shall be provided with at least two numbers of independent level instruments working on different principles and one level indicator shall be Radar gauge type for at least class A Storage tanks. One of the above shall be used for High-High and Low level alarms. However, both independent level instruments can also be radar gauges.
4.2.14.iii	Level gauging devices #1 LPG spheres shall be provided with two independent indicators as a minimum.	Each storage vessel shall have at least two nos independent level instruments, each working on different principles. However, both independent level instruments can also be radar gauges.
