Manual Swing Fire Door

Door Type	Fire Rated Swing Door
Description	BS 476 part(20 & 22)tested at A.CBRI :Central Building Research Institute, Roorkee. B.ARAI :Automotive Research Association Of India.
Fire rating	120 Minute (2 Hours) for Integrity and stability.
Frame	Thickness 1.5 mm thick sheet (Double Rabbet: 150 x 70 mm).
Shutter	Thickness 46 mm manufactured in 1.2 mm thick Sheet.
Material of Construction	Galvanized Steel.
Infill	Rock wool.
Finish	PU Paint customizable
Type of Doors	Single Leaf / Double Leaf
Hinges	SS Ball bearing hinges suitable for door thickness.
Hardware Optional	Hardware such as Panic devices, External Devise, Mortise Locks, Cylinder Locks, Hydraulic Doors Closer, Concealed Tower bolts & Vision Panels can be used as per service requirements.