NIHVA	QUALITY ASSURANCE PLAN		Document No.- NIHVA - QA - F - 08 REVISION NO.:- 00 Revision date: _ Date of origin:- 01-01-2018	
Product	HMPS DOOR		Updared date: 02-04-2024	
Sr. No.	Subject	Parameter	Checking Type	Checking Method	Inspection frequency
1	Raw material	GI Sheet	IS 277:2018 standard	TC Verifying	100%
		GI Sheet	IS 277 GP 250	TC Verifying	100%
2	Assembly Process				
2.1	Door Leaf	Length	Dimensional	Steel tape	10%
		Width		Steel tape	10%
		Thickness		Steel tape	10%
		Dent. Damage	Visual	Visual	100%
2.2	Frame outer dimension	Height	Dimensional	Steel tape	10%
		Width		Steel tape	10%
		Bend,twist	Visual	Visual	100%
2.3	Window dimension	Length	Dimensional	Steel tape	10%
		Width		Steel tape	10%
		Crack	Visual	Visual	100%
3	Surface Finish	Matching with RAL Pad		Visual	10%
		Coating thickness	60-70µ	DFT Meter	10%

Prepared by: Maruti Yamgar

Approved by: Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. * PUNE *