MURBAD, INDIA

TEST CERTIFICATE FOR STEEL TUBES

Format No.: QA-F-18
Rev.no. : 00
Date : 10.10.2017

APL APOLLO TUBES LIMITED UNIT-III

Works-Vill-Kudavali Plot No-M-1, Murbad, 421401, Thane (MS)

TEST CERTIFICATE FOR STEEL TUBES

IS: 1239

CM/L-7078173

TEST CERTIFICATE NO :	**IS1239/015**
DATE :	**19-10-22**
INVOICE NO:	**2105820067**
INVOICE DATE:	**19-10-22**

To,

M/s Apl Apollo Tubes Ltd Pune

We certify that the material described below fully conformed to IS 1239 (Pt. 1): 2004. Chemical composition and Mechanical properties of the product, as tested in accordance with the scheme of testing and inspection contained in the BIS certification marks license no. CM/L-7078173 are as indicated below against each order no.

TEST RESULT

Size	Class/ Type	Cast no. / Lot No	Total Pcs.	Total Weight (MT).	CHEMICAL ANALYSIS (% Max)				MECHANICAL PROPERTIES (Min)				GALVANIZING (Min)	
					C	Mn	P	S	Tensile Strength (Mpa)	Above25mm/ Up to 25mm %El	Flattening	Bend Test	Weight (g/m2)	Uniformity
Requirements					**0.20**	**1.30**	**0.04**	**0.04**	**320**	**20 / 12**	**75% & 60% OD**	**6D / 8D**	**360**	**5 Dip (1Dip/ Minute)**
25 NB	MEDIUM / BLK	**21101675 / 2210419A**	349	4.98	0.042	0.145	0.019	0.006	392	31	NA	OK	-	-
25 NB	LIGHT / BLK	**21301483 / 2210418A**	243	2.78	0.043	0.125	0.015	0.006	386	33	NA	OK	-	-
40 NB	MEDIUM / BLK	**21400823 / 2210330A**	129	2.56	0.042	0.108	0.009	0.006	397	33	NA	OK	-	-
80 NB	LIGHT / BLK	**21101675 / 6210419A**	164	6	0.042	0.145	0.019	0.006	392	31	OK	NA	-	-

It is certified that each steel tube is hydrostatically tested to test pressure of 5 Mpa. Material supplied conforms to standard dimensions and

AUTHORISED SIGNATORY

APL APOLLO TUBES LTD. MURBAD

PREPARED BY

(FOR APL APOLLO TUBES LIMITED)