




GROUND FLOOR PLAN
1:75



TERRACE FLOOR PLAN
1:75



KEY PLAN

FOR HANDRAIL,JOINERY,FLOORING PATTERN,COLOR SCHEME DOOR, WINDOW SPECIFICATIONS PLEASE REFER
STANDARD ARCH DETAIL DRAWING - TPL-3452-X9690-EC-AC-6400
DOORS,WINDOWS DETAIL DRAWING - TPL-3452-X9690-EC-AC-6401
CAGE LADDER DETAIL DRAWING - TPL-3452-X9690-EC-AC-6402

NOTES

1. ALL DIMENSIONS ARE IN MILLIMETRES AND LEVELS ARE IN METRES, UNO.
2. FGL EL.(±)0.000 CORRESPONDS TO RL. 43.800
3. THICKNESS OF ALL THE MASONRY WALLS SHOWN IN THE DRAWING SHALL BE 250MM IN CM(1:6)
4. ALL DIMENSIONS OF MASONRY WALL, COLUMNS, BEAMS WALL THICKNESS, DOOR/WINDOW/VENTILATOR/ROLLING SHUTTER OR ANY OTHER OPENINGS, ARE SHOWN EXCLUSIVE OF PLASTER,FINISHING OR FRAMES.

LEGEND

FGL - FINISHED GROUND LEVEL
FFL - FINISHED FLOOR LEVEL
EL - ELEVATION
TYP - TYPICAL

REFERENCE

1. FOR RC DETAILS OF FOUNDATION, PLINTH & TIE BEAM REFER DWG NO: TPL-3452-X9560-EC-RC-6110 & 6111

ENGG. REFERENCE

1. FOR GA OF FIRE WATER CUM WTP PUMP HOUSE REFER DWG NO: TPL-3452-X5500-EM-GA-1203

SCHEDULE OF EXTERNAL FINISHES

ROOFING	RCC
WALLS	250THK EXTERNAL BRICK WALLS, OVERALL 18MM THK CEMENT MORTAR PLASTERING WITH AN UNDER LAYER OF 12MM THK IN CM 1:5 AND TOP LAYER OF 6MM TH IN CM 1:5 WITH WEATHER SHIELD PAINT.
	FOR RCC WALL DETAILS REFER STRU. DRG.NO. 6110 & 6111
RWP	150 mm ø PVC DOWN TAKE PIPES - 2 NOS.
PAINT	TWO COATS OF WEATHER SHIELD PAINT OF BERGER MAKE OR APPROVED EQUIVALENT
WATER PROOFING (TERRACE)	BRICKBAT COBA OR EQUALENT

SCHEDULE OF INTERNAL FINISH:

FLOORING	VDF FLOOR OVER SEALED COAT AND EPOXY (2MM THK)
WALLS	250THK BRICK WALLS, OVERALL 15MM THK CEMENT MORTAR PLASTERING IN CM 1:5 WITH PLASTIC EMULSION PAINT
CEILING	6MM THK CEMENT MORTAR PLASTERING IN CM 1:5. WITH WATER BOUND DISTEMPER PAINT.
PAINT	TWO COATS OF PLASTIC ACRYLIC EMULSION OVER A COAT OF PRIMER

GRADE SLAB IS UNDER HOLD

FIRE WATER TANK-1 (SUPPLIED BY WT VENDOR)

FLANGE MARKING	PUDDLE FLANGE	PIPE SIZE	LEVEL	QUANTITY
PP-01	420SQ. 10 MM THK. PLATE	200 NB	ON SLAB	1 NO
PP-02	367SQ. 10 MM THK. PLATE	150 NB	ON SLAB	1 NO
PP-03	473SQ. 10 MM THK. PLATE	250 NB	CL.EL(+)1.163 (HOLD)	2 NOS
PP-04	315SQ. 10 MM THK. PLATE	100 NB	ON SLAB	1 NO
PP-05	235SQ. 10 MM THK. PLATE	25 NB	ON SLAB	3 NOS
PP-06	420SQ. 10 MM THK. PLATE	200 NB	CL.EL(+) 4.0	2 NOS
PP-07	315SQ. 10 MM THK. PLATE	100 NB	ON SLAB	1 NO
PP-08	420SQ. 10 MM THK. PLATE	200 NB	CL.EL(+) 4.31	1 NO
PP-13	290SQ. 10 MM THK. PLATE	80 NB	BOP.EL(+)0.525	1 NO

FIRE WATER TANK-2 (SUPPLIED BY VENDOR)


FLANGE MARKING	PUDDLE FLANGE	PIPE SIZE	LEVEL	QUANTITY
PP-01	420SQ. 10 MM THK. PLATE	200 NB	ON SLAB	1 NO
PP-02	367SQ. 10 MM THK. PLATE	150 NB	ON SLAB	1 NO
PP-03	473SQ. 10 MM THK. PLATE	250 NB	CL.EL(+)1.163 (HOLD)	2 NOS
PP-04	315SQ. 10 MM THK. PLATE	100 NB	ON SLAB	1 NO
PP-05	235SQ. 10 MM THK. PLATE	25 NB	ON SLAB	3 NOS
PP-13	290SQ. 10 MM THK. PLATE	80 NB	BOP.EL(+)0.525	1 NO

RAW WATER TANK (SUPPLIED BY VENDOR)


FLANGE MARKING	PUDDLE FLANGE	PIPE SIZE	LEVEL	QUANTITY
PP-02	367SQ. 10 MM THK. PLATE	150 NB	ON SLAB	1 NO
PP-04	315SQ. 10 MM THK. PLATE	100 NB	ON SLAB	1 NO
PP-05	235SQ. 10 MM THK. PLATE	25 NB	ON SLAB	3 NOS
PP-06	420SQ. 10 MM THK. PLATE	200 NB	CL.EL(+) 4.0	1 NO
PP-10	367SQ. 10 MM THK. PLATE	150 NB	CL.EL(+)1.216 (HOLD)	1 NO
PP-12	367SQ. 10 MM THK. PLATE	150 NB	CL.EL(+) 4.25	1 NO
PP-13	290SQ. 10 MM THK. PLATE	80 NB	BOP.EL(+)0.525	1 NO

DOMESTIC WATER TANK (SUPPLIED BY VENDOR)


FLANGE MARKING	PUDDLE FLANGE	PIPE SIZE	LEVEL	QUANTITY
PP-02	367SQ. 10 MM THK. PLATE	150 NB	ON SLAB	1 NO
PP-04	315SQ. 10 MM THK. PLATE	100 NB	ON SLAB	1 NO
PP-05	235SQ. 10 MM THK. PLATE	25 NB	ON SLAB	3 NOS
PP-10	367SQ. 10 MM THK. PLATE	150 NB	CL.EL(+)1.216 (HOLD)	1 NO
PP-11	290SQ. 10 MM THK. PLATE	80 NB	ON SLAB	1 NO
PP-12	367SQ. 10 MM THK. PLATE	150 NB	CL.EL(+) 4.25	1 NO
PP-13	290SQ. 10 MM THK. PLATE	80 NB	BOP.EL(+)0.525	1 NO




TYP. DETAIL OF PLINTH PROTECTION
1:20




SECTION X-X
1:20




TYP. FIXING DETAIL OF PUDDLE FLANGE
1:20



DETAIL OF PUDDLE FLANGE



ROOF TREATMENT WITH WATER PROOFING
1:20



TYPICAL DETAIL OF LINTEL WITH CHAJJA/BEDROOM ALOFT
(300MM PROJECTION ON EITHER SIDE OF OPENING FOR CHAJJA)
1:20

AREA STATEMENT :-

GROUND FLOOR : 386 sqm

SCHEDULE OF OPENINGS:

S.NO	DESCRIPTION	MARKING	OPENING SIZE WIDTH	OPENING SIZE HEIGHT	MATERIAL	NO'S
1	ROLLING SHUTTER	RS	3000	4000	ROLLING SHUTTER (PARTLY LATHED & PARTLY GRILLED) MECHANICALLY OPERATED	1
2	WINDOWS	W1	2400	1500	MS PROFILED FULLY OPENABLE WINDOWS WITH 6MM GLASS SHUTTERS,	2
3	WINDOW WITH LOUVER	W2/V1	2400	1200+300	MS PROFILED FULLY OPENABLE WINDOWS WITH 6MM GLASS SHUTTERS,+ALU. LOUVERED	2
4	STEEL DOOR	D1	1200	2400	GALVANIZED STEEL FLUSH DOOR CONFIRMING TO IS 277 WITH VISION GLASS SIZE OF 300MMx600MM	1
5	MAN HOLE (MH)	MH	600	600	MAN HOLE	6
6	EXHAUST FAN	FAN	530 DIA		EXHAUST FAN	2

REV.NO.	DATE	REVISION	CIVIL	MECH	ELEC	INST	APPD
3	27.02.17	REVISED AS PER SITE CONDITION					AS
2	07.02.17	ISSUED FOR APPROVAL					AS
1	25.01.17	ISSUED FOR APPROVAL					AS
0	30.12.16	ISSUED FOR APPROVAL					AS
			CLEARED				

THIS DRAWING IS PROPERTY OF "TATA PROJECTS LIMITED" MUST NOT BE PASSED ON TO ANY PERSON OR BODY NOT AUTHORIZED BY US T IT NOR BE COPIED OR OTHERWISE MADE USE EITHER IN FULL OR IN PART BY SUCH PERSON OR BODY WITHOUT OUR PRIOR PERMISSION IN WRI

EPC CONTRACTOR
TATA PROJECTS LIMITED
H. NO.1-7-80 TO 87, "MITHONA TOWERS – 1"
PRENDERGHAST ROAD, SECUNDERABAD – 500003.

PROJECT TITLE
PLANT FACILITY FOR MADHEPURA ELECTRIC LOCOMOTIVE PRIVATE LIM
AT MADHEPURA, BIHAR.

OWNER
MADHEPURA ELECTRIC LOCOMOTIVE PRIVATE LIM


OWNER A/E CONSULTANT :
SEMAC CONSULTANTS PVT LTD
6-1-276, 2ND FLOOR, ARCHANA BLOCK, CONJEEVARAM HOUSE, PADMARAO NAGAR SECUNDERABAD – 500025.

	SIGNATURE	DATE
DRAWN	MZ	03.02.17
DESIGNED	SR	03.02.17
CHECKED	AS	03.02.17
DEPT.HEAD	AS	03.02.17


RELEASED FOR: INFORMATION, APPROVAL, ENGINEERING, CONSTRUCTION ✓

DWG. TITLE:
FIRE WATER CUM WTP PUMP HOUSE ARCHITECTURAL PLAN (FACTORY AREA)


DEPT. CIVIL JOB NO. 0000 SCALE: – SHEET: 1 OF 2
FILE NAME. ALSTOM-M-AR-WP-101
DWG.NO. TPL-3452-X9420-EC-AC-6240




ELEVATION – 01
1:75




ELEVATION – 02
1:75




ELEVATION – 03
1:75




SECTION 1–1
1:75




ELEVATION – 04
1:75




SECTION 2–2
1:75




SECTION 3–3
1:75




TYPICAL DETAIL OF HAND RAIL
(ALL PIPES ARE 1.6 THK)
1:20




SECTION 8–8
1:20



SECTION 9–9
1:20



DET. OF INSERT PLATE (IP1)
1:10



IP1 DET. AT WALL
1:10

NOTES

1. ALL DIMENSIONS ARE IN MILLIMETRES AND LEVELS ARE IN METRES, UNO.
2. THICKNESS OF ALL THE MASONRY WALLS SHOWN IN THE DRAWING SHALL BE 250MM IN CM(1:6)
3. ALL DIMENSIONS OF MASONRY WALL, COLUMNS, BEAMS WALL THICKNESS, DOOR/WINDOW/VENTILATOR/ROLLING SHUTTER OR ANY OTHER OPENINGS, ARE SHOWN EXCLUSIVE OF PLASTER,FINISHING OR FRAMES.

LEGEND

FGL - FINISHED GROUND LEVEL
FFL - FINISHED FLOOR LEVEL
EL - ELEVATION
TYP - TYPICAL

REFERENCE

1. FOR RC DETAILS OF FOUNDATION, PLINTH & TIE BEAM REFER DWG NO: TPL-3452-X9560-EC-RC-6110 & 6111

ENGG. REFERENCE

1. FOR GA OF FIRE WATER CUM WTP PUMP HOUSE REFER DWG NO: TPL-3452-X5500-EM-GA-1203

REV.NO.	DATE	REVISION	SR	CIVIL	MECH	ELEC	INST	APPD	DRAWN
3	27.02.17	REVISED AS PER SITE CONDITION	SR					AS	MZ
2	03.02.17	ISSUED FOR APPROVAL	SR					AS	MZ
1	23.01.17	ISSUED FOR APPROVAL	SR					AS	GMN
0	03.02.17	ISSUED FOR APPROVAL	SR					AS	GMN
				CLEARED					

THIS DRAWING IS PROPERTY OF **"TATA PROJECTS LIMITED"** MUST NOT BE PASSED ON TO ANY PERSON OR BODY NOT AUTHORIZED BY US TO RECEIVE IT NOR BE COPIED OR OTHERWISE MADE USE EITHER IN FULL OR IN PART BY SUCH PERSON OR BODY WITHOUT OUR PRIOR PERMISSION IN WRITING.

EPC CONTRACTOR
TATA PROJECTS LIMITED
H. NO.1-7-80 TO 87, "MITHONA TOWERS – 1"
PRENDERGHAST ROAD, SECUNDERABAD – 500003.

PROJECT TITLE
PLANT FACILITY FOR
MADHEPURA ELECTRIC LOCOMOTIVE PRIVATE LIMITED
AT MADHEPURA, BIHAR.

OWNER
MADHEPURA ELECTRIC LOCOMOTIVE PRIVATE LIMITED

OWNER A/E CONSULTANT :
SEMAC CONSULTANTS PVT LTD
6-1-276, 2ND FLOOR, ARCHANA BLOCK,
CONJEEVARAM HOUSE, PADMARAO NAGAR
SECUNDERABAD – 500025.

	SIGNATURE	DATE
DRAWN	MZ	03.02.17
DESIGNED	SR	03.02.17
CHECKED	AS	03.02.17
DEPT.HEAD	AS	03.02.17

DWG. TITLE:
FIRE WATER CUM WTP PUMP HOUSE
SECTIONS & ELEVATIONS (FACTORY AREA)

RELEASED FOR: INFORMATION, APPROVAL, ENGINEERING, CONSTRUCTION (✓)

DEPT. CIVIL | JOB NO. 0000 | SCALE: – | SHEET: 2 OF 2 | SIZE : A0
FILE NAME. ALSTOM-M-AR-WP-101 | REV./ISSUE
DWG.NO. TPL-3452-X9420-EC-AC-6240 | R3