
HSSD2 High speed fabric doors - 9500mm x 6000mm

Please sheet ② of ②

Please support

23/01/2015




Please check the support for lateral stability

Please check the support for lateral stability

The complete footing work is over as per site condition and please propose the alternate supporting arrangement

Note #3

The supporting members for the fabric door will not with stand, please consider lateral supporting members for as much opening of 7705 x 9500 mm



structure should be bear approx. 7000 k.g. weight. (wind pressure included)

This drawing & designing is the property of NIHVA TECHNOLOGIES. Not be sold or copy to any other concern.

TITLE	ALL DIMENSION ARE IN mm			NIHVA TECHNOLOGIES PVT. LTD.	NIHVA TECHNOLOGY PVT. LTD. PUNE Tel : 020 66304033 Email:– info@nihva.com Website:– www.nihva.com
STRUCTURE FOR MEGADOOR		SIGN	DATE		
	DRAWN	ABHIJIT	22/01/15	CLIENT -REWARD	
CLIENT APPROVAL	CHECK	ANIL	22/01/15	PROJECT-IR PROJECT AHEMADABAAD	
	ENG			SITE -	
	APPRD.			DWG. NO. - NVA/REWARD/02/RE02	
	MFG			SCALE: 01	WT: SHEET: 01
	Ref. No.			If any queries contact : projects@nihva.com	