NIHVA
NIHVA Technologies Pvt. Ltd.

PRE DISPATCH INSPECTION REPORT

Format no.: NIHVA- QA-F-07	
Rev. no.: 00	
Rev date:	
Date of origin: 01.01.2017	

Client Name- SHREE PRE FAB STEELS PVT LTD — **Report No--**SO/23-24/060

Project Name- NTPL-209 — **Location-** NIHVA MANUFACTURING UNIT — **Date-12-03-2024**

Product Name- GI 1.2mm Gear Opearated Rolling Shutter (W 5000 mm X H 5000 mm) — **Qty-**01 NOS

Sr.No	Part Name	Drawing no.	Specification	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Curtain Length	NIHVA 22-23/SO/060	5210 ± 8	75	5210	5212	5210	Steel Tape	OK
2	Curtain width	NIHVA 22-23/SO/060	75 ± 1.5		76.22	76.22	76.18	Digital Vernier caliper	OK
3	Curtain Thickness	NIHVA 22-23/SO/060	1.2 ± 0.2		1.2	1.2	1.21	Digital Micrometer	OK
4	Curtain Profile	NIHVA 22-23/SO/060	Curved		OK	OK	OK	Visual	OK
5	M.S. Bottom length	NIHVA 22-23/SO/060	5210 ± 8	1	5210			Steel Tape	OK
6	M.S. Bottom width	NIHVA 22-23/SO/060	125 ± 2.5		127.31	–	–	Digital Vernier caliper	OK
7	M.S. Bottom thickness	NIHVA 22-23/SO/060	2 ± 0.2		1.995	–	–	Digital Micrometer	OK
8	Bottom lock	NIHVA 22-23/SO/060	–	2	OK	–	–	Visual	OK
9	Shaft assembly	NIHVA 22-23/SO/060		1	OK			Visual	OK
10	Hood cover Length	NIHVA 22-23/SO/060	5700 ± 8	1	5698		–	Steel Tape	OK
11	Hood cover width	NIHVA 22-23/SO/060	450 ± 4		452		–	Steel Tape	OK
12	Hood cover height	NIHVA 22-23/SO/060	450 ± 4		452	–	–	Steel Tape	OK
13	Hood cover thickness	NIHVA 22-23/SO/060	0.9 ± 0.2		0.8	–	–	Digital Micrometer	OK
14	Guide length	NIHVA 22-23/SO/060	5150 ± 8	2	5155	5152	–	Steel Tape	OK
15	Guide width	NIHVA 22-23/SO/060	130 ± 1.5		130	130	–	Steel Tape	OK
16	Guide thickness	NIHVA 22-23/SO/060	3.0 ± 0.2		2.969	2.998	–	Digital Micrometer	OK
17	M.S. Bracket (LxW)	NIHVA 22-23/SO/060	450x450	2	OK	OK	–	Steel Tape	OK
18	M.S. Bracket thickness	NIHVA 22-23/SO/060	5 ± 0.5		5.014	5.016	–	Digital Micrometer	OK
19	Gear Box & Handle	NIHVA 22-23/SO/060			OK		–	Visual	OK
20	Product name plate				NGRS1076			Visual	OK

Note-1) All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mK

Inspected By- Mahesh Tawgar

NIHVA TECHNOLOGIES PVT. LTD. ★ PUNE ★

Approved By- Amit Kurhade