ENQUIRY SITE VISIT REPORT

NIHVA
NIHVA TECHNOLOGIES PVT. LTD.

Purpose of visit	:- New Enquiry Site Visit Report		Date :- 24-01-2024
	:-		Format :- NIHVA-PRJ-F- 08
Client	:- Tata Motors Ltd		
Project	:- -		
Site Location	:- KSB		
Contact Person Name	:- Mr. Prashant Bilure Sir		
Product Name	:- Motorized Rolling shutter & Fire door		
product quantity	:- 08 Nos		
Sales Person Name	:-		
Attended by	:- Madhukar, Jitendra		

Actual Site Condition :- Wall Mounting (out side mounting)

1) Double wall Rolling shutter. Width 3000 MM x 3500 MM Height
2) Structure mounting Rolling shutter - Width 4000 x 4000 MM height (outside mounting)
3) MS structur Mounting Rolling shutter - Width 4000 x 2500 MM height
4) MS structure Mounting Rolling shutter. Width 2000 x 2600 MM Height

* They Required photocell provision for Single skinned Rolling shutter.

Solutions/Suggestion Readiness site :-

* Fire Door dimension :→
  1. Fire Door single leaf - 1000 width x 2500 MM Height
  2. Fire Door double Leaf - 2250 MM Width x 2980 MM Height
  3. Fire Door double Leaf - 2000 MM Width x 2950 MM Height
* 4. Fire Door single Leaf - 1000 MM Width x 2500 MM Height

Remark :- This visit is for dimension checking. As discussed We need wicket gate in (4x4m) Rolling shutter.

* Fire door will be confirmed.

Nihva Representative :- Madhukar Rathod	Client Representive :- Bilure P.L
Signature :- Rathod.	Signature :- Bilure
Date :- 24-01-2024	Date:- 24/01/2024

NIHVA NIHVA TECHNOLOGIES PVT. LTD. PUNE

Samrit Plaza, 1st Floor, G-Block, Thermax Chowk, Chinchwad, Pune - 411019.