NIHVA
NIHVA Technologies Pvt. Ltd.

Format no.: NIHVA- QA-F-07	
Rev. no.: 00	
Rev date:	
Date of origin: 01.01.2017	

Client Name- Smith Structures India Pvt. Ltd. **Report No--**SO/23-24/047(1)

Project Name- NTPL-207 **Location-** NIHVA MANUFACTURING UNIT **Date-01-04-2024**

Product Name- Fire door (W2400xH2100mm) **Qty-**14 NOS

Sr.No	Part Name		Dimension In mm	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Frame height		2095 ± 8	1	2095	2095	2095	Steel Tape	OK
2	Frame width		1190 ± 6	1	1187	1188	1187	Steel Tape	OK
3	Frame dimension		100 ± 1.5	1	99	99	99	Steel Tape	OK
4	Frame dimension		58 ± 1.5	1	59	59	59	Steel Tape	OK
5	Frame dimension		43 ± 1.5	1	43	43	43	Steel Tape	OK
6	Frame dimension		46 ± 1.5	1	47	47	47	Steel Tape	OK
7	Vision window location		1500± 6	1	1500	1500	1500	Steel Tape	OK
8	Vision window ID		300 ± 2.5	1	300	300	300	Steel Tape	OK
9	Product name plate			NOT AVAILABLE					_
Test certificate(BS 476 Part 22 & MS 1073 Part 3 1988)				Not available					_

Remark- All Material Are visually & dimensionally found ok

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

Approved By- Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. PUNE

NIHVA
NIHVA Technologies Pvt. Ltd.

Format no.: NIHVA- QA-F-07	
Rev. no.: 00	
Rev date:	
Date of origin: 01.01.2017	

Client Name- Smith Structures India Pvt. Ltd. **Report No--**SO/23-24/047(2)

Project Name- NTPL-207 **Location-** NIHVA MANUFACTURING UNIT **Date-01-04-2024**

Product Name- Fire door (W2400xH2100mm) **Qty-**09 NOS

Sr.No	Part Name		Dimension In mm	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Frame height		2095 ± 8	1	2095	2094	2095	Steel Tape	OK
2	Frame width		2390 ± 8	1	2391	2391	2391	Steel Tape	OK
3	Frame dimension		100 ± 1.5	1	99	99	99	Steel Tape	OK
4	Frame dimension		58 ± 1.5	1	59	59	59	Steel Tape	OK
5	Frame dimension		43 ± 1.5	1	43	43	43	Steel Tape	OK
6	Frame dimension		46 ± 1.5	1	47	47	47	Steel Tape	OK
7	Vision window location		1500± 6	1	1500	1500	1500	Steel Tape	OK
8	Vision window ID		300 ± 2.5	1	300	300	300	Steel Tape	OK
9	Product name plate			NOT AVAILABLE					_
Test certificate(BS 476 Part 22 & MS 1073 Part 3 1988)				Not available					_

Remark- All Material Are visually & dimensionally found ok

Note-1)All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

Approved By- Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. PUNE