Date: 12-02-2019

GUARANTEE / WARRANTY CERTIFICATE

TO WHOM SO EVER IT MAY CONCERN:

We hereby certify that the Fire Rated Sliding Steel Door supplied to M/s RATNARUP PROJECTS PRIVATE LIMITED, Pune IN C/O Kingfa Science & Technology (India) Ltd, Chakan, Pune are covered by this standard warranty clause.

The details of materials supplied are:

Sr. No	Product	Size (mm)	Quantity (Nos)	Sr. No	Supply Date
1	Fire Rated Sliding Steel Door	1600 x 2200	01	NFRSD329	12-02-2019

Warranty: One year from the date of supply, against manufacturing defects, provided the product is used within its rated capacity & proper installation.

The Guarantee/Warranty on Hardware's failures or damages that may occur due to human error, natural calamities /or any other accidents/repair or mishandled by others does not cover under this warranty.

For NIHVA Technologies Pvt. Ltd.

Authorized Signatory

Office Add:- 187/ G-Block, 1st Floor, Thermax Chowk, MIDC, Above Renault Showroom, Chinchwad, Pune - 411019
Reg. Add:- 8/1 Coromant Heg. Soc. Sec. No. 27, Nigdi, Pradhikaran, Pune - 411044.
+91 2066 3040 33 +91 85 51091 333 sales@nihva.com www.nihva.com | CIN No U72900PN2012PTC143948

Date: 24-12-2018

GUARANTEE / WARRANTY CERTIFICATE

TO WHOM SO EVER IT MAY CONCERN:

We hereby certify that the Fire Rated Sliding Steel Door supplied to M/s RATNARUP PROJECTS PRIVATE LIMITED, Pune IN C/O Kingfa Science & Technology (India) Ltd, Chakan, Pune are covered by this standard warranty clause.

The details of materials supplied are:

Sr. No	Product	Size (mm)	Quantity (Nos)	Sr. No	Supply Date
1	Fire Rated Sliding Steel Door	1600 x 2200	01	NFRSD328	24-12-2018

Warranty: One year from the date of supply, against manufacturing defects, provided the product is used within its rated capacity & proper installation.

The Guarantee/Warranty on Hardware's failures or damages that may occur due to human error, natural calamities /or any other accidents/repair or mishandled by others does not cover under this warranty.

For NIHVA Technologies Pvt. Ltd.

Authorized Signatory

Office Add:- 187/ G-Block, 1st Floor, Thermax Chowk, MIDC, Above Renault Showroom, Chinchwad, Pune - 411019
Reg. Add:- 8/1 Coromant Heg. Soc. Sec. No. 27, Nigdi, Pradhikaran, Pune - 411044.
+91 2066 3040 33 +91 85 51091 333 sales@nihva.com www.nihva.com | CIN No U72900PN2012PTC143948

TEST SCHEDULE 1/1
(Reference No. – FR / 0212)

1.	**Name of the Laboratory**	: Fire Research Laboratory CSIR-Central Building Research Institute, Roorkee-247 667
2.	**Name of the Party**	: **M/s Radiant Safedoors Pvt. Ltd.,** 539 GIDC. Phase II, Vatva, **Ahmedabad-382445.**
3.	**Name of the Test**	: Fire Resistance Test
4.	**Date of Test**	: November19, 2015
5.	**Ambient Temperature**	: 11°C
6.	**Fire Exposure**	: As per BS:476,Part 20 & 22
7.	**Applicability if Test Criteria**	: Stability :Yes Integrity : Yes Insulation : Yes
8.	**Specimen Details**	: Double LeafSlidingG.I. Composite Fire Door (Counterweight System). **Door Dimensions (Panel)** Height : 3000 mm Width : 3200 mm Thickness : 40 mm Door Panel Thickness: 40 mm
9.	**Specimen Construction**	: As shown in Figure 1 (Drg. No. 1/1 -0212(1)&Drg. No. 1/1 -0212-(2))
10.	**Door Type**	: Insulated
11.	**Indented Test Duration**	: Two Hours

Test Results

The data of evaluation reveals that the double leaf slidingG.I. composite fire door with counterweight systemhasbeen found to be able to withstand standard fire exposure for 120 minutes (One Hundred Twenty minutes only) with respect to **stability, integrity and thermal insulation.**

(Sushil Kumar) **(Narendra Kumar)** **(Dr.Suvir Singh)**

(Technical data provided in this schedule pertains to the specific sample submitted to the Institute and tested. CBRI's name or logo cannot be used for commercial purposes. All procedural, legal, and/or operational matters will be the responsibility of the party using these results. Accepting / Rejecting the results, partly or fully rests with the users agencies.)