NIHVA NIHVA Technologies Pvt Ltd.	PRE DISPATCH INSPECTION REPORT	Format no.: NIHVA- QA-F-07 Rev. no.: 00 Rev date: Date of origin: 01.01.2017

Client Name-Power Erectors Pvt Ltd									
Project Name- Motorized Single Skin Rolling Shutter (W4220xH4800mm)			Location- NIHVA MANUFACTURING UNIT						Date-11-05-2024
Product Name- Motorized Single Skin Rolling Shutter (W4220xH4800mm)						Qty-01 NOS			
Sr.No	Part Name		Dimension In mm	Qty per Product	Observation			Instrument used	Remark
					1	2	3		
1	Curtain Length		4370 ± 8	72	4370	4370	4370	Steel Tape	OK
2	Curtain width		82 ± 1.5		81.44	81.72	81.74	Digital Vernier caliper	OK
3	Curtain Thickness		1.2 ± 0.2		1.16	1.17	1.16	Digital Vernier caliper	OK
4	Curtain Profile		Flat		Flat	Flat	Flat	Visual	OK
5	Hood cover length		4900 ± 8	1	4900	_	_	Steel Tape	OK
6	Hood cover width		450 ± 4		450	_	_	Steel Tape	OK
7	Hood cover height		450 ± 4		438	_	_	Steel Tape	Not OK
8	Hood cover thickness		0.9 ± 0.2		0.760	_	_	Digital Micrometer	OK
9	Roller Length		4415 ± 8	1	4415	_	_	Steel Tape	OK
10	Roller dia.		114 ± 2		115.1	_	_	Digital Vernier caliper	OK
11	Aluminium bottom Length		4370 ± 8	1	4370	_	_	Steel Tape	OK
12	Aluminium bottom width		100 ± 8		100	_	_	Steel Tape	OK
13	Guide length		4950 ± 8	2	4954	4954	_	Steel Tape	OK
14	Guide width		110 ± 1.5		108	109	_	Steel Tape	OK
15	Guide thickness		2.5 ± 0.2		2.535	3	_	Digital Micrometer	Conditionaly accepted
16	M.S. Bracket (LxW)		450x450	2	OK	OK	_	Steel Tape	OK
17	M.S. Bracket thickness		5 ± 0.5		4.971	5.013	_	Digital Micrometer	OK
18	Motor -Jielong 1PH, 800kg Indirect drive			1	OK			Visual	OK
19	Surface Finish		Duco paint RAL 5015		OK	OK	OK	Visual	OK
20	Coating thickness		70-90 µ	_	85.3 µ	81.3 µ	87.5 µ	DFT Meter	OK
21	Product name plate		Sr. No.		Not available			_	_

Remark- All Material Are visually & dimensionally found ok

Note-1) All dimensions are in mm 2) Tolerance used as per DIN ISO 2768 - mk

Inspected By- Maruti Yamgar

Approved By- Amit Kurhade

NIHVA TECHNOLOGIES PVT. LTD. ★ PUNE ★